



Event Date: 3/31/2013

Flowgate ID/Name: FG 1969 Ringgold – Sales 115kV flo Dolet Hills – SW Shreveport 345kV

Metrics Tables: TLR Date

TLR Date 3/31/2013 13:25 Return to Zero 4/1/2013 02:00

Duration 12 hours 35 minutes **Hours in TLR 5** 11 hours 35 minutes

0

 Highest Level
 5B

 MW Cut
 392

 Firm
 392

Non-Firm

NNL:

EES	4	LEPA	
AECI		ONT	
AMIL		PJM	
CLEC	82	SMEE	
CSWS		SOCO	
EDE		SPA	
LAFA		TVA	
LAGN		WSCS	

Flowgate information at the time of the TLR 5 issuance:

Line Rating: 115 LODF: 0.1611 PC MVA: 124 Contingent Element: 374 Monitored Element: 64

Root Cause:

During the afternoon of March 31, strong storms moved across Western Louisiana. Numerous forced outages from the storms led to increased post contingent loading in the Entergy and CLECO Transmission Area in Western Louisiana.

Planned or Unplanned Generation Outage(s): (none, if blank)

Type

Planned or Unplanned Transmission Outage(s): (none, if blank)

Type:

Unplanned Montgomery - Winfield 230kV 3/31/2013

Unplanned Montgomery - Colfax 230kV 3/31/2013

Unplanned Winfield - Cane River 115kV 3/31/2013

Unplanned Standard - Winfield 115kV 3/31/2013

Unplanned Red Gum - Standard 115kV 3/31/2013

Unplanned Lucky - Hodges 115kV 3/31/2013

Unplanned Chalky Bulk - Gillis - Moss Bluff 230kV 3/31/2013

Unplanned Mansfield-Red River 138kV line 3/31/2013

Tags Excluded from the TLR (The following tags were excluded for Reliability)

None

Internal Non-Firm Tags that were curtailed: No Internal Non-Firm tags were curtailed

Non-Firm AFC's suspended: AFC's were not suspended for the duration of this TLR 5

AFC Limitations before, during and after the TLR Event: MISSING

MISO ICTE Reliability: TLR 5 Event Analysis Report



Event Date: 3/31/2013

Flowgate ID/Name: FG 1969 Ringgold – Sales 115kV flo Dolet Hills – SW Shreveport 345kV

Event History:

TLR Event History 1969 - Ringgold-Sales 115kV ftlo Dolet Hills-SW Shreveport 345kV Flow Change Requested Remaining Requested Relief Relief Status TLR Effective Time Confirmation Time **Run Time** Tags MW Relief Tags MW Relief MF NNL 20 75 20 CH SUPERSEDED 5B 03/31/2013 13:25 03/31/2013 13:03 10 03/31/2013 13:04 -75.0 75.0 10 0 0 NH SUPERSEDED 5A 03/31/2013 15:00 03/31/2013 14:33 03/31/2013 14:32 0.0 NH SUPERSEDED 5A 03/31/2013 16:00 03/31/2013 15:26 03/31/2013 15:25 -10.0 27.0 39 6 SUPERSEDED 5A 03/31/2013 17:00 03/31/2013 16:27 03/31/2013 16:26 -5.0 24.0 0.0 32 40 6 40 5 8 32 <u>SUPERSEDED</u> 5A 03/31/2013 18:00 03/31/2013 17:30 03/31/2013 17:29 18.0 0.0 32 NH 0.0 26 6 5 15 9 SUPERSEDED 5A 03/31/2013 19:00 03/31/2013 18:28 -15.0 29.0 0.0 36 6 41 6 41 6 20 NH 03/31/2013 18:26 03/31/2013 19:30 SUPERSEDED 5A 03/31/2013 20:00 03/31/2013 19:29 -10.0 39.0 0.0 48 55 55 8 27 13 NH NH SUPERSEDED 5A 03/31/2013 21:00 03/31/2013 20:28 03/31/2013 20:27 27.0 6 SUPERSEDED 5A 03/31/2013 22:00 03/31/2013 21:28 0.0 32.0 0.0 42 47 6 47 7 10 SUPERSEDED 5A 03/31/2013 23:00 03/31/2013 22:26 03/31/2013 22:25 +5.0 26.0 0.0 36 40 7 40 5 8 0.0 SUPERSEDED 5A 04/01/2013 00:00 03/31/2013 23:31 03/31/2013 23:26 0.0 0.0 0 NH +38.0 0 0 0.0 0 SUPERSEDED 1 04/01/2013 01:00 04/01/2013 00:28 04/01/2013 00:27 0.0 0.0 0.0 0 0 0 NH 0.0 0.0 NH TERMINATED 0 04/01/2013 02:00 04/01/2013 01:03 04/01/2013 01:03 0.0 0.0

MISO ICTE Reliability: TLR 5 Event Analysis Report



Event Date: 3/31/2013

Flowgate ID/Name: FG 1969 Ringgold – Sales 115kV flo Dolet Hills – SW Shreveport 345kV

Event Summary:

Event Summary FILE SAVED AS: MISO_1969_20130331_1225.htm Incident: MISO 1969 20130331 1225 Date: 03/31/2013 (EST) Reliability Coordinator: MISO 1969 - Ringgold-Sales 115kV ftlo Dole... LODF: 16.11% TLR Direction: Normal Effective StartTime: 03/31/2013 13:25 (EST) Effective EndTime: 04/01/2013 02:00 (EST) TLR Duration: 12 Hours and 35 Minutes **TLR Actions** TLR Action Comr NEXT 0.0 0.0 16.2 0.0 16.2 Mar 31 14:33 (EST) 3.0 3.0 3.0 3.0 16.2 Mar 31 15:26 (EST) 7.0 1.0 **8.0** Mar 31 16:27 (EST) TLR 5A 0.0 0.0 15.1 0.0 **15.1** Mar 31 17:30 (EST) 12.0 0.0 **12.0** Mar 31 19:30 (EST) 55 **55** 7.8 **7.8** 7-F Total 0.0 27.4 Mar 31 20:28 (EST) Mar 31 21:28 (EST)

MISO ICTE Reliability: TLR 5 Event Analysis Report



Event Date: 3/31/2013

Flowgate ID/Name: FG 1969 Ringgold – Sales 115kV flo Dolet Hills – SW Shreveport 345kV

Mar 31 21:28 (EST)	TLR 5A	NEXT	7-F Total	6 / 0	47 47	6.6 6.6	47 47	6.6 6.6	0	0.0 0.0	CLEC EES Total	9.0 1.0 10.0	10.0 0.0 10.0	ED-2 ED-6 FIRM-7 FIRM-CREDIT Total	SWPP SWPP SWPP	0.0 0.0 25.2 0.0 25.2	0.0 0.0 25.2 0.0 25.2	0	0	0	NIA
Mar 31 22:26 (EST)	TLR 5A	NEXT	7-F Total	7/0 7/0	40 40	5.5 5.5	40 40	5.5 5.5	0	0.0 0.0	CLEC EES Total	8.0 1.0 9.0	8.0 0.0 8.0	ED-2 ED-6 FIRM-7 FIRM-CREDIT Total	SWPP SWPP SWPP SWPP	0.0 0.0 22.3 0.0 22.3	0.0 0.0 22.3 0.0 22.3	0	0	0	N/A
Mar 31 23:31 (EST)	TLR 5A	NEXT				NONE						NONE		ED-2 ED-6 FIRM-7 FIRM-CREDIT Total	SWPP SWPP SWPP SWPP	0.0 0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0 0.0	0	0	0	N/A
Apr 01 00:28 (EST)	TLR 1	CURRENT	NONE					NONE		NONE			0	0	0	N/A					
Apr 01 01:03 (EST)	TLR 0	CURRENT	RRENT NONE				NONE NONE				0	0	0	N/A							

TLR Schedule Totals

	Schedule							
Priority	Total Tags Cut / Hold	IDC Cut MVV	RC Cut Acknowledge MVV	Hold MVV				
0	0	0	0	0				
1	0	0	0	0				
2	0	0	0	0				
3	0	0	0	0				
4	0	0	0	0				
5	0	0	0	0				
6	0	0	0	0				
7	57	392	392	0				
Total	57	392	392	0				

TLR NNL Totals

	NNL Relief						
CA	IDC MVV	RC Ackn MVV					
CLEC	80.0	82.0					
EES	8.0	4.0					
Total	88.0	86.0					

TLR Market Flow Totals

		Market Relief			
Market	Туре	IDC MVV	RC Ackn MVV		
SWPP	ED-2	0.0	0.0		
	ED-6	0.0	0.0		
	FIRM-7	247.5	247.5		
Total for SWPP		247.5	247.5		
	Total	247.5	247.5		