

Attachment K

Rocky Mountain Power Five Year Study Findings & Kick Off Meeting

Thursday, March 23 2017



Study Areas for 2017


Findings Reports

North Salt Lake,	Utah	Sachith Abayakoon
Sigurd,	Utah	Carlton Jones
Southern Wyoming,	Wyoming	Scott Murdock

Kickoff Studies

Park City,	Utah	Scott Murdock
------------	------	---------------


North Salt Lake Study Findings



Area Planner: Jeremy Viula

Prepared by: Sachith Abayakoon

System Overview



- Covers North Salt Lake, Rose Park, Bountiful and Centerville
- Main sources into the area are 138 kV lines from Syracuse and Terminal substations
- 12 RMP owned substations
- Area transmission includes 138 and 46 kV lines
- Two municipal customers in the area.

Load Growth

- Base System Loads
 - Summer 2016: 398 MVA
 - Winter 2015-16: 290 MVA
- Growth
 - Average Summer: 1.1%
 - Average Winter: 1.9%
- Projected System Loads
 - Summer 2021: 428 MVA
 - Winter 2020-21: 372 MVA
- Distribution capacity: 342 MVA
- Area Utilization Factor: 73%


N-0 and N-1 Conditions

There were no prominent N-0 conditions

There were no prominent N-1 conditions

Any questions or comments?

Southern Wyoming Study Findings



Area Planner: Talmage Daley

Prepared by: Scott Murdock

System Overview



System Overview

- Covers Sweetwater, Carbon, and Albany county
- Main sources into the area include 230 kV lines from Atlantic City, Dave Johnston, Flaming Gorge, Monument, Snowy Range and Spence substations
- Area generation includes Jim Bridger, Foote Creek, Seven Mile Hill, Dunlap, High Plains, Mc Fadden Ridge and several customer operated cogeneration units
- 39 RMP owned substations
- Area transmission includes 230, 115 and 57 kV lines
- There are two rural electric systems in the area (Bridger Valley and Tristate G&T)

Load Growth

- Base System Loads
 - Summer 2016: 483 MVA
 - Winter 2015-16: 503 MVA
- Growth
 - Average Summer: 0.7%
 - Average Winter: 0.8%
- Projected System Loads
 - Summer 2021: 498 MVA
 - Winter 2020-21: 520 MVA
- Distribution capacity: 1222 MVA (1464 MVA Winter)
- Area Utilization Factor: 41%

N-0 and N-1 Conditions

There were no prominent N-0 conditions


There were no prominent N-1 conditions

Any questions or comments?


Sigurd Study Findings

Area Planner: Nathan Wilson

Prepared by: Carlton Jones



System Overview



- Covers Sanpete, Sevier, Piute, Beaver, and Garfield
- Main sources are 230-138 kV transformers at Sigurd and 138 kV tie to Parowan Valley
- Generation at Suphurdale and Blundell with several smaller units in the Milford area
- Contains 51 substations (15 are customer owned)
- Contains 138, 69, and 46 kV lines

Load Growth

- Base System Loads
 - Summer 2016: 121 MVA
 - Winter 2015-16: 86 MVA
- Growth:
 - Average Summer: 1.5%
 - Average Winter: 0.9%
- Projected System Loads
 - Summer 2021: 130 MVA
 - Winter 2020-21: 90 MVA
- Distribution capacity: 205 MVA
- Area Utilization Factor: 59%


N-0 Conditions – Improve Voltage

2017 Issue:

- Low voltage at Panguitch during summer peaks

Solution:

- Install 1.5 MW, 5 MWh battery and 650 kW of solar on 12.47 kV distribution system to improve and control voltage at peak.




N-0 Conditions – Improve Voltage

2017 Issue:

- Low voltage at Gunnison during summer peak.

Solution:

- Reconductor Salina-Gunnison line with 795 ACSR, install 2.7 Mvar of capacitors at Gunnison, and install 900 kvar of capacitors on the Gunnison distribution system to improve voltage at peak.




N-0 Conditions – Increase Capacity

2018 Issue:

- The Sevier 46 – 12.5 kV 1 MVA transformer is overloaded.

Solution:

- Install a 2.5 MVA transformer with matching regulators.




N-0 Conditions – Increase Capacity

2021 Issue:

- The Gunnison 10.5 MVA transformer is overloaded.

Solution:

- Install a 22.4 MVA transformer with an LTC.




N-0 Conditions – Increase Capacity

2021 Issue:

- The Elsinore 46 – 12.5 2.5 MVA transformer is overloaded.

Solution:

- Install a 5 MVA transformer. (Matches existing regulators)



N-1 Conditions – Reduce Exposure

2017 Issue:

- When Sigurd-Gunnison #2 line trips the entire Gunnison system is served by the #1 line. This leads to low voltages at Gunnison.

Solution:

- Complete the Gunnison N-0 voltage project and open switch 46A at Gunnison.

N-1 Conditions – Reduce Exposure

2017 Issue:


- The Milford and South Milford areas have large amounts of both load and generation. A loss of the Milford 138 kV system when generation output is low results in low voltages in the area.

Solution:

- Install relays at Milford and South Milford substations to shed load in a low voltage contingency event.

Any questions or comments?

Park City/Midway System Overview



- The study area covers portions of Summit, Wasatch and Morgan counties in central Utah.
- Weber Canyon in north.
- Parleys Canyon in center.
- Provo Canyon in south.
- Major communities are Park City and Midway.
- Municipals served are Heber City and Morgan City.

Park City/Midway Study Info

- Main transmission sources into the area include 138 kV lines from Cottonwood (Parleys Canyon), Hale (Provo Canyon) and Rainbow (Evanston, Wyoming).
- Local hydroelectric generation within the area includes Jordanelle, Deer Creek, Echo, Snake Creek and Wanship.
- The area has 25 RMP owned substations.
- Area transmission includes 138 kV and 46 kV.
- Winter peaking area.

Any questions or comments?