

Tri-State Generation and Transmission Association, Inc.
Open Access Transmission Tariff – GIP and GIA
Summary of substantive changes effective June 21, 2018

GIP

Section 9.6 updated per FERC Order 842 including Primary Frequency Response.
New Sections include 9.6.4, 9.6.4.1, 9.6.4.2 and 9.6.4.3

Revised Sheet No.'s 155 and 206 to include an Attachment D to Appendix 1

Appendix 1 to GIP, Interconnection Request For A Generating Facility added a new requirement for the Interconnection Customer to provide:

- j. Primary frequency response operating range for electric storage resources.

Attachment B to Appendix 1 Interconnection Request for Solar Revised

The current Attachment C to Appendix 1, Synchronous Generator Applications is being changed to Attachment D to Appendix 1

A new assignment for Attachment C to Appendix 1, Interconnection Request:
Generating Facility Data Electric Storage Resources has been developed

GIP Site Control Requirements has a new assignment as Attachment E to Appendix 1