

## Carman, Keith

---

**From:** Miller, Curtis  
**Sent:** Friday, November 14, 2008 1:54 PM  
**To:** Carman, Keith  
**Subject:** Statistics on 115 kV line at Springer

Mr. Carman

My name is Curtis Miller and I work in the Energy Resource Department. I am hoping you will be able to provide information or direction to find the information I need. There is a possibility a solar plant will be connected to the 115 kV radial line from Springer to Van Bremmer in NE New Mexico. I need statistic information that deals with the number of outages, average duration of the outages, and max outage times experienced on this line. If you have data for the past several years, I would appreciate it.

Please call me to discuss this further and clarify any issues.

Respectfully

Curtis Miller  
Power Resource Planner  
(303) 254-3230

11/18/2008

Interruption Number	Actual Out Date	Actual In Date	Stations Interrupted	Line or Equipment	Owner	Ownership	Members Affected	Members Notified	Cause	Weather	Additional Information
2006-0438	7/12/06 9:33	7/12/06 9:34	TS - YORK CANYON SP DELIVERY POINT	SPRINGER - YORK CANYON 115KV LINE	Tri-State	TS	SP	SP -	UNKNOWN	UNKNOWN	0937: SPRINGER 115 KV CB 462 CLOSED BY SCADA.
2006-0767	9/12/06 7:52	9/12/06 7:59	TS - YORK CANYON SP DELIVERY POINT	SPRINGER - YORK CANYON 115KV LINE	Tri-State	TS	SP	SP - DAVID SPRADLIN	TECHNICIAN ERROR	MILD	TECHS WORKING AT TAOS PULLING CABLES ACTIVATED CB 662 TRIP CIRCUIT.
2006-0809	10/6/06 14:47	10/6/06 14:47	TS - YORK CANYON SP DELIVERY POINT	SPRINGER - YORK CANYON 115KV LINE	Tri-State	TS	SP	SP - LEO LAUMBACH	UNKNOWN	THUNDERSTORMS	
2008-0303	6/29/08 0:14	6/29/08 0:25	TS - YORK CANYON SP DELIVERY POINT	SPRINGER - YORK CANYON 115KV LINE	Tri-State	TS	SP	SP - RON BRASHEAR	UNKNOWN	UNKNOWN	0020 : SP/BRASHEAR DISPATCH CREW TO INVESTIGATE MEMBER SYSTEM AT

TS TCODI GOAL 102.2  
This line 6.33