



Arrowhead-Stone Lake-Gardner Park 345 kV Line Concerns

September 2, 2005



Overview

- ATC can address reliability concerns raised
- The PST resolves the voltage stability concerns for 2K/2K/3K imports during n-1 conditions
- A Phase Shifting Transformer (PST) was included in the \$420M cost estimate approved at the PSCW re-hearing
- WIRES no longer exists
 - Disbanded prior to ATC formation



Concern: Use of PST

- Several Options to Improve Voltage Stability
 - Line Relocation/Re-termination: Could be expensive and would add delays and raise other issues, but could add extra capability to line.
 - Series Capacitors: Were found to increase voltage stability flow limit, but also increased flow due to lower line impedance, so post contingent flow remained near the nose of the PV curve. (BAH-2)
 - Phase Shifting Transformer: Minimized changes to line design and offers operational flexibility.




Concern: Stability Limit Exceeded During King-Eau Claire-Arpin Outage

- Under Severe Conditions Simulated Voltage Stability Limit NOT Exceeded with KEA Out (9/24/04 Voltage Stability Analysis Report)
 - An acceptable (10%) margin exists under intact system conditions and a 0° PST angle
 - KEA outage causes line flow to approach limit
 - PST Operation Returns Line Flow to an Acceptable margin following KEA outage
 - Line Flow is reduced less than 10% by PST



3000 MW ATC Import Arrowhead 345 kV PV Curves under Intact and King-Eau Claire-Arpin Outage Conditions





Concern: Line is Undersized

- The Conditions Across the MN-WI Interface Dictate that the Capability of Any New Line Would be Fully Utilized for 3K Import
- Surge Impedance Loading Well Below Thermal Limits
- Long Lines are often Stability (Dynamic or Voltage) Limited
- Can't Be Expected to Have the same Flow Limits as Shorter KEA line



Concern: Arrowhead 230 kV Termination

- The Proposed Line Design Accomplishes Objectives
 - Line Objective is a Specific Import Level
 - No Line Flow Objective Was Ever Specified
- No Justification for the Greater Expense of Connecting to the 500 kV System



Concern: WIRES Study Oversights

- WIRES Study Pre-dates ATC, so we can't Directly Address their Procedures and Processes
 - No NERC Planning Standards in Place when WIRES was Performed
 - WIRES Used a Different Voltage Stability Analysis Methodology (WIRES Study Chapter 5)
 - WIRES did not Consider a Tap at Stone Lake



Concern: Potential for Voltage Instability Not Addressed

- Project Participants believe the PST Addresses Voltage Stability Concerns
- Cost and Timeliness Concerns also Addressed



Concern: PST Not Addressed in 2003 Hearings

- PST Requirements Draft Report (11/5/01, BAH-2) presented at 2003 Hearings
 - Various Line Configurations and Voltage Stability Solutions Evaluated
 - Specific PST Design Concerns were Addressed based on Facts Known at the time
 - MVA Size, Angle range
 - Redundancy
 - Etc.



Concern: Increased Flow on Other Paths

- Decreasing Flows at Arrowhead under Contingency Conditions will increase Flows on Alternate Paths (Iowa and Illinois)
 - Studies have not revealed any problems under this condition
 - Our System is being designed for 3000 MW import, 2000 West & 1000 South or 1000 West & 2000 South
 - Partial Explanation: Forcing Flow South During High West Imports Utilizes Capability Designed into System for High South Flows



Concern: Weston Generator Shaft Stress During Line Reclosure

- Weston 3 Shaft Stress Issues are Eliminated by New Line
 - Delta P 37.2% limit identified by WIRES
 - “Worst Case”
 - 2005 Model, Without Arrowhead Line: 39%
 - 2005 Model, With Arrowhead Line: 32%
 - 2008 Model, Weston 4 on: 23%



Other Line Benefits

-
- Line Increases Geographic Diversity
 - Enhances Network Reliability
 - Increases Transfer Levels