

Simulation Study of the Northeast Wisconsin/Upper  
Peninsula Separation Event of November 14, 2001

A Report Prepared for  
Walter T. Woelfle  
American Transmission Company, LLC

Investigators: A. W. Schneider, Jr., PE, Consultant, I<sup>2</sup>R Technologies  
J. A. Pinnello, PE, Independent Consultant

Dated February 21, 2003

## Exhibits

Exhibit	Figure	Contents
A		One Line Diagrams of steady state power flows on ties into island
	A-1	Flows on ties into island prior to any switching operation
	A-2	Flows following switching White Clay – North Appleton line 6851
	A-3	Flows following closing of Indian Lake – Hiawatha 69 kV lines
B		Development of island (dynamic simulation)
	B-1	MVA flows on ties into island as the island formed
	B-2	Impedance plots for 69 kV lines looking west from Hiawatha
	B-2.1	Hiawatha – Engadine (line xxxx)
	B-2.2	Hiawatha – Gould City (line xxxx)
C		Simulation of the Actual Event
	C-1	Selected 138 and 69 kV bus voltages
	C-2	Generator speeds
	C-3	Generator mechanical power and load
	C-3A	Components of load and generation
	C-4	Motor speeds, bus frequency and voltage at Empire Mine
	C-4.1	-- bus 1
	C-4.2	-- bus 2
	C-4.3	-- bus 3
	C-4.4	-- bus 4
	C-5	Motor speeds, bus frequency and voltage at Tilden Mine
	C-5.1	-- bus 1
	C-5.2	-- bus 2
	C-6	Effect of motor tripping
D		Simulation of an Event with Enhanced UFLS
	D-1	Selected 138 and 69 kV bus voltages
	D-2	Generator speeds
	D-3	Generator mechanical power and load
	D-3A	Components of load and generation
	D-4	Motor speeds, bus frequency and voltage at Empire Mine
	D-4.1	-- bus 1
	D-4.2	-- bus 2
	D-4.3	-- bus 3
	D-4.4	-- bus 4
	D-5	Motor speeds, bus frequency and voltage at Tilden Mine
	D-5.1	-- bus 1
	D-5.2	-- bus 2
	D-6	Frequency comparison
	D-7	Load comparison

- E Excerpt from MAIN Guide 1B
- F Characteristics of Generating Units within Island Area
- G Characteristics of Existing Underfrequency Load Shedding in Island Area
- H PSS/E Command Files used to create the Base Case Power Flow
- I PSS/E Command Files used to set up and run the simulations  
(Note: these files invoke certain IDEV files distributed with the NERC System Dynamics Database, which are not included in this report but may be obtained by persons authorized to receive it.)

## Simulation Study of the Northeast Wisconsin/Upper Peninsula Separation Event of November 14, 2001

### Summary

American Transmission Company (ATC) commissioned a study to investigate a system separation event that occurred on November 14, 2001 and involved the power systems in Northeast Wisconsin and the Upper Peninsula of Michigan. During this event the affected area was isolated from the Eastern Interconnection, and sustained frequencies of 58 Hz were observed due to an imbalance of load and generation. ATC's assessment of the event indicated that the performance of the system was less than desirable even though the separated area did not experience a complete power shutdown. Some industrial loads, primarily motors, tripped during the event; it is not known definitively whether this was due to low frequency, low voltage, or both. The objectives of the study were to reproduce the event by computer simulation to better understand the factors that contributed to the performance, and then develop recommendations to improve the performance should a similar event occur in the future.

A computer simulation that reasonably duplicated the actual event has been completed. The results indicated that the amount of load shed automatically by underfrequency load shedding (UFLS) relays was inadequate and this was the major cause of the marginal system response. Voltage levels during and after the transient period did not contribute significantly to the system performance. The simulation study included the effect of the industrial load trips, and a comparison case included in the analysis demonstrated that without such motor tripping system response would have been worse. In effect, beneficial but unplanned and uncontrolled load shedding occurred due to the response of customer equipment.

A second simulation was also run, with the same system conditions but with the UFLS enhanced to trip up to 30% of the load in the area in three stages: at least 10% of load at 59.3 Hz, another 10% at 59.0 Hz, and a final 10% at 58.7 Hz. These are the levels of UFLS required for each control area under MAIN Guide 1B. The results showed that the system response was significantly improved even without the uncontrolled tripping of the motor load. It should be noted that this requirement currently applies to entire control areas, not to operating districts or other subsidiary areas within one or more control areas.

The principal recommendation reached during this study is that the UFLS protection system in the area affected by this disturbance should be upgraded to meet the level specified in MAIN Guide 1B for control areas.

## Overview of the Disturbance

The principal events leading up to the islanding incident were as follows.

- 0600: 138 kV Line 6851, North Appleton-White Clay, was taken out of service for scheduled work.
- 0604 Hiawatha- Indian Lake 69 kV lines 6912 and 6913 were closed, a routine operation dictated by the operation of the Ludington Pumped Storage Plant, completing a through path to the lower peninsula of Michigan via the Straits of Mackinac.
- 0636 138 kV line 64441, Pulliam-Stiles, tripped due to tree contact. At this time the West Marinette Units M31 and M32 were ordered to start.
- 0638 Line 64441 was successfully reclosed and the startup of the West Marinette units was canceled.
- 0645 Line 64441 tripped again. However, since the West Marinette units were still coasting down to standstill, they could not be restarted.
- 0645 138 kV line 64451, the second Pulliam-Stiles circuit, sagged into a distribution feeder and tripped. Almost simultaneously 6912 and 6913 opened automatically at Hiawatha, islanding the area north of, and including, 138 kV substations at Stiles and White Clay in Oconto County, Wisconsin, and west of a 69 kV substation at Hiawatha in Mackinac County, Michigan.

## System Model

The NERC MMWG base case power flow model representing 2002 light load conditions was used as a starting point. The NERC power flow model was modified in the area of interest to replicate actual conditions at the time of the event. Loads in the area that became islanded were iteratively incremented until flows into the islanded area reasonably matched EMS values. A transfer of 60 MW from WPS to UPP was added to further tune the power flow model. The industrial loads were converted to motor loads so that they could be represented as dynamic models.

The NERC System Dynamics Data Base (SDDDB) was the source for dynamic data for generating plants. It is notable that many of the small hydro plants in the area have no voltage regulator and exciter models, and some have no governors. Such modeling simplification would tend to bias the study results in a conservative or pessimistic direction. See Exhibit F for details.

Locations and settings of existing underfrequency relays were obtained from a 2001 MAIN UFLS study. This data was reviewed by ATC and updated. (See Exhibit G for details.) The UFLS relays in this area have a 15 cycle time delay rather than the 6 cycle delay specified in MAIN Guide 1B.

Relay data for Indian Lake- Hiawatha 69 kV lines 6912 and 6913, which tripped to form the island, was also provided by ATC. ATC provided dynamic data for the induction and synchronous motor loads at two large industrial sites in the island. During the dynamic time period all other loads were modeled as constant current for the MW component and constant reactance for the Mvar component.

The simulations were conducted using the PSS/E computer code marketed by Power Technologies, Inc., of Schenectady, NY.

### Sequence of Island Formation

The initial power flows on the ties into the island prior to any switching operations are shown on Exhibit A-1. The flows following switching the North Appleton-White Clay 138 kV Line out of service are shown on Exhibit A-2. Exhibit A-3 shows flows following switching which closed Hiawatha –Indian Lake 69 kV lines 6912 and 6913. This power flow was used as the steady state operating condition prior to island formation.

Exhibit B-1 shows the MVA flows on the ties into the island as the island formed illustrating the sequence of tripping. Pulliam-Stiles 138 kV Line 64441 was tripped at time equal to 0.5 seconds. (The 0.5 second delay was used to insure that the system remained in the steady state for a period time after the dynamic routine was called.) 138 kV Line 64451 was tripped 0.5 seconds later. Both of these line trips are known to be the result of heavy loading levels, during which the lines sagged into a tree and an underbuilt distribution line, respectively. The 0.5 second interval between the trips was intended to allow machine swings from the first switching event to damp out before a second perturbation was imposed; the actual time interval is believed to be at least several seconds and possibly a minute or two. The tripping of 69 kV Lines 6912 and 6913 occurred almost simultaneously by distance relay operation, which was modeled. Exhibits B-2.1 and B-2.2 show that the impedance trajectories entered the zone 1 relay settings at Hiawatha, resulting in instantaneous relay operation and line tripping after a 5 cycle breaker operating time.

### Analysis of the Simulated Actual Event

Exhibits C-1 through C-6 give the time domain plots of variables in the islanded area after island formation. These exhibits represent the simulation of the actual event and include the effects of the existing UFLS relays and the tripping of some of the industrial motor load. This motor tripping was implemented by underfrequency load shedding models available in the PSS/E program, with settings in the neighborhood of 58 Hz.

Exhibit C-1 shows selected 138 and 69 kV bus voltages. Following an initial transient voltage depression, voltages recover to somewhat higher levels than their initial values due to load shedding. Reactive power support is adequate to allow the island to recover to acceptable voltages. It is of interest to note that pronounced 69 kV voltage oscillations occur at the High Falls plant. Voltages on lightly loaded radial lines commonly jump up following underfrequency load shedding and this indicates that this happened. No voltage regulator models were included in the SDDB for the small hydro units in the southern

part of the island area, and if there is no provision for automatic regulation of generators, significant voltage swings on the 69 kV system are to be expected following a disturbance. Manually controlled excitation of these units is likely to result in unsatisfactory extreme voltages following disturbances, to which tap changers and switched capacitors will only slowly respond.

Exhibit C-2 shows generator speeds expressed as frequency at various plants. Frequency drops to about 58.2 Hz and recovers to about 59.2 Hz after 10 seconds. This result is more favorable than the reported frequency response of 58 Hz as a low with recovery to 59 Hz in one minute. The tripping of motor loads was included in the simulation. The cause of the motor trips, the amount tripped, and the time that they tripped is unknown.

In the simulation it was assumed that the motors tripped when frequency reached slightly above 58 Hz. Exhibit C-6 compares the frequency trajectory shown on Exhibit C-2 with that for an identical scenario without motor tripping. For this case frequency drops to nearly 58 Hz and recovers to about 58.25 Hz after 10 seconds. The actual frequency trajectory would then be somewhere between these two, and cannot be further determined because of uncertainty in the motor trips.

Exhibit C-3 shows generator mechanical power and load in the island. The increase in prime mover output is attributed to governor action. The load shown on Exhibit C-3 includes all substation loads and synchronous motor load, totaling 730 MW initially. The induction motor load is 115 MW giving a total island load of 845 MW. Due to a limitation in the PSS/E software it was not possible to add the induction motors to the other load in Exhibit C-3. Exhibit C-3A was developed to show the details of the various load components. From this data it is seen that about 63 MW, or 7.5% of the total island load was shed by underfrequency relays. The frequency was low enough that all three steps of UFLS should operate. The unintentional tripping of motor load assisted in recovery, but being uncontrolled, it can be concluded that the amount of load included in the automatic UFLS program in this area of the system is inadequate.

Exhibits C-4.1 through C-5.2 show motor speeds and 13.8 kV voltages at the Empire and Tilden mines, the largest industrial customers in the island area. These plots show that some motors did trip due to frequency. The 13.8 kV voltages did not drop below 85% indicating that motor tripping due to contactor dropout was unlikely.

#### Analysis of a Simulation with Enhanced UFLS

A second simulation was run with UFLS in accordance with MAIN Guide 1B, with 10% of the initial island load shed at each frequency set point of 59.3, 59.0, and 58.7 Hz. The relays were modeled with a 6 cycle time delay rather than a 15 cycle delay. The results of this simulation are shown in Exhibits D-1 to D-7. The tripping of motor loads was not included in this case.

Exhibit D-1 shows substantially the same voltage response as the first simulation. The frequency response shown on Exhibit D-2 shows a marked improvement, with frequency dropping to about 58.7 Hz and recovering to about 59.75 Hz in 10 seconds. This

frequency level is above the generally accepted minimum level for safe continuous operation of steam turbines, 59.5 Hz. (see IEEE Std. C37.106, *Guide for Abnormal Frequency Protection for Power Generating Plants*, currently under revision).

Exhibits D-3 and D-3A show island load and generation. It is likely that all of the UFLS relays set at 58.7 Hz did not operate. Analysis of the plots shows that about 195 MW or 23% of the total island load was shed by UFLS relay operation.

Exhibits D-4.1 to D-5.2 show motor speeds and the 13.8 kV voltages at the supply buses. As in the previous case, there is no indication of motors stalling or excessive low voltage to cause contactor dropout. However, it cannot be concluded that motor trips will not occur since the cause has not been established. It is reasonable to conclude that motor trips are less likely to occur since the shock to the system is reduced.

Exhibits D-6 and D-7 are presented to compare the frequency response and island load for the three conditions analyzed: the existing UFLS with and without motor tripping and the UFLS modified to apply MAIN Guide 1B to this zone without motor tripping.

### Conclusions and Recommendations

The study has demonstrated that the current UFLS in the area does not provide a satisfactory system response to separation disturbances. Frequency levels are low enough and of sufficient duration to cause possible damage to steam turbines. Relying on unpredictable and uncontrolled tripping of customer motor load does not constitute a robust protection plan to prevent power outages over a wide area of the system. An enhanced UFLS program has been shown to provide considerable improvement.

It is recommended that ATC and load serving entities and generating unit owners within its transmission service area consider the following.

- Upgrade the UFLS protection system in the area affected by this disturbance to:
  - Trip at least 10% of connected load at 59.3 Hz,
  - Another 10% at 59.0 Hz,
  - And a final 10% at 58.7 Hz.

To minimize costs while achieving maximum protection, existing UFLS electromechanical relays that cannot be set to trip within 6 cycles should be utilized in the third, 58.7 Hz, step of this UFLS program.



Note: MAIN Guide 1B does not require uniform distribution of UFLS across all load in a control area. This study found that relatively uniform distribution of UFLS in the amounts and at the settings specified in MAIN Guide 1B would have stabilized frequency within the island area at an acceptable level.




- Review UFLS practices to uncover deficiencies, particularly in areas more prone to separation disturbances.
- Submit voltage regulator models to the SDDB for hydro units if so equipped. These will increase the realism of studies in the area.
- Consider equipping hydro units with automatic voltage regulators if they are not so equipped.

Exhibit A



ONE LINE DIAGRAMS OF  
STEADY STATE POWER FLOWS INTO ISLAND



138 KV





69 KV




2001 SERIES, NERC/MMWG BASE CASE LIBRARY  
 INITIAL CASE - LOAD INCR 60 PCT, INTER OF 60 FROM WPS TO UPP  
 FIG. A-1 TSM. TIES INTO ISLAND FRI, NOV 08 2002 18:51

BUS - VOLTAGE (PU)  
 BRANCH - MW/MVAR  
 EQUIPMENT - MW/MVAR




138 KV




69 KV

ESC STM  
38721





PRESO IS  
39904




1.035





138 KV



69 KV






Exhibit B

DEVELOPMENT OF ISLAND


(Dynamic Simulation)



APPENDIX B. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
DEVELOPMENT OF THE ISLAND


FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_c.out

100.00	CHNL# 55: [6912_MVA-H]	+ - - - - +	0.0
100.00	CHNL# 53: [6913_MVA-I]	◇ - - - - ◇	0.0
400.00	CHNL# 50: [64441_MVA]	← - - - - ▷	0.0
400.00	CHNL# 49: [64451_MVA]	□ - - - - □	0.0




FRI, NOV 08 2002 19:14

B-1 MVA FLOWS INTO ISLAND




APPENDIX B. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
DEVELOPMENT OF THE ISLAND

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_c.out  
RELAY: DISTR  
TSTART: 0.9833 TSTOP: 2.0 TIC INCREMENT: 0.0167  
CHNL# 48: [HIA-ENG\_X]



B-2.1 HIA-ENG DIST. RELAY






APPENDIX B. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
DEVELOPMENT OF THE ISLAND

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_c.out

RELAY: DISTR

TSTART: 0.9833 TSTOP: 2.0 TIC INCREMENT: 0.0167

CHNL# 46: [HIA-GLD\_X]



FRI, NOV 08 2002 19:14

B-2.2 HIA-GLD DIST. RELAY

Exhibit C

SIMULATION OF THE ACTUAL EVENT





EXHIBIT C. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
ACTUAL UNDERFREQUENCY LOAD SHEDDING AND MOTOR TRIPPING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_c.out

1.2000	CHNL# 110: [VOLT 38608 [HIGH FLS69.000]]	→	0.80000
1.2000	CHNL# 8: [VOLT 39017 [CRYSTAL 69.000]]	×	0.80000
1.2000	CHNL# 7: [VOLT 39569 [PLAINS 138.00]]	+-----+	0.80000
1.2000	CHNL# 6: [VOLT 38897 [STILLESS 138.00]]	◇-----◇	0.80000
1.2000	CHNL# 5: [VOLT 38787 [VICTORIA69.000]]	←-----△	0.80000
1.2000	CHNL# 2: [VOLT 39904 [PRESQ IS138.00]]	□-----□	0.80000







EXHIBIT C. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
ACTUAL UNDERFREQUENCY LOAD SHEDDING AND MOTOR TRIPPING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_c.out

60.250	CHNL# 20: 60*(1+[SPD 38721 [ESC STM 12.500] [1 ]])	→	57.750
60.250	CHNL# 18: 60*(1+[SPD 39594 [PUL G8 16.000] [8 ]])	×	57.750
60.250	CHNL# 17: 60*(1+[SPD 39102 [BRUL HG 6.6000] [1 ]])	+	57.750
60.250	CHNL# 16: 60*(1+[SPD 38807 [VIC 1 1111.500] [1 ]])	◇	57.750
60.250	CHNL# 15: 60*(1+[SPD 39895 [MOT STM 69.000] [3 ]])	←	57.750
60.250	CHNL# 14: 60*(1+[SPD 38774 [PSQI G9 13.800] [9 ]])	□	57.750







EXHIBIT C. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
ACTUAL UNDERFREQUENCY LOAD SHEDDING AND MOTOR TRIPPING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_c.out







EXHIBIT C. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
ACTUAL UNDERFREQUENCY LOAD SHEDDING AND MOTOR TRIPPING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_c.out



THU, NOV 21 2002 19:15





EXHIBIT C. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
ACTUAL UNDERFREQUENCY LOAD SHEDDING AND MOTOR TRIPPING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_c.out

1.2000	CHNL# 62: [VOLT 38908 [EMPIRE 113.800]]	→	0.80000
60.500	CHNL# 71: 60*(1+[SPD 38908 [EMPIRE 113.800]] [P ])	×	55.500
60.500	CHNL# 70: 60*(1+[SPD 38908 [EMPIRE 113.800]] [M ])	+	55.500
60.500	CHNL# 69: 60*(1+[SPD 38908 [EMPIRE 113.800]] [2 ])	◇	55.500
60.500	CHNL# 68: 60*(1+[SPD 38908 [EMPIRE 113.800]] [1 ])	←	55.500
60.500	CHNL# 1: 60*(1+[FREQ 39904 [PRESQ IS138.00]])	□	55.500







EXHIBIT C. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
ACTUAL UNDERFREQUENCY LOAD SHEDDING AND MOTOR TRIPPING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_c.out

1.2000	CHNL# 63: [VOLT 38909 [EMPIRE 213.800]]	→	0.80000
60.500	CHNL# 76: 60*(1+[SPD 38909 [EMPIRE 213.800]] [M ])	x	55.500
60.500	CHNL# 75: 60*(1+[SPD 38909 [EMPIRE 213.800]] [M ])	+ - - - - - +	55.500
60.500	CHNL# 73: 60*(1+[SPD 38909 [EMPIRE 213.800]] [2 ])	◇	55.500
60.500	CHNL# 72: 60*(1+[SPD 38909 [EMPIRE 213.800]] [1 ])	← - - - - - △	55.500
60.500	CHNL# 1: 60*(1+[FREQ 39904 [PRESQ IS138.00]])	□	55.500









EXHIBIT C. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
ACTUAL UNDERFREQUENCY LOAD SHEDDING AND MOTOR TRIPPING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_c.out

1.2000	CHNL# 63: [VOLT 38909 [EMPIRE 213.800]]	→	0.80000
60.500	CHNL# 81: 60*(1+[SPD 38910 [EMPIRE 313.800]] [P ])	×	55.500
60.500	CHNL# 80: 60*(1+[SPD 38910 [EMPIRE 313.800]] [M ])	+	55.500
60.500	CHNL# 79: 60*(1+[SPD 38910 [EMPIRE 313.800]] [2 ])	◇	55.500
60.500	CHNL# 78: 60*(1+[SPD 38910 [EMPIRE 313.800]] [1 ])	←	55.500
60.500	CHNL# 1: 60*(1+[FREQ 39904 [PRESQ IS138.00]])	□	55.500







EXHIBIT C. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
ACTUAL UNDERFREQUENCY LOAD SHEDDING AND MOTOR TRIPPING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_c.out

1.2000	CHNL# 63: [VOLT 38909 [EMPIRE 213.800]]	→	0.80000
60.500	CHNL# 85: 60*(1+[SPD 38911 [EMPIRE 413.800]] [P ])	×	55.500
60.500	CHNL# 84: 60*(1+[SPD 38911 [EMPIRE 413.800]] [M ])	+	55.500
60.500	CHNL# 83: 60*(1+[SPD 38911 [EMPIRE 413.800]] [2 ])	◇	55.500
60.500	CHNL# 82: 60*(1+[SPD 38911 [EMPIRE 413.800]] [1 ])	←	55.500
60.500	CHNL# 1: 60*(1+[FREQ 39904 [PRESQ IS138.00]])	□	55.500







EXHIBIT C. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
ACTUAL UNDERFREQUENCY LOAD SHEDDING AND MOTOR TRIPPING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_c.out

1.2000	CHNL# 63: [VOLT 38909 [EMPIRE 213.800]]	→	0.80000
60.500	CHNL# 89: 60*(1+[SPD 38920 [TILDEN 113.800]] [M ])	×	55.500
60.500	CHNL# 88: 60*(1+[SPD 38920 [TILDEN 113.800]] [3 ])	+	55.500
60.500	CHNL# 87: 60*(1+[SPD 38920 [TILDEN 113.800]] [2 ])	◇	55.500
60.500	CHNL# 86: 60*(1+[SPD 38920 [TILDEN 113.800]] [1 ])	←	55.500
60.500	CHNL# 1: 60*(1+[FREQ 39904 [PRESQ IS138.00]])	□	55.500








EXHIBIT C. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
ACTUAL UNDERFREQUENCY LOAD SHEDDING AND MOTOR TRIPPING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_c.out

1.2000	CHNL# 63: [VOLT 38909 [EMPIRE 213.800]]	→	0.80000
60.500	CHNL# 95: 60*(1+[SPD 38921 [TILDEN 213.800]] [M ])	x	55.500
60.500	CHNL# 94: 60*(1+[SPD 38921 [TILDEN 213.800]] [3 ])	+	55.500
60.500	CHNL# 93: 60*(1+[SPD 38921 [TILDEN 213.800]] [2 ])	◇	55.500
60.500	CHNL# 92: 60*(1+[SPD 38921 [TILDEN 213.800]] [1 ])	←	55.500
60.500	CHNL# 1: 60*(1+[FREQ 39904 [PRESQ IS138.00]])	□	55.500





2001 SERIES, NERC/MMWG BASE CASE LIBRARY  
INDIAN LAKE - HIAWATHA CLOSED

THU, NOV 21 2002 19:15

C-6 EFFECT OF MOTOR TRIP





Exhibit D


SIMULATION OF AN EVENT WITH ENHANCED UFLS




APPENDIX D. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
UNIFORM 30% UNDERFREQUENCY LOAD SHEDDING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_b.out

1.3000	CHNL# 110: [VOLT 38608 [HIGH FLS69.000]]	→	0.80000
1.2000	CHNL# 8: [VOLT 39017 [CRYSTAL 69.000]]	×	0.80000
1.2000	CHNL# 7: [VOLT 39569 [PLAINS 138.00]]	+	0.80000
1.2000	CHNL# 6: [VOLT 38897 [STILLESS 138.00]]	◇	0.80000
1.2000	CHNL# 5: [VOLT 38787 [VICTORIA69.000]]	←	0.80000
1.2000	CHNL# 2: [VOLT 39904 [PRESQ IS138.00]]	□	0.80000







APPENDIX D. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
UNIFORM 30% UNDERFREQUENCY LOAD SHEDDING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_b.out

60.250	CHNL# 20: 60*(1+[SPD 38721 [ESC STM 12.500] [1 ]])	→	57.750
60.250	CHNL# 18: 60*(1+[SPD 39594 [PUL G8 16.000] [8 ]])	×	57.750
60.250	CHNL# 17: 60*(1+[SPD 39102 [BRUL HG 6.60000] [1 ]])	+-----+	57.750
60.250	CHNL# 16: 60*(1+[SPD 38807 [VIC 1 1111.500] [1 ]])	◇-----◇	57.750
60.250	CHNL# 15: 60*(1+[SPD 39895 [MGT STM 69.000] [3 ]])	←-----→	57.750
60.250	CHNL# 14: 60*(1+[SPD 38774 [PSQI G9 13.800] [9 ]])	□-----□	57.750









APPENDIX D. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
UNIFORM 30% UNDERFREQUENCY LOAD SHEDDING


FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_b.out






APPENDIX D. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
UNIFORM 30% UNDERFREQUENCY LOAD SHEDDING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_b.out




FRI, NOV 08 2002 19:23


APPENDIX D. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
 UNIFORM 30% UNDERFREQUENCY LOAD SHEDDING



FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_b.out

1.2000	CHNL# 62: [VOLT 38908 [EMPIRE 113.800]]	→	0.80000
60.500	CHNL# 71: 60*(1+[SPD 38908 [EMPIRE 113.800]] [P ])	×	55.500
60.500	CHNL# 70: 60*(1+[SPD 38908 [EMPIRE 113.800]] [M ])	+	55.500
60.500	CHNL# 69: 60*(1+[SPD 38908 [EMPIRE 113.800]] [2 ])	◇	55.500
60.500	CHNL# 68: 60*(1+[SPD 38908 [EMPIRE 113.800]] [1 ])	←	55.500
60.500	CHNL# 1: 60*(1+[FREQ 39904 [PRESQ IS138.00]])	□	55.500







APPENDIX D. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
UNIFORM 30% UNDERFREQUENCY LOAD SHEDDING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_b.out

1.2000	CHNL# 63: [VOLT 38909 [EMPIRE 213.800]]	→	0.80000
60.500	CHNL# 76: 60*(1+[SPD 38909 [EMPIRE 213.800]] [M ])	×	55.500
60.500	CHNL# 75: 60*(1+[SPD 38909 [EMPIRE 213.800]] [M ])	+ - - - - -	55.500
60.500	CHNL# 73: 60*(1+[SPD 38909 [EMPIRE 213.800]] [2 ])	◇ - - - - -	55.500
60.500	CHNL# 72: 60*(1+[SPD 38909 [EMPIRE 213.800]] [1 ])	← - - - -	55.500
60.500	CHNL# 1: 60*(1+[FREQ 39904 [PRESQ IS138.00]])	□ - - - -	55.500







APPENDIX D. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
UNIFORM 30% UNDERFREQUENCY LOAD SHEDDING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_b.out

1.2000	CHNL# 81: 60*(1+[SPD 38910 [EMPIRE 313.800]] [P ])	→	0.80000
60.500	CHNL# 63: [VOLT 38909 [EMPIRE 213.800]]	×	55.500
60.500	CHNL# 80: 60*(1+[SPD 38910 [EMPIRE 313.800]] [M ])	+ - - - - -	55.500
60.500	CHNL# 79: 60*(1+[SPD 38910 [EMPIRE 313.800]] [2 ])	◇ - - - - -	55.500
60.500	CHNL# 78: 60*(1+[SPD 38910 [EMPIRE 313.800]] [1 ])	← - - - -	55.500
60.500	CHNL# 1: 60*(1+[FREQ 39904 [PRESQ IS138.00]])	□ - - - -	55.500







APPENDIX D. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
UNIFORM 30% UNDERFREQUENCY LOAD SHEDDING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_b.out

1.2000	CHNL# 63: [VOLT 38909 [EMPIRE 213.800]]	→	0.80000
60.500	CHNL# 85: 60*(1+[SPD 38911 [EMPIRE 413.800]] [P ])	×	55.500
60.500	CHNL# 84: 60*(1+[SPD 38911 [EMPIRE 413.800]] [M ])	+ - - - - - +	55.500
60.500	CHNL# 83: 60*(1+[SPD 38911 [EMPIRE 413.800]] [2 ])	◇ - - - - - ◇	55.500
60.500	CHNL# 82: 60*(1+[SPD 38911 [EMPIRE 413.800]] [1 ])	← - - - - - →	55.500
60.500	CHNL# 1: 60*(1+[FREQ 39904 [PRESQ IS138.00]])	□ - - - - - □	55.500







APPENDIX D. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
UNIFORM 30% UNDERFREQUENCY LOAD SHEDDING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_b.out

1.2000	CHNL# 89: 60*(1+[SPD 38920 [TILDEN 113.800] [M ]])	→	0.80000
60.500	CHNL# 63: [VOLT 38909 [EMPIRE 213.800]]	x	55.500
60.500	CHNL# 88: 60*(1+[SPD 38920 [TILDEN 113.800] [3 ]])	+ - - - - - +	55.500
60.500	CHNL# 87: 60*(1+[SPD 38920 [TILDEN 113.800] [2 ]])	◇ - - - - - ◇	55.500
60.500	CHNL# 86: 60*(1+[SPD 38920 [TILDEN 113.800] [1 ]])	← - - - - - →	55.500
60.500	CHNL# 1: 60*(1+[FREQ 39904 [PRESQ IS138.00]])	□ - - - - - □	55.500







APPENDIX D. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
UNIFORM 30% UNDERFREQUENCY LOAD SHEDDING

FILE: c:\WUMS Island Study\Simulation Runs\TRIPBOTH\_b.out

1.2000	CHNL# 63: [VOLT 38909 [EMPIRE 213.800]]	→	0.80000
60.500	CHNL# 95: 60*(1+[SPD 38921 [TILDEN 213.800]] [M ])	x	55.500
60.500	CHNL# 94: 60*(1+[SPD 38921 [TILDEN 213.800]] [3 ])	+	55.500
60.500	CHNL# 93: 60*(1+[SPD 38921 [TILDEN 213.800]] [2 ])	◇	55.500
60.500	CHNL# 92: 60*(1+[SPD 38921 [TILDEN 213.800]] [1 ])	←	55.500
60.500	CHNL# 1: 60*(1+[FREQ 39904 [PRESQ IS138.00]])	□	55.500









2001 SERIES, NERC/MMWG BASE CASE LIBRARY  
INDIAN LAKE - HIAWATHA CLOSED

60.500	FILE:TRIPBOTH_c.out	CHNL# 14: 60*(1+[SPD 38774 [PSQI G9 13.800] [9 ]])	58.000
60.500	FILE:TRIPBOTH_b.out	CHNL# 14: 60*(1+[SPD 38774 [PSQI G9 13.800] [9 ]])	58.000
60.500	FILE:TRIPBOTH_a.out	CHNL# 14: 60*(1+[SPD 38774 [PSQI G9 13.800] [9 ]])	58.000




FRI, NOV 08 2002 19:23

D-6 FREQUENCY COMPARISON



2001 SERIES, NERC/MMWG BASE CASE LIBRARY  
INDIAN LAKE - HIAWATHA CLOSED

900.00	CHNL#'S 103,106,108:	[PLOAD	ZONE 369	[	]]-[PELEC	ZONE 379	[WE-PI	]]+[
900.00	FILE:TRIPBOTH_c.out							400.00
900.00	CHNL#'S 103,106,108:	[PLOAD	ZONE 369	[	]]-[PELEC	ZONE 379	[WE-PI	]]+[
900.00	FILE:TRIPBOTH_b.out							400.00
900.00	CHNL#'S 103,106,108:	[PLOAD	ZONE 369	[	]]-[PELEC	ZONE 379	[WE-PI	]]+[
900.00	FILE:TRIPBOTH_a.out							400.00



## Exhibit E

### EXCERPT FROM MAIN GUIDE 1B: PROCEDURES DURING GENERATING CAPACITY DEFICIENCIES CAUSING DECLINING SYSTEM FREQUENCY OR SEPARATION

Note: the complete and current text of MAIN Guide 1B is available on the MAIN Web site, [www.maininc.org](http://www.maininc.org) to authorized users.

#### I. SYSTEM EMERGENCY CONDITION

##### C. Frequency Declining: 59.3 to 58.7 Hz

All MAIN load serving entities shall utilize automatic load shedding devices to arrest declining frequency. The frequency settings shall be as follows:

Step 1                      At **59.3** Hz, shed not less than 10% of system load.

Step 2                      At **59.0** Hz, shed additional load so that the total amount shed from Steps 1 and 2 is not less than 20% of system load prior to Step 1.

Step 3                      At **58.7** Hz, shed additional load so that the total amount shed from Steps 1, 2 and 3 is not less than 30% of system load prior to Step 1.

To enhance the effectiveness of automatic load shedding, all MAIN load serving entities shall comply with the following:

1. Use solid state underfrequency relays for all new installations and relay replacements. These relays should be applied on the first step of load shedding, where practical, to take advantage of their improved stability over electromechanical relays and their constant response time which is not significantly affected by voltage magnitude or frequency decay rate.
2. Set time delays for each of the three automatic load-shedding steps at 6 cycles. For large motor loads that may be isolated, the time delay may be increased to 15 cycles. If this is not adequate to avoid operation on isolation, a high-dropout overcurrent relay should be applied to supervise underfrequency relay tripping having a 6 cycle time delay.
3. Trip bulk power capacitor banks along with loads, unless specific studies show this to be a problem or of negligible benefit.

4. Set the voltage setting on automatic load shedding relays which are equipped with undervoltage inhibit as low as possible within the security constraints of the relay.

Exhibit F

CHARACTERISTICS OF GENERATING UNITS WITHIN ISLAND AREA

BUS#	NAME	KV	ID	Status	PGEN	QGEN	PMAX	MBASERSORCE	XSORCE	Generator	Exciter	Stabilizer	Governor
38556	WHR HG	2.4	1	On	2.3	-1.2	8.0	10.0	0.0030	0.2200	Salient		Hydro
38608	HIGH FLS	69	1	On	1.7	3.0	7.0	8.8	0.0000	0.2800	Classical		
								Trans:	0.0064	0.7802			
38611	CAF G	2.4	1	On	1.3	4.0	6.4	8.0	0.0000	0.3900	Classical		
38617	JOF G	2.4	1	On	1.3	1.5	3.5	4.4	0.0000	0.3400	Classical		
38618	SANDSTON	69	1	On	1.2	2.5	3.8	4.8	0.0000	0.3800	Classical		
								Trans:	0.0058	0.0542			
38628	GR RAPID	69	1	On	3.5	2.0	6.5	7.8	0.0000	0.2500	Salient		Hydro
								Trans:	0.0085	0.0696			
38721	ESC STM	12.5	1	On	6.4	2.3	7.2	13.5	0.0020	0.1904	Round	IEEET1	Steam
38721	ESC STM	12.5	2	On	6.4	2.3	7.2	13.5	0.0020	0.1904	Round	IEEET2	Steam
38724	GLADSTN	12.5	1	Off	0.0	1.3	27.0	24.1	0.0020	0.1140	Round	IEEET1	Gas Turbine
38763	PORT 12.	12.5	1	Off	0.0	0.0	23.8	24.1	0.0020	0.1140	Round	IEEET1	Gas Turbine
38766	PSQI G1	13.8	1	Off	0.0	3.2	25.0	29.4	0.0020	0.2090	Round	IEEET4	Steam
38767	PSQI G2	13.8	2	On	23.0	14.7	37.0	44.1	0.0020	0.1940	Round	IEEET1	Steam
38768	PSQI G3	13.8	3	On	54.0	14.7	58.0	68.0	0.0020	0.2120	Round	IEEET3	Steam
38769	PSQI G4	13.8	4	On	54.0	14.7	58.0	68.0	0.0020	0.2120	Round	IEEET4	Steam
38770	PSQI G5	13.8	5	On	78.0	14.7	88.0	100.0	0.0030	0.1700	Round	EXST2A PTIST1	Steam
38771	PSQI G6	13.8	6	On	80.0	14.7	90.0	100.0	0.0030	0.1700	Round	EXST2A PTIST1	Steam
38772	PSQI G7	13.8	7	On	78.0	14.7	85.0	100.0	0.0030	0.1700	Round	EXST2A PTIST1	Steam
38773	PSQI G8	13.8	8	On	77.0	14.7	88.0	100.0	0.0030	0.1700	Round	EXST2A PTIST1	Steam
38774	PSQI G9	13.8	9	On	81.0	14.7	88.0	100.0	0.0030	0.1700	Round	IEEET3	Steam
38790	WARDEN 1	13.8	1	Off	0.0	0.0	17.7	22.1	0.0020	0.1490	Classical		
38798	WPINE M	13.8	1	On	6.0	0.0	14.8	17.5	0.0020	0.1470	Round	IEEET1	Gas Turbine
38798	WPINE M	13.8	2	Off	0.0	0.0	14.8	17.5	0.0020	0.1470	Round	IEEET1	Gas Turbine

BUS#NAME	KV	ID	Status	PGEN	QGEN	PMAX	MBASE	RSORCE	XSORCE	Generator	Exciter	Stabilizer	Governor
38798 WPINE M	13.8	3	Off	0.0	0.0	14.8	17.5	0.0020	0.1470	Round	IEEET1		Gas Turbine
38807 VIC 1 11	11.5	1	On	5.0	0.7	6.0	7.5	0.0030	0.3800	Classical			
38808 VIC A 11	11.5	1	On	5.0	0.0	6.0	7.5	0.0030	0.3800	Classical			
39022 WAY HG1	4.16	1	Off	0.0	0.0	1.8	2.2	0.0030	0.2200	Classical			
39024 HEM HG1	4.16	1	Off	0.0	-0.5	2.8	3.1	0.0000	0.3500	Salient			Hydro
39071 NEQ HG1	6.9	1	On	7.9	3.4	8.0	8.9	0.0030	0.3250	Salient			Hydro
39072 NEQ HG2	6.9	2	On	7.9	3.4	8.0	8.9	0.0030	0.3250	Salient			Hydro
39099 PVY HG1	6.9	1	Off	0.0	4.0	6.0	7.5	0.0030	0.3400	Salient			Hydro
39101 PVY HG2	6.9	2	Off	0.0	4.0	6.0	7.5	0.0030	0.3400	Salient			Hydro
39102 BRUL HG	6.6	1	On	1.1	2.3	5.3	6.7	0.0030	0.2840	Salient			Hydro
39105 MCH HG1	4.16	1	Off	0.0	1.9	4.8	5.3	0.0030	0.4000	Salient			Hydro
39106 MCH HG2	4.16	2	Off	0.0	1.9	4.8	5.3	0.0030	0.4000	Salient			Hydro
39107 TWF HG	6.6	1	On	2.1	2.9	6.1	6.4	0.0030	0.1460	Salient			Hydro
39108 PIN HG	2.3	1	On	1.1	2.3	3.6	4.0	0.0030	0.2500	Salient			Hydro
39109 KIN HG	13.8	1	On	2.1	1.5	7.2	9.0	0.0030	0.2830	Salient			Hydro
39111 OLQ HG1	2.3	1	Off	0.0	0.0	1.8	2.2	0.0030	0.1700	Salient			Hydro
39112 OLQ HG2	2.3	2	Off	0.0	0.0	1.8	2.2	0.0030	0.1700	Salient			Hydro
39124 CKH HG	2.4	1	On	2.0	1.5	7.8	9.8	0.0030	0.4300	Salient			Hydro
39655 WEM G31	13.8	1	Off	0.0	8.2	41.0	47.0	0.0000	0.1150	Round	IEEET2		Gas Turbine
39660 WEM G32	13.8	2	Off	0.0	1.1	39.0	47.0	0.0000	0.1150	Round	IEEET2		Gas Turbine
39661 WEM G33	13.8	3	Off	0.0	0.0	75.0	112.9	0.0000	0.2000	Round	IEEET1		Gas Turbine
39824 WEM 34	13.8	1	Off	0.0	0.0	79.5	112.9	0.0000	0.2000	Round	IEEET1		Gas Turbine
39895 MQT STM	69	1	On	2.7	0.0	6.0	14.7	0.0020	0.1036	Round	IEEET1		Steam
							Trans:	0.0110	0.1100				
39895 MQT STM	69	2	On	4.2	0.0	9.4	22.9	0.0020	0.1434	Round	IEEET1		Steam
							Trans:	0.0110	0.1100				
39895 MQT STM	69	3	On	9.6	0.0	21.2	52.0	0.0020	0.2110	Round	IEEET1		Steam
							Trans:	0.0110	0.1100				
39895 MQT STM	69	4	On	4.5	0.0	9.9	24.1	0.0020	0.1140	Round	IEEET1		Gas Turbine
							Trans:	0.0110	0.1100				

Exhibit G

CHARACTERISTICS OF EXISTING UNDERFREQUENCY LOAD SHEDDING

IN ISLAND AREA

Owner	Name	KV	Fraction Shed
WPS	WELLS ST	69	100%
WPS	30TH AVE	69	50%
UPP	DELTA 69	69	100%
UPP	ELEV 69	69	100%
UPP	HENRY 69	69	100%
UPP	SAWYER 6	69	100%
UPP	ELEV TP2	69	100%
WE	WCL	34.5	40%
WPS	W.MARNET	138	100%





Exhibit H  
PSS/E COMMAND FILES USED TO CREATE THE BASE CASE POWER FLOW

INITIAL.IDV

MENU,OFF /\* FORCE MENU TO CORRECT STATUS  
TEXT PARAMETER 1 = %1% IS PERCENTAGE INCREASE IN LOAD FOR ISLAND AREA  
TEXT PARAMETER 2 = %2% IS MW INTERCHANGE FROM AREA 366 TO AREA 368 TO SUPPLY LOAD  
TEXT ORIGINAL LOAD IS 94 MW  
ODEV  
2  
INITIAL.LOG  
PDEV  
2  
INITIAL.LOG  
TEXT PARAMETER 1 = %1% IS PERCENTAGE INCREASE IN LOAD FOR ISLAND AREA  
TEXT PARAMETER 2 = %2% IS MW INTERCHANGE FROM AREA 366 TO AREA 368 TO SUPPLY LOAD  
CASE  
C:\WUMS Island Study\Power Flow Cases\INITIAL\_1.SAV  
OPTN  
16 / TURN ON PHASE SHIFT ADJUSTMENT  
1  
21 / NEWTON TOLERANCE  
0.250000  
0  
rdch  
1  
0 / bus data  
0 / load data  
0 / gen data  
39799,39772,1,.01438,.04379,.00084,76,76,76,,,,,0 / man-glen jk (open)  
0 / line data  
Q  
@INPUT,"C:\WUMS Island Study\Power Flow Cases\initial\_lines.idv"  
TEXT Change Presque Isle and Pulliam controlled voltages and MW to 6:30 values  
TEXT Change PSQI to control 138 kV bus  
TEXT Change area 366 and 368 control buses to Weston 3 and Escanaba  
chng  
2 / gen  
38766 / PSQI 1  
1  
1.0348,39904  
1  
1  
0 / off  
-1 / next  
38767 / PSQI 2  
1  
1.0348,39904  
1  
2  
1  
1 23 / on, new MW  
-1 / next  
38768 / PSQI 3  
1  
1.0348,39904  
3  
1

1,54  
-1 / next  
38769 / PSQI 4  
1  
1.0348,39904  
4  
1  
1 54  
-1 / next  
38770 / PSQI 5  
1  
1.0348,39904  
5  
1  
1,78  
-1 / next  
38771 / PSQI 6  
1  
1.0348,39904  
6  
1  
1,80  
-1 / next  
38772 / PSQI 7  
1  
1.0348,39904  
7  
1  
1,78  
-1 / next  
38773 / PSQI 8  
1  
1.0348,39904  
8  
1  
1,77  
-1 / next  
38774 / PSQI 9  
1  
1.0348,39904  
9  
1  
1,81  
-1 / next  
39590 / Pulliam G7  
1  
1.0188  
7  
1  
0 / off  
-1  
39591 / Pulliam 5  
1  
1.0188  
5  
1

, 44, 9  
-1  
39592 / Pulliam G4  
1  
1.0188  
4  
1  
,21.3,6.5  
-1  
39593 / Pulliam G3  
1  
1.0188  
3  
1  
,18.9,4.3  
-1  
39594 / Pulliam G8  
1  
1.0109  
8  
1  
1,125.5,31.2  
-1  
39595 / Pulliam G6  
1  
1.0109  
6  
1  
1,61.3,9.0  
-1  
0 / NEW CHANGE CODE  
9 / SWITCHED SHUNT  
39589 / PULLIAM 138  
1  
,1.025,1.01,25.2 / NEW VALUES  
  
0 / NEW CHANGE CODE  
5 / AREA INTERCHANGE  
366 / WPS  
1 / CHANGE  
39678 / WESTON 3  
368 / UPP  
1 / CHANGE  
38721 / ESC STM  
-1 / EXIT  
TEXT FOLLOWING MODELED AS 1 UNIT IN POWER FLOW EXCEPT AS NOTED  
RDCH  
1  
0 / bus data  
0 / load data  
38556,1,2.3,,,,,,,,,1 /WHR HG 2.40  
38608,1,1.7,,,,,,,,,1 /HIGH FLS69.0  
38611,1,1.3,,,,,,,,,1 /CAF G 2.40  
38617,1,1.3,,,,,,,,,1 /JOF G 2.40  
38618,1,1.2,,,,,,,,,1 /SANDSTON69.0  
38628,1,3.5,,,,,,,,,1 /GR RAPID69.0

```

38721,1,7.0,,,,,,,,,1 /ESC STM
38721,2,7.0,,,,,,,,,1 /ESC STM
38763,1,10,,,,,,,,,0 /PORT 12.12.5
38790,1,3.7,,,,,,,,,0 /WARDEN 12.5
39022,1,0.0,,,,,,,,,0 /WAY HG1 4.16
39024,1,0.0,,,,,,,,,0 /HEM HG1 4.16
39071,1,7.9,,,,,,,,,1 /NEQ HG1 6.90
39072,2,7.9,,,,,,,,,1 /NEQ HG2 6.90
39099,1,0.0,,,,,,,,,0 /PVY HG1 6.90 -- EMS VALUES NEGATIVE
39101,2,0.0,,,,,,,,,0 /PVY HG2 6.90
39102,1,1.1,,,,,,,,,1 /BRUL HG 6.60
39105,1,0.0,,,,,,,,,0 /MCH HG1 4.16
39106,2,0.0,,,,,,,,,0 /MCH HG2 4.16
39107,1,2.1,,,,,,,,,1 /TWF HG1 6.60
39108,1,1.1,,,,,,,,,1 /PIN HG 2.30
39109,1,2.1,,,,,,,,,1 /KIN HG 13.8
39111,1,0.0,,,,,,,,,0 /OLQ HG1 2.30
39112,2,0.0,,,,,,,,,0 /OLQ HG2 2.30
39124,1,2.0,,,,,,,,,1 /CKH HG 2.40
39678,3,319,,,,,,,,,1 /WESTON 3
39679,1,41.5,,,,,,,,,1 /WESTON 1
39680,2,80.5,,,,,,,,,1 /WESTON 2
39737,1,2.3,,,,,,,,,1 /ESHYDR-14.20
39738,1,2.3,,,,,,,,,1 /ESHYDR-24.20
39739,1,2.2,,,,,,,,,1 /ESHYDR-34.20
39740,1,2.1,,,,,,,,,1 /ESHYDR-44.20
39745,1,16.3,,,,,,,,,1 /US HYDRO13.8
0 / generator data
Q
TEXT TAP CODE CHANGED TO DIRECT
FDNS,OPT
1,2,1,0,0,0
0
@INPUT,"C:\WUMS Island Study\Power Flow Cases\changeemptld.idv"
TEXT REGULATE EMPIRE AND TILDEN 138 kV BUS AT 6:30 AM VALUES
CHNG
2
38908
1
0.9986,39886,,11.5
-1
38909
1
0.9986,39886,,8.0
-1
38910
1
.9986,39886,,29.4
-1
38911
1
.9986,39886,,51.0
-1
38920
1
1.0022,39915,,50.0

```

```

-1
38921
1
1.0022,39915,,50.0
-1
-1 / EXIT
TEXT SCALE EMPIRE AND TILDEN MOTOR LOADS TO 6:30 VALUES
scal
38908
1 / SPECIFY NEW TOTAL POWERS
,,,,-23.3
1 / ENFORCE POWER LIMITS
0 / NO CHANGE IN LOAD MVAR
38909
1
,,,,-47.1
1
0
38910
1
,,,,-21.9
1
0
38911
1
,,,,-56
1
0
38920
1
,,,,-62.8
1
0
38921
1
,,,,-71.6
1
0

CHNG
8
0
1
BASE LOAD and INTERCHANGE, 6:00 Configuration
0
FDNS,OPT
1,2,1,0,0,0
0
SAVE
INITIAL_BASE
text @INPUT,"C:\WUMS Island Study\Power Flow Cases\draw_case.idv"
rdch
island_loads_in_zone369.rdc
TEXT FOLLOWING REMOVED BY CHANGEMPTLD.IDV FILE
TEXT 38718,1,,365,369
TEXT 38785,1,,365,369

```

```

TEXT 38912,1,,365,369
TEXT 38922,1,,365,369
rdch
island_buses_in_zone369.rdc
TEXT FOLLOWING REMOVED BY CHANGEMPTLD.IDV FILE
TEXT 38718,,13.8,,,,365,369
TEXT 38785,,13.8,,,,365,369
TEXT 38912,,13.8,,,,365,369
TEXT 38922,,13.8,,,,365,369
TEXT
TEXT FOLLOWING REMOVED TO ALLOW A CHSB MODEL TO SUM AREA 379
TEXT 38908,,13.8,,,,365,369
TEXT 38909,,13.8,,,,365,369
TEXT 38910,,13.8,,,,365,369
TEXT 38911,,13.8,,,,365,369
TEXT
@INPUT,"C:\WUMS Island Study\Power Flow Cases\scale_zone.idv" %1%
TEXT @INPUT,"C:\WUMS Island Study\Power Flow Cases\scale_wps.idv" %1%
TEXT SCALE PAPER MILLS (NIAGARA OF WIS, CHAMPION) TO MEASURED VALUES -- ADDED
    9/29/02
scal
38554
1
26.2
1
1
38546
1
62
1
1

FDNS,OPT
1,2,1,0,0,0
0
@INPUT,"C:\WUMS Island Study\Power Flow Cases\CHNG_366_TO_368.idv" %2%
CHNG
8
0
1
INITIAL CASE - LOAD INCR %1% PCT, INTER OF %2% FROM WPS TO UPP
0
FDNS,OPT
1,2,1,0,0,0
0
SAVE
INITIAL_%1%
@INPUT,"C:\WUMS Island Study\Power Flow Cases\draw_case.idv"
@INPUT,"C:\WUMS Island Study\Power Flow Cases\LIST_FLOWS.idv" %1%_pct
LIST,AR
2 / FILE
WUMS_GENS
365 366 368
4 / PLANT DATA
5 / UNITS

```

```

11 / AREA INTERCHANGE
0
chng
3 / branch
39576 39545 1 / 6851 -- White Clay - Lawn Road
1 / change first line
0 / status off
-1
0
0
CHNG
8
0
1
Line 6851 (White Clay-Lawn Road) Out
0
FDNS,OPT
1,2,1,0,0,0
0
@INPUT,"C:\WUMS Island Study\Power Flow Cases\draw_case.idv"
save
trip_6851
chng
3 / branch
39764 39769 1 / 6913 -- Hiawatha - Gould City
1
1
-1
39772 39794 1 / 6912 -- Manistique - Valley
1
1
-1
39772 39799 1 / 6913 -- Manistique - Glen Jenks
1
0
-1
0
8
0
1
Indian Lake - Hiawatha Closed
0
FDNS,OPT
1,2,1,0,0,0
0
save
close69
@INPUT,"C:\WUMS Island Study\Power Flow Cases\draw_case.idv"
@INPUT,"C:\WUMS Island Study\Power Flow Cases\convertlf_wums.idv" close69
ODEV
1
PDEV
1
TEXT SOLUTION COMPLETED

```

@end



INITIAL\_LINES.IDV

```
MENU,OFF /* FORCE MENU TO CORRECT STATUS
chg
3
38895 39545 1 / 6851 N App - Lawn Rd
1
1
-1
39589 38897 2 / 64451 Pulliam - Stiles 5
1
1
-1
39589 39575 1 / 64441 Pulliam - Stiles 4
1
1
-1
39764 39769 1 / 6913 HIA - GLD
1
0
-1
39772 39799 1 / 6913 MTQ - GLJ (N.O.)
1
1
-1
39802 39799 1 / 6916 ILK - GLJ
1
1
-1
39764 39763 1 / 6912 HIA - ENG
1
1
-1
39772 39794 1 / 6912 MTQ - VLE
1
0
-1
-1
fnsl
0
save inital_config
IDEV,"C:\WUMS Island Study\Power Flow Cases\list_flows.IDV" Initial

@end
```

CHANGEEMPTLD.IDV

EXTR,SI

YES

0

0

38718 38785 38908 38909 38910 38911 38912 38920 38921 38922

0

RDCH

1

38908,'EMPIRE 1',13.8,2,,5.0,365,379 /EMP GEN BUS

38909,'EMPIRE 2',13.8,2,,15.0,365,379 /EMP GEN BUS

38910,'EMPIRE 3',13.8,2,,,365,379 /EMP GEN BUS

38911,'EMPIRE 4',13.8,2,,,365,379 /EMP GEN BUS

38920,'TILDEN 1',13.8,2,,,365,379 /TLD GEN BUS

38921,'TILDEN 2',13.8,2,,,365,379 /TLD GEN BUS

0 / BUS DATA

0 / LOAD DATA (NONE)

38908,'1',-15.100, 2.268, 4.8, -4.8,0.98,0,17.6,0.00,0.16,0.0,0.08000,1.0,1,100.0,0.0,-17.000,1,1.0

38908,'2',-2.600, 0.390, 1.0, -0.9,0.98,0, 3.0,0.00,0.16,0.0,0.04000,1.0,1,100.0,0.0, -2.800,1,1.0

38908,'M',-9.200, -6.800, -6.8, -6.8,0.98,0,13.1,0.02,0.16,0.0,0.04000,1.0,1,100.0,0.0,-10.900,1,1.0

38908,'P',-1.100, -0.700, -0.7, -0.7,0.98,0, 1.5,0.02,0.16,0.0,0.02000,1.0,1,100.0,0.0, -1.200,1,1.0

38909,'1',-10.400, 3.464, 8.7, -4.4,0.98,0,14.6,0.00,0.17,0.0,0.07000,1.0,1,100.0,0.0,-11.700,1,1.0

38909,'2',-12.600, 4.196, 11.4, -5.7,0.98,0,18.9,0.00,0.16,0.0,0.08400,1.0,1,100.0,0.0,-15.100,1,1.0

38909,'3',-3.100, 1.032, 1.4, -1.1,0.98,0, 3.6,0.00,0.15,0.0,0.04800,1.0,1,100.0,0.0, -3.300,1,1.0

38909,'M',-6.200, -4.100, -4.1, -4.1,0.98,0, 7.9,0.02,0.16,0.0,0.03700,1.0,1,100.0,0.0, -6.600,1,1.0

38909,'N',-7.600, -5.800, -5.8, -5.8,0.98,0,11.1,0.02,0.16,0.0,0.04000,1.0,1,100.0,0.0, -9.200,1,1.0

38909,'P',-1.100, -0.700, -0.7, -0.7,0.98,0, 1.5,0.02,0.16,0.0,0.02000,1.0,1,100.0,0.0, -1.200,1,1.0

38910,'1',-19.800, 5.203, 10.2, -7.4,0.98,0,24.6,0.00,0.12,0.0,0.06500,1.0,1,100.0,0.0,-22.300,1,1.0

38910,'2',-2.400, 0.631, 2.0, -1.0,0.98,0, 3.4,0.00,0.17,0.0,0.04500,1.0,1,100.0,0.0, -2.700,1,1.0

38910,'M',-6.700, -4.900, -4.9, -4.9,0.98,0, 9.4,0.02,0.16,0.0,0.02200,1.0,1,100.0,0.0, -7.800,1,1.0

38910,'P',-1.100, -0.700, -0.7, -0.7,0.98,0, 1.4,0.02,0.16,0.0,0.01900,1.0,1,100.0,0.0, -1.200,1,1.0

38911,'1',-10.000, 7.306, 8.8, -4.4,0.98,0,14.7,0.00,0.13,0.0,0.02000,1.0,1,100.0,0.0,-11.800,1,1.0

38911,'2',-4.600, 3.361, 3.8, -1.9,0.98,0, 6.3,0.00,0.21,0.0,0.02500,1.0,1,100.0,0.0, -5.100,1,1.0

38911,'M',-34.000,-24.100,-24.1,-24.1,0.98,0,46.2,0.02,0.16,0.0,0.04100,1.0,1,100.0,0.0,-38.400,1,1.0

38911,'P',-2.400, -1.700, -1.7, -1.7,0.98,0, 3.3,0.02,0.16,0.0,0.01300,1.0,1,100.0,0.0, -2.700,1,1.0

38920,'1',-22.600, 7.680, 16.0, -9.0,0.98,0,30.6,0.00,0.14,0.0,0.03400,1.0,1,100.0,0.0,-26.100,1,1.0

38920,'2',-22.500, 7.646, 16.0, -9.0,0.98,0,30.8,0.00,0.14,0.0,0.03400,1.0,1,100.0,0.0,-26.300,1,1.0

38920,'3',-8.200, 2.786, 7.8, -4.0,0.98,0,12.9,0.00,0.21,0.0,0.02100,1.0,1,100.0,0.0,-10.300,1,1.0

38920,'M',-13.300,-10.700,-10.7,-10.7,0.98,0,19.2,0.02,0.16,0.0,0.04700,1.0,1,100.0,0.0,-15.900,1,1.0

38920,'N',-5.700, -4.900, -4.9, -4.9,0.98,0, 8.8,0.02,0.16,0.0,0.04800,1.0,1,100.0,0.0, -7.300,1,1.0

38920,'P',-5.200, -4.500, -4.5, -4.5,0.98,0, 8.1,0.02,0.16,0.0,0.02700,1.0,1,100.0,0.0, -6.700,1,1.0

38921,'1',-22.500, 6.539, 17.5,-10.0,0.98,0,33.1,0.00,0.14,0.0,0.03680,1.0,1,100.0,0.0,-28.100,1,1.0

38921,'2',-22.200, 6.452, 17.4,-10.0,0.98,0,32.9,0.00,0.14,0.0,0.03680,1.0,1,100.0,0.0,-27.900,1,1.0

38921,'3',-7.600, 2.209, 7.8, -4.0,0.98,0,12.9,0.00,0.21,0.0,0.02150,1.0,1,100.0,0.0,-10.300,1,1.0

38921,'M',-11.100, -9.400, -9.4, -9.4,0.98,0,16.8,0.02,0.16,0.0,0.04600,1.0,1,100.0,0.0,-13.900,1,1.0

38921,'N',-4.500, -4.200, -4.2, -4.2,0.98,0, 7.5,0.02,0.16,0.0,0.04100,1.0,1,100.0,0.0, -6.200,1,1.0

38921,'P',-4.600, -4.300, -4.3, -4.3,0.98,0, 7.8,0.02,0.16,0.0,0.02600,1.0,1,100.0,0.0, -6.500,1,1.0

0 / GENERATOR (MOTOR) DATA

39886,38908,'1',0.01400,0.29430,0.0,50.00,50.0,50.0,1.0,0.0,0.0,0.0,0.0,0.0,1.0,0,1,1.0

38903,38909,'1',0.01400,0.29430,0.0,50.00,50.0,50.0,1.0,0.0,0.0,0.0,0.0,0.0,1.0,0,1,1.0

38904,38909,'1',0.01400,0.29430,0.0,50.00,50.0,50.0,1.0,0.0,0.0,0.0,0.0,0.0,1.0,0,1,1.0

38905,38910,'1',0.01400,0.29430,0.0,50.00,50.0,50.0,1.0,0.0,0.0,0.0,0.0,0.0,1.0,0,1,1.0

38906,38911,'1',0.01400,0.29430,0.0,50.00,50.0,50.0,1.0,0.0,0.0,0.0,0.0,0.0,1.0,0,1,1.0

38907,38911,'1',0.01400,0.29430,0.0,50.00,50.0,50.0,1.0,0.0,0.0,0.0,0.0,0.0,1.0,0,1,1.0

39915,38920,'1',0.01280,0.16000,0.0,50.00,50.0,50.0,1.0,0.0,0.0,0.0,0.0,0.0,1.0,0,1,1.0

38917,38920,'1 ',0.01280,0.16000,0.0,50.00,50.0,50.0,1.0,0.0,0.0,0.0,0.0,0.0,1,0.0,1,1.0  
38918,38921,'1 ',0.01280,0.16000,0.0,50.00,50.0,50.0,1.0,0.0,0.0,0.0,0.0,0.0,1,0.0,1,1.0  
38919,38921,'1 ',0.01280,0.16000,0.0,50.00,50.0,50.0,1.0,0.0,0.0,0.0,0.0,0.0,1,0.0,1,1.0

0 / BRANCH DATA

0  
0  
0  
0  
0  
0  
0  
0  
0  
0  
0

RDCH

1  
0  
0  
0  
0  
0  
0

218,-1223 /CONS nc FROM -1223

363,,572 /NI nc FROM +572

364,,671 /ALTE nc FROM +671

365,-623 /WEC nc FROM -623

366,-194 /WPS nc FROM -194

367,-278 /MGE nc FROM -278

368,-75 /UPPC nc FROM - 75

0  
0  
0  
0  
0  
0  
0  
0  
0  
0

@END

SCALE\_ZONE.IDV

MENU,OFF /\* FORCE MENU TO CORRECT STATUS

TEXT Was zones 368 378 379

scal,zone

369

2

%1%

1 / constant p/q

@END

SCALE\_WPS.COM

MENU,OFF /\* FORCE MENU TO CORRECT STATUS

scal

38604 -38630 39633 39647 39648 39658

2 / percent change

%1%

1 / constant P/Q

39895

2

,%1%

1

0

@end

CHNE\_366\_TO\_368.IDV

MENU,OFF /\* FORCE MENU TO CORRECT STATUS

RDCH

1

0 / BUS

0 / LOAD

0 / GENERATOR

0 / BRANCH

0 / TR ADJ

0 / AREA INT

0 / 2 TERM DC

0 / SW SHUNT

0 / TR Z CORR

0 / MULT TERM DC

0 / MULTISECTION LINE GROUP

0 / ZONE

366 368 1 0.1

0 / INTERAREA TRANSFER

Q

chnng

13 / inter area transfer

1 / change affected net interchange values

366 368 1

1

%1%

0

0

-1

@END

FIX\_CONFLICTS.IDV

MENU,OFF /\* FORCE MENU TO CORRECT STATUS

cntb

0

1

16371

1.0174

68630 68330 -68333

1.07

70836 70837

1.017

@END

DRAWCASE.IDV

MENU,OFF /\* FORCE MENU TO CORRECT STATUS

TEXT OUTPUT DEVICE CHANGED FROM 29 (PRINTER) TO 41 (POSTSCRIPT) WITH 1 COPY 9/29/02

DRAW

C:\WUMS Island Study\Power Flow Cases\ilk-hia.drw

1

0

0,SIGN

2

2

0

0

3

0

0

0

138 and 69 kV Ties Into Island

29

4

41

1,Acrobat PDFWriter

0 / No more

@END

ZERO\_LOADS\_OFF.IDV

MENU,OFF /\* FORCE MENU TO CORRECT STATUS

chg

1/ bus data

38555

1

1

0

-1

38741

1

1

0

-1

38753

1

1

0

-1

38792

1

1

0

-1

38848

1

1

0

-1

39025

1

1

0

-1

-1

@END

LIST\_FLOWS.IDV

MENU,OFF /\* FORCE MENU TO CORRECT STATUS

pout

2

%1% flows

39589 39575 38897 39576 39545

39590 -39595

39588 38605

39802 39772 39799 39764

39904 38765 -38768 38721

38769 -38774 38808

38903 -38911 39886

38917 -38921 39915

39678 -39680

28273 39753

exam

2

%1% config

39589 39575

38897 39576 39545

39590 39591

39592 39593

39594 39595

39588 38605

39802 39772

39799 39764

39904 38808

38765 -38768 38721

38769

38903 -38911 39886

38917 -38921 39915

28273 39753

@END

CONVERTLF\_WUMS.IDV

```
MENU,OFF /* FORCE MENU TO CORRECT STATUS
TEXT Parameter 1 =%1% is percent increase in island load
case %1%.sav
@input PLI2002LLXsorce.rdc
@input PliNpcc74942.rsp
@input mainMerge2Gens.idv
@input solveLf.idv
conl,all
100 0
0 100
1
@input 02LL_gnet.rsp
rawd,all
2
%1%.raw
1,1
cong
ordr
fact,dp
tysl
save %1%_conv
@end
```



ILK\_HIA.DRW

HD, , 10.000 8.00 0.050 0.000 R  
 CO, , 0 0 0 0 1 2 3 4  
 VO, , 69.0 115.00 230.00  
  
 BU, , 38895 2.000 6.750 2.000 5.750 0 -4 /\* NAP 138  
 BU, , 39545 2.500 6.750 2.500 5.750 0 -4 /\* WCL 138  
 BU, , 39576 3.000 6.750 3.000 5.750 0 -4 /\* WCL 138  
 LI,F , 38895 39545 1 2.000 6.250 2.500 6.250 R 0.125 L 0.125  
 LI,T , 39545 39576 1 2.500 6.250 3.000 6.250 R 0.125 L 0.125  
  
 BU, , 39589 2.000 4.750 2.000 2.500 0 -4 /\* PUL 138  
 BU, , 39575 3.000 4.750 3.000 3.750 0 4 /\* STL 4 138  
 BU,N , 38897 3.000 3.500 3.000 2.500 4 0 /\* STL 5 138  
  
 BU, , 39801 4.875 7.000 7.875 7.000 0 -4 /\* ILK 138  
 BU, , 39802 4.875 6.000 7.875 6.000 0 -4 /\* ILK 69  
  
 BU, , 39799 4.875 5.250 6.000 5.250 0 -2 /\* GLJ  
 BU, , 39772 6.750 5.250 7.875 5.250 -5 -2 /\* MTQ  
 BU,N , 39794 6.750 4.500 7.875 4.500 -5 -2 /\* VLE  
 BU,N , 39795 4.875 4.500 6.000 4.500 0 -2  
 BU,N , 39770 6.750 3.750 7.875 3.750 -5 -2 /\* BPK  
 BU,N , 39771 4.875 3.750 6.000 3.750 0 -2  
 BU,N , 39766 6.750 3.000 7.875 3.000 -5 -2 /\* CUR  
 BU,N , 39767 4.875 3.000 6.000 3.000 0 -2  
 BU,N , 39768 6.750 2.250 7.875 2.250 -5 -2 /\* GLD  
 BU,N , 39769 4.875 2.250 6.000 2.250 0 -2  
 BU,N , 39763 7.250 1.625 7.500 1.625 -9 -2 /\* ENG (FUT)  
 BU, , 39764 4.875 1.250 7.875 1.250 0 -4 /\* HIA  
  
 BU, , 38721 8.875 7.000 8.875 6.000 -4 -4 /\* ESC STM 12.5  
  
 GE, 1, 38721 8.875 6.750 9.250 6.750 /\* ESC STM  
 GE, 2, 38721 8.875 6.250 9.250 6.250 /\* ESC STM  
  
 BU, , 39904 8.875 5.500 8.875 1.000 -4 -4 /\* PRESQUE IS  
  
 GE, 1, 38766 8.875 5.250 9.250 5.250 /\* PRESQUE IS  
 GE, 2, 38767 8.875 4.750 9.250 4.750 /\* PRESQUE IS  
 GE, 3, 38768 8.875 4.250 9.250 4.250 /\* PRESQUE IS  
 GE, 4, 38769 8.875 3.750 9.250 3.750 /\* PRESQUE IS  
 GE, 5, 38770 8.875 3.250 9.250 3.250 /\* PRESQUE IS  
 GE, 6, 38771 8.875 2.750 9.250 2.750 /\* PRESQUE IS  
 GE, 7, 38772 8.875 2.250 9.250 2.250 /\* PRESQUE IS  
 GE, 8, 38773 8.875 1.750 9.250 1.750 /\* PRESQUE IS  
 GE, 9, 38774 8.875 1.250 9.250 1.250 /\* PRESQUE IS  
  
 BU, S, 38766 8.875 5.250 8.875 5.250 /\* PRESQUE IS  
 BU, S, 38767 8.875 4.750 8.875 4.750 /\* PRESQUE IS  
 BU, S, 38768 8.875 4.250 8.875 4.250 /\* PRESQUE IS  
 BU, S, 38769 8.875 3.750 8.875 3.750 /\* PRESQUE IS  
 BU, S, 38770 8.875 3.250 8.875 3.250 /\* PRESQUE IS  
 BU, S, 38771 8.875 2.750 8.875 2.750 /\* PRESQUE IS

BU, S, 38772 8.875 2.250 8.875 2.250 /\* PRESQUE IS  
 BU, S, 38773 8.875 1.750 8.875 1.750 /\* PRESQUE IS  
 BU, S, 38774 8.875 1.250 8.875 1.250 /\* PRESQUE IS  
  
 TX, 1, 6.350 1.000 0.100 0.0 '69 kV'  
  
 LI,F, 39589 39575 1 2.000 4.250 3.000 4.250 R 0.125 L 0.125  
 LI,F, 39589 38897 2 2.000 3.000 3.000 3.000 R 0.125 L 0.125  
 /\* LI,SP, 39575 38897 1 3.000 3.750 3.000 3.500 D 0.125 U 0.125  
 SY, , 133, 3.000 3.625 0.250 0.000  
  
 TX, 1, 2.125 1.125 0.100 0.0 '138 kV'  
  
 TR,F, 39801 39802 1 5.375 7.000 5.375 6.000 D 0.125 U 0.250  
 TR,F, 39801 39802 2 7.375 7.000 7.375 6.000 D 0.125 U 0.250  
  
 LI,T, 39802 39799 1 5.375 6.000 5.375 5.250 D 0.125 U 0.125  
 LI,T, 39802 39772 1 7.375 6.000 7.375 5.250 D 0.125 U 0.125  
  
 LI,T, 39799 39772 1 6.000 5.250 6.750 5.250 D 0.125 D 0.125  
  
 LI,T, 39799 39795 1 5.375 5.250 5.375 4.500 D 0.125 U 0.125  
 LI,T, 39772 39794 1 7.375 5.250 7.375 4.500 D 0.125 U 0.125  
  
 LI,T, 39795 39771 1 5.375 4.500 5.375 3.750 D 0.125 U 0.125  
 LI,T, 39794 39770 1 7.375 4.500 7.375 3.750 D 0.125 U 0.125  
  
 LI,T, 39771 39767 1 5.375 3.750 5.375 3.000 D 0.125 U 0.125  
 LI,T, 39770 39766 1 7.375 3.750 7.375 3.000 D 0.125 U 0.125  
  
 LI,T, 39767 39769 1 5.375 3.000 5.375 2.250 D 0.125 U 0.125  
 LI,T, 39766 39768 1 7.375 3.000 7.375 2.250 D 0.125 U 0.125  
  
 LI,T, 39769 39764 1 5.375 2.250 5.375 1.250 D 0.125 U 0.125  
 LI,SP, 39768 39763 1 7.375 2.250 7.375 1.625 D 0.125 U 0.125  
  
 LI,T, 39763 39764 1 7.375 1.625 7.375 1.250 D 0.125 U 0.125  
  
 LO, , 39799 5.875 5.250 5.875 5.000 0 -2 /\* GLJ  
 LO, , 39772 7.000 5.250 7.000 5.000 0 -2 /\* MTQ  
  
 LO, , 39794 7.000 4.500 7.000 4.250 0 -2 /\* VLE  
 LO, , 39795 5.875 4.500 5.875 4.250 0 -2  
  
 LO, , 39771 5.875 3.750 5.875 3.500 0 -2 /\* BPK  
  
 LO, , 39766 7.000 3.000 7.000 2.750 0 -2 /\* CUR  
 LO, , 39767 5.875 3.000 5.875 2.750 0 -2  
  
 LO, , 39769 5.875 2.250 5.875 2.000 0 -2 /\* GLD  
  
 SH, , 39799 5.000 5.250 5.000 5.000 0 -2 /\* GLJ  
 SH, , 39772 7.750 5.250 7.750 5.000 0 -2 /\* MTQ  
 SH, , 39794 7.750 4.500 7.750 4.250 0 -2 /\* VLE  
 SH, , 39795 5.000 4.500 5.000 4.250 0 -2  
 SH, , 39770 7.750 3.750 7.750 3.500 0 -2 /\* BPK

SH, , 39771 5.000 3.750 5.000 3.500 0 -2  
SH, , 39766 7.750 3.000 7.750 2.750 0 -2 /\* CUR  
SH, , 39767 5.000 3.000 5.000 2.750 0 -2  
SH, , 39768 7.750 2.250 7.750 2.000 0 -2 /\* GLD  
SH, , 39769 5.000 2.250 5.000 2.000 0 -2  
TX, 1, 5.200 5.875 0.080 0.0 '6916'  
TX, 1, 7.200 5.875 0.080 0.0 '6910'  
TX, 1, 5.200 5.125 0.080 0.0 '6913'  
TX, 1, 7.200 5.125 0.080 0.0 '6912'  
EN

Exhibit I  
PSS/E COMMAND FILES USED TO SET UP AND RUN THE SIMULATIONS

CRTSNAP\_WUMS.IDV

```
.MENU,OFF      /* FORCE MENU TO CORRECT STATUS
ODEV
2
CRTSNAP.LOG
PDEV
2
CRTSNAP.LOG
lofl
read
C:\WUMS Island Study\Power Flow Cases\close69.raw
fdns,opt
1,2,1,0,0,0
0
cong
ordr
fact,dp
tysl
save close69_conv.sav

rtrn
dyre
wums.dyr
conec.flx
conet.flx
wums_relays
101,101,101,101
MyCompile.bat
snap INITIAL.snp

STOP
```

STRTDS\_MOD.IDV

```
odev
2
strtds_mod.log
pdev
2
strtds_mod.log
rstr initial.snp
lofl
case C:\WUMS Island Study\Power Flow Cases\close69_conv.sav
fact,dp
tysl
rtrn
@INPUT CHANNEL_SEL
@input dynadcfx25.idv
@input tstep.rsp
@input audrain.idv
@input removeModels2002LL.rsp
@input chngPrm2002LL.rsp
@input PLIConfirm2002LL.rsp
@input PLIModelsOff2002LL.rsp
@input PliChngPrm2002LL.rsp
TEXT @input AddSysChan.rsp
@input Big_Bend.idv
text @input zone_total.idv

TEXT OPEN GRAPHICS WINDOW
OPTN
10
26

dyre,add
ufls.dyr

text dyre,add
text minetrip.dyr

strt
nodist_wums
wums_started

run
0.5,100,1,5
stop
```

CHANNEL\_SEL.IDV

MENU,OFF  
TEXT 12 =FREQUENCY (CHANNEL 1 -- PRESQUE ISLE)  
TEXT 13 = VOLTAGE (CHANNELS 2-9)  
TEXT 1 = ANGLE (CHANNELS 10-13)  
TEXT 7 = SPEED (CHANNELS 14-20)  
TEXT 16 = FLOW (CHANNELS 21-36)(2 PER LINE)  
TEXT 18 = APPARENT IMPEDANCE (CHANNELS 37-48)(2 PER LINE)  
TEXT 17 = MVA (CHANNELS 49-56)  
chan

12  
39904

13  
39904  
38903  
38919  
38787  
38897  
39569  
39017  
38630

1  
38774,9  
39895,3  
38807,1  
39678,3

7  
38774,9  
39895,3  
38807,1  
39102,1  
39594,8  
39678,3  
38721,1

16  
39589 38897 2 '64451\_W'  
'64451\_R'  
39589 39575 1 '64441\_W'  
'64441\_R'  
39802 39772 1 '6910\_W'  
'6910\_R'  
39802 39799 1 '6916\_W'  
'6916\_R'  
39764 39769 1 'HIA-GLD\_W'  
'HIA-GLD\_R'  
39764 39763 1 'HIA-ENGD\_W'  
'HIA-ENGD\_R'  
28273 39753 1 'Straits\_W'  
'Straits\_R'  
38765 39895 1 'MQT-W'  
'MQT\_R'

18

39589 38897 2 '64451'  
'64451\_X'  
39589 39575 1 '64441'  
'64451\_X'  
39802 39772 1 '6910'  
'6910\_X'  
39802 39799 1 '6916'  
'6916\_X'  
39764 39769 1 'HIA-GLD'  
'HIA-GLD\_X'  
39764 39763 1 'HIA-ENG'  
'HIA-ENG\_X'

17

39589 38897 2 '64451\_MVA'  
39589 39575 1 '64441\_MVA'  
39802 39772 1 '6910\_MVA'  
39772 39794 1 '6912\_MVA-M'  
39802 39799 1 '6913\_MVA-I'  
39764 39720 1 '6913\_MVA\_H'  
39764 39763 1 '6912\_MVA-H'

0

@input AddSysChan.rsp  
TEXT EMPIRE AND TILDEN VALUES  
TEXT 13 = VOLTAGE  
TEXT 7 = SPEED  
chan

13

38908  
38909  
38910  
38911  
38920  
38921

7

38908,1  
38908,2  
38908,M  
38908,P  
38909,1  
38909,2  
38909,3  
38909,M  
38909,N  
38909,P  
38910,1  
38910,2  
38910,M  
38910,P  
38911,1  
38911,2  
38911,M



38911,P  
38920,1  
38920,2  
38920,3  
38920,M  
38920,N  
38920,P  
38921,1  
38921,2  
38921,3  
38921,M  
38921,N  
38921,P

18  
38995 38997 1 '3810'  
'3810\_X'

0  
@input zone\_total.idv  
chan

13  
38608  
38628

0  
TEXT SELECT CHANNELS TO MONITOR IN GRAPHICS WINDOW  
TEXT 1 -- #1 -- FREQUENCY -- PRESQUE ISLE  
TEXT 2 -- #2 -- VOLTAGE -- PRESQUE ISLE (WAS #49 -- MVA -- LINE 64451)  
TEXT 3 -- #111 -- VOLTAGE -- GR RAPID69  
TEXT 4 -- #53 -- MVA -- LINE 6913 @ INDIAN LK  
TEXT 5 -- #103-- MW -- ISLAND LOAD (ZONE 369)  
TEXT 6 -- #55 -- MVA -- LINE 6912 @ HIAWATHA

ALTR  
4  
1  
Y  
1  
Y  
Y  
-.045,0.005  
2  
Y  
2  
Y  
Y  
0.875,1.125  
3  
Y  
111  
Y  
Y  
0.85,1.20  
4  
Y  
53

Y  
Y  
0,50  
5  
Y  
103  
Y  
Y  
0,600  
6  
Y  
55  
Y  
Y  
0,50  
-1  
0  
  
@end

TRIPBOTH2.IDV

```
MENU,OFF          /* FORCE MENU TO CORRECT STATUS
ODEV
2
tripBOTH.LOG
PDEV
2
tripBOTH.LOG
rstr wums_started.snp
lofl
CASE
C:\WUMS Island Study\Power Flow Cases\close69_conv.SAV
TEXT @input aep_fix
ordr
fact
tysl
rtrn
ALTR
6

Y
TRIPBOTH_A.out

0
TEXT SELECT CHANNELS TO MONITOR IN GRAPHICS WINDOW
TEXT 1 -- #1 -- FREQUENCY -- PRESQUE ISLE
TEXT 2 -- #2 -- VOLTAGE -- PRESQUE ISLE (WAS #49 -- MVA -- LINE 64451)
TEXT 3 -- #111 -- VOLTAGE -- GR RAPID69
TEXT 4 -- #53 -- MVA -- LINE 6913 @ INDIAN LK
TEXT 5 -- #103-- MW -- ISLAND LOAD (ZONE 369)
TEXT 6 -- #55 -- MVA -- LINE 6912 @ HIAWATHA
ALTR
4
1
Y
1
Y
Y
-.045,0.005
2
Y
2
Y
Y
0.875,1.125
3
Y
111
Y
Y
0.85,1.20
4
Y
53
```

Y  
Y  
0,50  
5  
Y  
103  
Y  
Y  
0,600  
6  
Y  
55  
Y  
Y  
0,50  
-1  
0  
TEXT OPEN GRAPHICS WINDOW  
OPTN  
10  
26

run  
0.5,20,1,5  
lofl  
chnng  
3 / branch  
39576 39545 1 / 6851 -- White Clay - Lawn Road  
1 / change first line  
0 / status off  
-1  
39575 39589 1 / 64441 -- Stiles 4 - Pulliam  
1  
0  
0  
-1

ORDR  
FACT,DP  
rtrn  
run  
1,120,1,5  
lofl  
chnng  
3 / branch  
38897 39589 2 / 64441 -- Stiles 5 - Pulliam  
1  
0  
0  
-1

ORDR  
FACT,DP  
rtrn  
run,CM  
1.80,120,1,5  
lofl

```
chnng
3 / branch
38995 38997 1 / 6530 -- MASS
1
0
0
-1
```

```
ORDR
FACT,DP
rtrn
run,cm
10,120,1,5
stop
```

PLOT\_FIG\_C.IDV

```
MENU,OFF      /* FORCE MENU TO CORRECT STATUS
odev
2
plotcase.log
pdev
2
plotcase.log
chnf c:\WUMS Island Study\Simulation Runs\TRIPBOTH_c.out
LFTI
1
APPENDIX c. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT
1
    UNIFORM 30% UNDERFREQUENCY LOAD SHEDDING -- No MOTOR TRIPPING
RELY
C:\WUMS Island Study\Simulation Runs\wums_relays.DAT
TINT
0.000000 10.000000
SLCT
2
0.85 1.15
5
0.85 1.15
6
0.85 1.15
7
0.85 1.15
8
0.85 1.15
9
0.75 1.25
PLOT
C-1 TSM. VOLTAGES
41
FUNC
2
60*(1+A)
SLCT
14
57.75 60.25
15
57.75 60.25
16
57.75 60.25
17
57.75 60.25
18
57.75 60.25
20
57.75 60.25
PLOT
C-2 GEN. SPEEDS (Hz)
FUNC
1
TINT
0.000000 2.000000
```

```

SLCT
49
0.0000 400.0000
50
0.0000 400.0000
53
0.0000 100.0000
55
0.0000 100.0000
0
PLOT
C-3 mva flows into island
TINT
0.000000 10.000000
SLCT
62
400. 900.
0
FUNC
2
A-B
SLCT
65 68
400. 900.
0
PLOT
C-4 Island Gen. & Load
FUNC
2
60*(1+A)
SLCT
1
57.75 60.25
78
57.75 60.25
79
57.75 60.25
80
55 60
81
55 60
0
FUNC
1
SLCT
72
0.8750 1.1250
PLOT
C-5.1 Empire 1
FUNC
2
60*(1+A)
SLCT
1
57.75 60.25
82
57.75 60.25

```

```

83
57.75 60.25
85
55 60
86
55 60
0
FUNC
1
SLCT
73
0.8750 1.1250
PLOT
C-5.2 Empire 2
FUNC
2
60*(1+A)
SLCT
1
57.75 60.25
88
57.75 60.25
89
57.75 60.25
90
55 60
91
55 60
0
FUNC
1
SLCT
73
0.8750 1.1250
PLOT
C-5.3 Empire 3
FUNC
2
60*(1+A)
SLCT
1
57.75 60.25
92
57.75 60.25
93
57.75 60.25
94
55 60
95
55 60
0
FUNC
1
SLCT
73
0.8750 1.1250
PLOT

```



C-5.4 Empire 4

FUNC

2

60\*(1+A)

SLCT

1

57.75 60.25

96

57.75 60.25

97

57.75 60.25

98

57.75 60.25

99

55 60

0

FUNC

1

SLCT

73

0.8750 1.1250

PLOT

C-6.1 Tilden 1

FUNC

2

60\*(1+A)

SLCT

1

57.75 60.25

102

57.75 60.25

103

57.75 60.25

104

57.75 60.25

105

55 60

0

FUNC

1

SLCT

73

0.8750 1.1250

PLOT

C-6.2 Tilden 2

POPT

6

0.01667

0

TINT

0.9833 2.0

PTYP,XY

SLCT

47

-.5000 2.0000

48

-.2500 2.2500

```
39764-39763- DISTR
PLOT
C-7.1 hiC-eng DIST. relay
SLCT
45
-1.0000 1.5000
46
-.5000 2.0000
39764-39769- DISTR
PLOT
C-7.2 hiC-gld DIST. relay
ODEV
1
PDEV
1
TEXT ENTER 0
stop
```

PLOT\_FIG\_D.IDV

```
MENU,OFF      /* FORCE MENU TO CORRECT STATUS
odev
2
plotcase.log
pdev
2
plotcase.log
chnf c:\WUMS Island Study\Simulation Runs\TRIPBOTH_b.out
RANG
1
5
1
VOLT*,1,99,0.80,1.20
SPD*,1,999,55.5,60.5
FREQ*,1,999,55.5,60.5

0
LFTI
1
EHHIBIT D. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT
1
          UNIFORM 30% UNDERFREQUENCY LOAD SHEDDING
RELY
C:\WUMS Island Study\Simulation Runs\wums_relays.DAT
TINT
0.0 10.0
SLCT
2

5

6

7

8

110

PLOT
D-1 TSM. VOLTAGES
41
FUNC
2
60*(1+A)
SLCT
14
57.75 60.25
15
57.75 60.25
16
57.75 60.25
17
57.75 60.25
18
```

```

57.75 60.25
20
57.75 60.25
PLOT
D-2 GEN. SPEEDS (Hz)
FUNC
1
CHID
100
1
ISLAND MECHANICAL POWER
101
1
ISLAND ELECTRICAL POWER
103
1
ISLAND LOAD(EXCL. MINES)
108
1
MINE LOADS(NON-MOTOR)
106
1
MINE MOTOR LOADS
0
SLCT
100
400. 900.
0
FUNC
2
A-B
SLCT
103 106
400. 900.
0
PLOT
D-3 Island Gen. & Load
FUNC
1
SLCT
100
-100. 900
101
-100. 900
103
-100. 900
108
-100. 900.
0
FUNC
2
-A
SLCT
106
-100. 900.
0
CHID

```

100  
1  
ISLAND MECHANICAL POWER  
101  
1  
ISLAND ELECTRICAL POWER  
103  
1  
ISLAND LOAD(EXCL. MINES)  
108  
1  
MINE LOADS(NON-MOTOR)  
106  
1  
MINE MOTOR LOADS  
0  
PLOT  
D-3A Gen. & Load Details  
FUNC  
2  
60\*(1+A)  
SLCT  
1  
55.5,60.5  
68  
55.5,60.5  
69  
55.5,60.5  
70  
55.5,60.5  
71  
55.5,60.5  
0  
FUNC  
1  
SLCT  
62  
  
PLOT  
D-4.1 Empire 1  
FUNC  
2  
60\*(1+A)  
SLCT  
1  
55.5,60.5  
72  
55.5,60.5  
73  
55.5,60.5  
75  
55.5,60.5  
76  
55.5,60.5  
0  
FUNC  
1

SLCT  
63

PLOT  
D-4.2 Empire 2

FUNC  
2  
 $60*(1+A)$

SLCT  
1  
55.5,60.5  
78  
55.5,60.5  
79  
55.5,60.5  
80  
55.5,60.5  
81  
55.5,60.5

0  
FUNC

1  
SLCT  
63

PLOT  
D-4.3 Empire 3

FUNC  
2  
 $60*(1+A)$

SLCT  
1  
55.5,60.5  
82  
55.5,60.5  
83  
55.5,60.5  
84  
55.5,60.5  
85  
55.5,60.5

0  
FUNC

1  
SLCT  
63

PLOT  
D-4.4 Empire 4

FUNC  
2  
 $60*(1+A)$

SLCT  
1  
55.5,60.5  
86  
55.5,60.5

87  
55.5,60.5  
88  
55.5,60.5  
89  
55.5,60.5  
0  
FUNC  
1  
SLCT  
63

PLOT  
D-5.1 Tilden 1  
FUNC  
2  
60\*(1+A)  
SLCT  
1  
55.5,60.5  
92  
55.5,60.5  
93  
55.5,60.5  
94  
55.5,60.5  
95  
55.5,60.5  
0  
FUNC  
1  
SLCT  
63

PLOT  
D-5.2 Tilden 2  
MCHN  
TRIPBOTH\_a.out  
TRIPBOTH\_b.out  
TRIPBOTH\_c.out  
-1  
FUNC  
2  
60\*(1+A)  
SLCT  
14  
58.0,60.5  
0  
LFTI  
1  
EHHIBIT D. SIMULATION OF NOVEMBER 14, 2001 ISLANDING EVENT  
1  
COMPARE EXISTING AND ENHANCED UNDERFREQUENCY LOAD SHEDDING  
PLOT  
D-6 Frequency comparison  
FUNC  
2

```
A-B+C  
SLCT  
103 106 108  
400. 900.  
0  
PLOT  
D-7 Load comparison  
ODEV  
1  
PDEV  
1  
TEXT ENTER 0  
stop
```