

The following material presents insight into potential redispatch options in the context of Lore-Turkey River-Cassville 161kV limits found in the revised MAIN TASG (Transmission Assessment Study Group)2003 summer assessment.

Listed below are some redispatch factors for selected units from the MAIN 2003 summer TASG case (posted on 4/11/2003). The units listed below were chosen because of: 1) Their proximity to the Lore-Turkey River-Cassville 161 kV line and 2) Output levels in the TASG 2003 base case indicate that they may be available for redispatch. Redispatch factors (composed of Generation Shift Factors (GSF) pairs) for selected units are shown based on their size and proximity. The redispatch factors show what percentage of the redispatch will be expected to flow across the selected limit.

<u>Lore-Turkey River-Cassville 161kV</u>		<u>Redispatch</u>
<u>for loss of Wempletown-Paddock 345kV + 69 operating steps</u>		<u>Factor</u>
Stoneman (52MW DPC) to Cordova	(CE, 451 MW on in case)	49.2%
Stoneman (52MW DPC) to Beaver Channel		51.3%
Stoneman (52MW DPC) to Rockford Energy Center	(CE, 377MW on in case)	46.6%
Stoneman (52MW DPC) to Collins		45.2%
Stoneman (52MW DPC) to Joliet		45.1%
Stoneman (52MW DPC) to Elk Mound	(DPC, 63 MW on in case)	39.8%
Germantown (WEC) to Cordova	(CE)	8.6%
Germantown (WEC) to Beaver Channel	(ALTW, 234MW on in case)	10.7%
Fitchburg (MGE) to Cordova	(CE)	14.5%
Collins (CE) to Cordova	(CE)	4.0%

Real-time redispatch must take into account other potential transmission limitations. NERC MRD (Market ReDispatch) policy allows for non-firm redispatch to support firm transmission service to the extent it remains flowing and is not curtailed by other TLR activity. For example, a Stoneman against Rockford Energy Center redispatch has a 6.2% factor in the aggravating direction for Flowgate 3006 ECL-ARP. That redispatch direction would be subject to TLR activity on Flowgate 3006.

The **attached spreadsheet** lists additional GSFs (Generation Shift Factors) for selected units with significant size and proximity to the Lore-Turkey River-Cassville 161kV. The GSFs are referenced to the Stoneman generation, which is in close proximity to the downstream end of Lore-Turkey River-Cassville 161kV. The Net Redispatch shift factors can be obtained by subtracting the decremented (dec) unit GSF from the increased (inc) unit GSF.

$$\text{Redispatch Factor} = (\text{GSF}_{\text{inc}} - \text{GSF}_{\text{dec}}) * 100\% \quad (\text{a negative factor would reduce flow})$$

GSF Analysis

related to potential redispatch options

to relieve Lore-Turkey River-Cassville 161kV flows for the outage of Wempletown Paddock 345kV.

Data is based on the MAIN 2003 summer TASG case posted 4/11/2003

GSF's for selected units are shown based on their size and proximity.

GSF are referenced to the Stoneman generation, which is in close proximity to the downstream end of Lore-Turkey River-Cassville 161kV.

The Net Redispatch shift factors can be obtained by subtracting the dec unit GSF from the inc unit GSF.

Subsystem (Case Bus#_ Bus name)	Flowgate 3704 Powshk-Reasn flo Montez-Bondu	Flowgate 6801 QuadCty West	Flowgate 6004 MWSI	Flowgate 6009 Cooper_S	Flowgate 3006 EauCl-Arpin	Flowgate 3707+ Lore-TurkeyRv161 flo Wemp-Pad345 +69kV Op steps
	Notes	Notes	Notes	Notes	Notes	Notes
34024_LANS5_4G	-0.0156	-0.1162	0.0355	0.0328	0.0793	0.3487
34041_BEVCHN28	0.0167	-0.0107	-0.0062	-0.0184	-0.016	0.5127
34090_ARNOLD1G	-0.0021	-0.268	-0.0095	0.0229	0.03	0.478
34146_OTTUMW1G	0.1141	-0.2564	0.0414	0.0243	0.0174	0.469
35981_LEECO_G1	0.0113	0.2123	-0.0184	-0.0381	-0.0463	0.475
37524_BYRON_1U	0.0087	0.1656	-0.0246	-0.0423	-0.0582	0.4688
37526_COLL1_1U	0.0033	0.0488	-0.0117	-0.0733	-0.0539	0.4523
37542_JO_29_7U	0.0041	0.0597	-0.0171	-0.0674	-0.059	0.4508
37551_QUAD_1U	0.0183	0.3628	-0.007	-0.0221	-0.0208	0.4927
37616_CORDO_	0.0183	0.3656	-0.007	-0.0222	-0.0209	0.4923
37620_ROCKF_BP	0.0077	0.1449	-0.0262	-0.0448	-0.0619	0.4658
37655_KENDA_1C	0.0044	0.0562	-0.0163	-0.0674	-0.0579	0.4515
39000_NED_G1	-0.0005	0.0063	-0.0048	-0.0028	-0.0099	0.033
39043_ROR_G5	0.0041	0.0998	-0.0445	-0.038	-0.0871	0.3501
39137_CHA1_18	0.0029	0.0902	-0.0551	-0.0357	-0.1024	0.3571
39277_CCD_GT1	0.0017	0.071	-0.0634	-0.04	-0.1169	0.3911
39323_GER_GT1	0.0011	0.062	-0.0682	-0.0416	-0.1247	0.4059
39403_PRS_GT1	0.0028	0.0733	-0.0478	-0.0482	-0.0968	0.4114
39430_PL_PRG1	0.003	0.0684	-0.0421	-0.0534	-0.0905	0.4309
39590_PUL_G7	-0.0027	0.0371	-0.1132	-0.0282	-0.1876	0.3998
39678_WES_G3	-0.0101	-0.0115	-0.1597	-0.0009	-0.2703	0.3955
39822_FCH_14_1	0.002	0.0787	-0.0584	-0.0327	-0.1063	0.3471
39968_BLT_G7	0.0017	0.0752	-0.0601	-0.0319	-0.1088	0.3459
63804_CBLUF1G	-0.0698	-0.1843	0.1169	0.1818	0.0466	0.455
63881_NEAL_1G	-0.0664	-0.1809	0.1641	0.1555	0.0699	0.4494
64487_LOUIS31G	0.0266	-0.4238	0.0023	-0.0092	-0.0017	0.4836
68701_STONE	0	0	0	0	0	0
69397_ELKMDGEN	-0.0221	-0.0944	0.3897	0.0412	0.2476	0.3982
69538_ALMA5_4G	-0.0219	-0.11	0.2064	0.0438	0.1706	0.3866
69542_JFM	-0.0219	-0.11	0.2064	0.0438	0.1706	0.3866