

**ATC's Transmission Facilities Transitioning to the Study Based Ratings
Methodology Starting June 1, 2013**

	Transmission Line Names	Line Voltage
1	Arpin - Eau Claire 345 kV	345
2	Columbia SW YD (ALTE) - North Madison 345 kV (Line # - L-COL21)	345
3	Columbia SW YD (ALTE) - North Madison 345 kV (Line # - W-7)	345
4	Columbia SW YD (ALTE) - Rockdale 345 kV	345
5	Columbia SW YD (ALTE) - South Fond Du Lac SW YD 345 kV	345
6	Cypress SW YD - Arcadian 345 kV	345
7	Edgewater SW YD - South Fond Du Lac SW YD 345 kV	345
8	Elm Road 345 Sws Yd - Arcadian 345 kV	345
9	Elm Road 345 Sws Yd - Oak Creek SW YD 345 kV	345
10	Forest Junction - Cypress SW YD 345 kV	345
11	Fox River SW YRD - Forest Junction 345 kV	345
12	Fox River SW YRD - North Appleton 345 kV	345
13	Fox River SW YRD - Point Beach SW YD 345 kV	345
14	Granville - Arcadian 345 kV	345
15	Granville - Saukville 345 kV	345
16	Highway 22 - Gardner Park 345 kV	345
17	Highway 22 - Morgan 345 kV	345
18	Kewaunee SW YD - Point Beach SW YD 345 kV	345
19	Morgan - Plains 345 kV	345
20	North Appleton - Fitzgerald 345 kV	345
21	Paddock - Rockdale 345 kV	345
22	Paddock - Wempletown 345 kV	345
23	Pleasant Prairie SW YD - Arcadian 345 kV	345
24	Pleasant Prairie SW YD - Bain 345 kV (Line # - 641)	345
25	Pleasant Prairie SW YD - Bain 345 kV (Line # - 641)	345
26	Point Beach SW YD - Forest Junction 345 kV	345
27	Racine - Elm Road 345 Sws Yd 345 kV	345
28	Rocky Run - Arpin 345 kV	345
29	Saukville - Edgewater SW YD 345 kV	345
30	Sheboygan Falls Energy Center SW YD - Granville 345 kV	345
31	South Fond Du Lac SW YD - Fitzgerald 345 kV	345
32	Wempletown - Rockdale 345 kV	345
33	Werner West - Highway 22 345 kV	345
34	20th St - Edgewater SW YD 138 kV	138
35	96th St - West Junction 138 kV	138
36	Academy - Boxelder 138 kV	138
37	Albers - Paris 138 kV	138
38	Amberg - Crivitz 138 kV	138
39	Amberg - Holmes 138 kV	138
40	Amberg - Plains 138 kV (Line # - 60842)	138
41	Amberg - Plains 138 kV (Line # - 60853)	138
42	Amberg - Stiles SW STA 138 kV	138
43	Arnold - Forsyth 138 kV	138
44	Arnott - Hartman Creek 138 kV	138
45	Artesian - Birchwood 138 kV	138
46	Arthur Road - St Lawrence 138 kV	138
47	Aspen - Iron Grove 138 kV	138
48	Auburn - Barton 138 kV	138
49	Badger - Maplewood 138 kV	138
50	Badger - West Shawano 138 kV	138

**ATC's Transmission Facilities Transitioning to the Study Based Ratings
Methodology Starting June 1, 2013**

	Transmission Line Names	Line Voltage
51	Bark River - Summit 138 kV	138
52	Bay De Noc - Ingalls 138 kV	138
53	Birchwood - Kilbourn 138 kV	138
54	Blackhawk SW YD (ALTE) - Colley Rd 138 kV	138
55	Bluemound - 28th St 138 kV	138
56	Bluemound - Allerton 138 kV	138
57	Bluemound - Brookdale 138 kV	138
58	Bluemound - Butler 138 kV (Line # - 5051)	138
59	Bluemound - Butler 138 kV (Line # - 5061)	138
60	Bluemound - Lincoln 138 kV	138
61	Bluemound - O Connor 138 kV	138
62	Bluemound - Park Hill 138 kV	138
63	Bluemound - St Martins 138 kV	138
64	Bluemound - Tosa 138 kV	138
65	Boxelder - Stony Brook 138 kV	138
66	Branch - Pennsylvania 138 kV	138
67	Brick Church - Elkhorn 138 kV	138
68	Bristol (ALTE) - Delavan 138 kV	138
69	Burlington - Tichigan 138 kV	138
70	Butte Des Morts - Casaloma 138 kV	138
71	Butte Des Morts - City Limits 138 kV	138
72	Butte Des Morts - Tayco 138 kV	138
73	Butternut - Auburn 138 kV	138
74	Butternut - Forward Energy Center 138 kV	138
75	Canal - Dunn Rd 138 kV	138
76	Canal - Dyckesville 138 kV	138
77	Cardinal - Pleasant View 138 kV	138
78	Casaloma - Ellington 138 kV	138
79	Cedarburg South - 68th St 138 kV	138
80	Christiana - Kegonsa 138 kV (Line # - G-CHR21)	138
81	Christiana - Kegonsa 138 kV (Line # - X-59)	138
82	Clintonville - Badger 138 kV	138
83	Colley Rd - Brick Church 138 kV	138
84	Concord SW YD - Crawfish River 138 kV	138
85	Cooney - Summit 138 kV	138
86	Cornell Milwaukee - Fiebrantz 138 kV (Line # - 3611)	138
87	Cornell Milwaukee - Fiebrantz 138 kV (Line # - 3612)	138
88	Cornell Milwaukee - Shorewood 138 kV	138
89	Crawfish River - Jefferson 138 kV	138
90	Cross Country - Fitchburg 138 kV	138
91	Darlington - North Monroe 138 kV	138
92	Duplainville - Sussex 138 kV	138
93	East Krok - Canal 138 kV	138
94	Eastman Ave - Pulliam SW YD 138 kV	138
95	Eastman Ave - Tower Dr 138 kV	138
96	Eden - Spring Green 138 kV	138
97	Edgewater SW YD - Lodestar 138 kV	138
98	Edgewood - Mukwonago 138 kV	138
99	Elkhart Lake - Forest Junction 138 kV	138
100	Elkhorn - Bristol (ALTE) 138 kV	138

**ATC's Transmission Facilities Transitioning to the Study Based Ratings
Methodology Starting June 1, 2013**

	Transmission Line Names	Line Voltage
101	Ellington - Hintz 138 kV	138
102	Ellinwood - Aviation 138 kV	138
103	Empire Mine - National 138 kV	138
104	Falls - Morgan 138 kV	138
105	Femrite 138/69 kV - Sprecher 138 kV	138
106	Fitzgerald - Ellinwood 138 kV	138
107	Forest Junction - Glenview 138 kV	138
108	Forest Junction - Highway V 138 kV	138
109	Forest Junction - Howards Grove 138 kV	138
110	Forest Junction - Lake Park 138 kV	138
111	Forest Junction - Melissa 138 kV	138
112	Forest Junction - Tecumseh Rd 138 kV	138
113	Forsyth - Empire Mine 138 kV	138
114	Forsyth - Munising 138 kV	138
115	Fredonia - Saukville 138 kV	138
116	Freeman - National 138 kV	138
117	Freeman - Presque Isle SW YD 138 kV	138
118	Garden Corners - Indian Lake 138 kV	138
119	Germantown SW YD - Bark River 138 kV	138
120	Glenview - Shoto 138 kV	138
121	Glory Rd - Depere 138 kV	138
122	Granville - 68th St 138 kV	138
123	Granville - Parkland 138 kV	138
124	Green Lake SW STA - Wautoma 138 kV	138
125	Harrison North 138kV - Hartman Creek 138 kV	138
126	Harrison North 138kV - White Lake (WE) 138 kV	138
127	Hartford - Butler Ridge 138 kV	138
128	Hiawatha (ESE) - Brevort Tap 138 kV	138
129	Highway V - Dyckesville 138 kV	138
130	Highway V - East Krok 138 kV	138
131	Highway V - Tower Dr 138 kV	138
132	Hillman - Darlington 138 kV	138
133	Hintz - Werner 138 kV	138
134	Holland - Howards Grove 138 kV	138
135	Holland - Saukville 138 kV	138
136	Holmes - Chalk Hill Hy 138 kV	138
137	Hoover - Arnott 138 kV	138
138	Ingalls - Holmes 138 kV	138
139	Iron Grove - Lakota Rd 138 kV	138
140	Janesville General SW YD - Rock River 138 kV	138
141	Janesville General SW YD - Russell 138 kV	138
142	Jefferson - Fort Atkinson 138 kV	138
143	Jefferson - Stony Brook 138 kV	138
144	Kegonsa - Femrite 138 kV	138
145	Kegonsa - Fitchburg 138 kV	138
146	Kegonsa - Oak Ridge 138 kV	138
147	Kewaunee SW YD - Shoto 138 kV	138
148	Kirkwood - Fox Hills Tap 138 kV	138
149	Kohler - Lodestar 138 kV	138
150	Lake Park - City Limits 138 kV	138

**ATC's Transmission Facilities Transitioning to the Study Based Ratings
Methodology Starting June 1, 2013**

	Transmission Line Names	Line Voltage
151	Liberty St - Glory Rd 138 kV	138
152	Lodestar - Erdman 138 kV	138
153	Lost Dauphin - Forest Junction 138 kV	138
154	Lost Dauphin - Highway V 138 kV	138
155	M-38 - Atlantic 138 kV	138
156	Mackinac - Straits #1 138 kV	138
157	Mackinac - Straits #2 138 kV	138
158	Mackinac - Straits #3 138 kV	138
159	Maes - Apple Hills 138 kV	138
160	Maes - Combined Locks 138 kV	138
161	Maple (WE) - Germantown SW YD 138 kV	138
162	Mason St - Howard 138 kV	138
163	McCue - Sunrise 138 kV	138
164	Menominee - Bay De Noc 138 kV	138
165	Merrill Hills - Summit 138 kV	138
166	Metomen - North Fond Du Lac 138 kV	138
167	Mukwonago - Merrill Hills 138 kV	138
168	Mukwonago - Whitewater 138 kV	138
169	Mullet River - Plymouth Muncipal 138 kV	138
170	National - Tilden 138 kV (Line # - 16343)	138
171	National - Tilden 138 kV (Line # - 16344)	138
172	Nelson Dewey SW YD - Eden 138 kV	138
173	Nelson Dewey SW YD - Hillman 138 kV	138
174	Nordic - Perch Lake 138 kV	138
175	North Appleton - Apple Hills 138 kV	138
176	North Appleton - Ellington 138 kV	138
177	North Appleton - Kaukauna North 138 kV	138
178	North Appleton - Lost Dauphin 138 kV	138
179	North Appleton - Mason St 138 kV	138
180	North Appleton - White Clay 138 kV	138
181	North Beaver Dam - Beaver Dam East 138 kV	138
182	North Fond Du Lac - Green Lake SW STA 138 kV	138
183	North Fond Du Lac - Ohmstead 138 kV	138
184	North Fond Du Lac - South Fond Du Lac SW YD 138 kV	138
185	North Gate SW STR - Erdman 138 kV	138
186	North Lake - Empire Mine 138 kV	138
187	North Lake - M-38 138 kV	138
188	North Lake Geneva - Elkhorn 138 kV	138
189	North Lake Geneva - North Lake Geneva Tap - Burlington 138 kV	138
190	North Madison 345/138 kV - Cardinal 138 kV	138
191	North Madison 345/138 kV - Huiskamp 138 kV	138
192	North Madison 345/138 kV - Yahara River 138 kV	138
193	North Monroe - Bass Creek 138 kV	138
194	North Randolph - Green Lake SW STA 138 kV	138
195	North Randolph - Metomen 138 kV	138
196	North Randolph - North Beaver Dam 138 kV	138
197	Norwich - Harbor (WE) 138 kV	138
198	Norwich - Kansas 138 kV	138
199	Norwich - Ramsey 138 kV	138
200	O Connor - 28th St 138 kV	138

**ATC's Transmission Facilities Transitioning to the Study Based Ratings
Methodology Starting June 1, 2013**

	Transmission Line Names	Line Voltage
201	Oak Creek SW YD - 51st St Term 138 kV	138
202	Oak Creek SW YD - Nicholson Tap 138 kV	138
203	Oak Creek SW YD - Ramsey 138 kV	138
204	Oak Creek SW YD - Root River 138 kV	138
205	Oak Ridge - Fitchburg 138 kV	138
206	Oak Ridge - Verona 138 kV	138
207	Ohmstead - Rienzi Road 138 kV	138
208	Paddock - Blackhawk SW YD (ALTE) 138 kV	138
209	Paris - Burlington 138 kV	138
210	Paris - St Martins 138 kV	138
211	Park Hill - 28th St 138 kV	138
212	Parkland - Mequon 138 kV	138
213	Perch Lake - M-38 138 kV	138
214	Perkins - Garden Corners 138 kV	138
215	Perkins - Indian Lake 138 kV	138
216	Pioneer (WPS) - Falls 138 kV	138
217	Pioneer (WPS) - Stiles SW STA 138 kV	138
218	Pioneer (WPS) - West Marinette SW YD 138 kV	138
219	Plains - Arnold 138 kV	138
220	Plains - Aspen 138 kV	138
221	Plains - Nordic 138 kV	138
222	Pleasant Valley - Arthur Road 138 kV	138
223	Pleasant View - Cross Country 138 kV	138
224	Port Edwards - Saratoga 138 kV	138
225	Port Edwards - Sigel 138 kV	138
226	Port Washington SW YD - Range Line SW 138 kV (Line # - 731)	138
227	Port Washington SW YD - Range Line SW 138 kV (Line # - 751)	138
228	Port Washington SW YD - Saukville 138 kV (Line # - 752)	138
229	Portage - Columbia SW YD (ALTE) 138 kV (Line # - X-13)	138
230	Portage - Columbia SW YD (ALTE) 138 kV (Line # - X-20)	138
231	Portage - Staff 138 kV	138
232	Portage - Trienda 138 kV	138
233	Presque Isle SW YD - Dead River (WE) 138 kV	138
234	Presque Isle SW YD - National 138 kV	138
235	Presque Isle SW YD - North Lake 138 kV	138
236	Presque Isle SW YD - Perch Lake 138 kV	138
237	Presque Isle SW YD - Tilden 138 kV	138
238	Pulliam SW YD - Bayport SW STA 138 kV	138
239	Pulliam SW YD - Howard 138 kV	138
240	Pulliam SW YD - Liberty St 138 kV	138
241	Pulliam SW YD - Maplewood 138 kV	138
242	Racine - Hayes 138 kV	138
243	Racine - Kenosha 138 kV	138
244	Racine - Somers 138 kV	138
245	Range Line SW - Glendale 138 kV	138
246	Red Maple - Depere 138 kV	138
247	Red Maple - Lost Dauphin 138 kV	138
248	Reiner Rd - Sycamore SW YD 138 kV	138
249	Rock River - Colley Rd 138 kV	138
250	Rock River - Southwest Delavan 138 kV	138

**ATC's Transmission Facilities Transitioning to the Study Based Ratings
Methodology Starting June 1, 2013**

	Transmission Line Names	Line Voltage
251	Rock River - Town Line Rd (ALTE) 138 kV (Line # - X-73)	138
252	Rock River - Town Line Rd (ALTE) 138 kV (Line # - X-74)	138
253	Rockdale - Boxelder 138 kV	138
254	Rockdale - Christiana 138 kV (Line # - X-65)	138
255	Rockdale - Christiana 138 kV (Line # - X-66)	138
256	Rockdale - Jefferson 138 kV	138
257	Root River - St Martins 138 kV	138
258	Rubicon - Butler Ridge 138 kV	138
259	Rubicon - Hubbard 138 kV	138
260	Russell - McCue 138 kV	138
261	Russell - Rockdale 138 kV	138
262	Russell - Town Line Rd (ALTE) 138 kV	138
263	Saukville - Barton 138 kV	138
264	Saukville - Cedarburg South 138 kV	138
265	Saukville - Elkhart Lake 138 kV	138
266	Saukville - Maple (WE) 138 kV	138
267	Saukville - Mequon 138 kV	138
268	Saukville - Pleasant Valley 138 kV	138
269	Sherwood - Roosevelt Rd 138 kV	138
270	Sigel - Arpin 138 kV	138
271	South Fond Du Lac SW YD - Forward Energy Center 138 kV	138
272	South Fond Du Lac SW YD - Ohmstead 138 kV	138
273	South Sheboygan Falls - Edgewater SW YD 138 kV	138
274	South Sheboygan Falls - Mullet River	138
275	Southwest Delavan - Bristol (ALTE) 138 kV	138
276	Sprecher - Reiner Rd 138 kV	138
277	Spring Green - Kirkwood 138 kV	138
278	St Lawrence - Barton 138 kV	138
279	St Lawrence - Hartford 138 kV	138
280	Staff - North Randolph 138 kV	138
281	Stiles SW STA - Crivitz 138 kV	138
282	Sunrise - Rock River 138 kV	138
283	Sunset Point - Fitzgerald 138 kV	138
284	Tamarack - Sussex 138 kV	138
285	Tayco - Melissa 138 kV	138
286	Tecumseh Rd - Fredonia 138 kV	138
287	Tosa - Granville 138 kV	138
288	Tower Dr - Pulliam SW YD 138 kV	138
289	Town Line Rd (ALTE) - Janesville General SW YD 138 kV	138
290	Town Line Rd (ALTE) - Paddock 138 kV	138
291	Trienda - Kilbourn 138 kV	138
292	Waukesha - Duplainville 138 kV	138
293	Wautoma - Port Edwards 138 kV	138
294	Werner West - Clintonville 138 kV	138
295	Werner West - Werner 138 kV	138
296	Werner West - White Lake (WE) 138 kV	138
297	West Marinette SW YD - Menominee 138 kV	138
298	West Marinette SW YD - Roosevelt Rd 138 kV	138
299	West Middleton - Cardinal 138 kV (Line # - X-93)	138
300	West Middleton - Cardinal 138 kV (Line # - X-94)	138

**ATC's Transmission Facilities Transitioning to the Study Based Ratings
Methodology Starting June 1, 2013**

	Transmission Line Names	Line Voltage
301	West Shawano - East Shawano 138 kV	138
302	White Clay - East Shawano 138 kV	138
303	White Clay - Morgan 138 kV	138
304	Whitewater - Sunrise 138 kV	138
305	Winona - M-38 138 kV	138
306	Yahara River - Sycamore SW YD 138 kV	138
307	Aurora St - Venus 115 kV	115
308	Badger - Caroline 115 kV	115
309	Caroline - Whitcomb 115 kV	115
310	Coyne St - Plover 115 kV	115
311	Coyne St - Rocky Run 115 kV	115
312	Cranberry - St Germain 115 kV	115
313	Cranberry - Venus 115 kV	115
314	Eastom - Tomahawk - ATC 115kV 115 kV	115
315	Gardner Park - Aurora St 115 kV	115
316	Gardner Park - Hilltop (WPS) 115 kV	115
317	Gardner Park - Kelly 115 kV	115
318	Grandfather Falls - Tomahawk - ATC 115kV 115 kV	115
319	Highway 8 - Hodag 115 kV	115
320	Highway 8 - Clear Lake 115 kV	115
321	Highway 8 - Rhinelander Paper Company 115 kV	115
322	Hume - Mill Creek 115 kV	115
323	Kelly - Pine (WPS) 115 kV	115
324	Maine - Hilltop (WPS) 115 kV	115
325	Maine - Pine (WPS) 115 kV	115
326	McMillan - Wildwood (MEWD) 115 kV	115
327	Mill Creek - Arpin 115 kV	115
328	Pine (WPS) - Eastom 115 kV	115
329	Pine (WPS) - Grandfather Falls 115 kV	115
330	Plover - Whiting Ave 115 kV	115
331	Rocky Run - Plover 115 kV	115
332	Rocky Run - Weston SW YD 115 kV	115
333	Rocky Run - Whiting Ave 115 kV	115
334	Saratoga - Coyne St 115 kV	115
335	Sherman St - Hilltop (WPS) 115 kV	115
336	Sherman St - Sunnyvale 115 kV	115
337	St Germain - Clear Lake 115 kV	115
338	Sunnyvale - Wien SW STA 115 kV	115
339	Venus - Hodag 115 kV	115
340	Venus - Metonga 115 kV	115
341	Weston SW YD - Gardner Park 115 kV (Line # - U-GDP61)	115
342	Weston SW YD - Gardner Park 115 kV (Line # - U-GDP71)	115
343	Weston SW YD - Morrison Ave 115 kV	115
344	Weston SW YD - Sherman St 115 kV	115
345	Whitcomb - Kelly 115 kV	115
346	Whiting Ave - Hoover 115 kV	115
347	Wien SW STA - Stratford 115 kV	115
348	Wien SW STA - T Corners 115 kV	115
349	Wildwood (MEWD) - Hume 115 kV	115
350	9 Mile SW STA - Roberts SW STA 69 kV	69

**ATC's Transmission Facilities Transitioning to the Study Based Ratings
Methodology Starting June 1, 2013**

	Transmission Line Names	Line Voltage
351	Academy - Columbus (ALTE) 69 kV	69
352	Alto SW STR - Waupun 69 kV	69
353	Artesian - Reedsburg 69 kV	69
354	Aspen - Florence Tap 69 kV	69
355	Aspen - Pine Hy Tap 69 kV	69
356	Atlantic - Osceola 69 kV (Line # - Laurium1)	69
357	Atlantic - Osceola 69 kV (Line # - Laurium2)	69
358	Bass Creek - Sheepskin 69 kV	69
359	Berlin - Wautoma 69 kV	69
360	Big Pond - Petenwell 69 kV	69
361	Big Quinnesec Falls Hy - Armory 69 kV	69
362	Blacksmith - South Monroe 69 kV	69
363	Blount - Ruskin 69 kV	69
364	Blount - Sycamore SW YD 69 kV	69
365	Boscobel - Lone Rock 69 kV	69
366	Brandon Tap - Fairwater 69 kV	69
367	Canal - Dunn Rd 69 kV	69
368	Chaffee Creek - Sand Lake 69 kV	69
369	Colley Rd - East Beloit 69 kV	69
370	Columbia SW YD (ALTE) - Deforest 69 kV	69
371	Columbia SW YD (ALTE) - Rio Pumping Station 69 kV	69
372	Columbus (ALTE) - Columbus South 69 kV	69
373	Columbus (ALTE) - South Beaver Dam 69 kV	69
374	Council Creek - Warrens 69 kV	69
375	Crivitz - Pioneer (WPS) 69 kV	69
376	Crivitz - Sandstone Rapids Hy 69 kV	69
377	Cross Country - Fitchburg 69 kV	69
378	Crystal Falls - Iron Grove 69 kV	69
379	Curtis Tap - Gould City Sw Str 69 kV	69
380	Custer - Dewey 69 kV	69
381	Dam Heights - Portage 69 kV	69
382	Dam Heights - Spruce Street 69 kV	69
383	Dane - Waunakee SW STA 69 kV	69
384	Darlington - Jennings Rd SW STA 69 kV	69
385	Deforest - North Madison 69 kV	69
386	Deforest - Sun Prairie 69 kV	69
387	Dunn Rd - First Ave 69 kV	69
388	Dunn Rd - Sister Bay 69 kV	69
389	Dyckesville - Sawyer SW STA 69 kV	69
390	Eagle Tap - James Olson 69 kV	69
391	East Campus - Wingra 69 kV	69
392	Eden - Dodgeville 69 kV	69
393	Eden - Rock Branch 69 kV	69
394	Edgewater SW YD - Erdman 69 kV	69
395	Edgewater SW YD - Riverside (ALTE) 69 kV	69
396	Ellinwood - Sunset Point 69 kV	69
397	Erdman - Riverside (ALTE) 69 kV	69
398	Escanaba Steam Plant - Delta (UPPCO) 69 kV	69
399	Femrite - Femrite 138/69 kV 69 kV	69
400	Femrite - Royster 69 kV	69

**ATC's Transmission Facilities Transitioning to the Study Based Ratings
Methodology Starting June 1, 2013**

	Transmission Line Names	Line Voltage
401	Finger Rd SW STA - Highway V 69 kV	69
402	Finger Rd SW STA - Wesmark 69 kV	69
403	Fitchburg - Wingra 69 kV	69
404	Forsyth - Gwinn 69 kV	69
405	Glenview - New Holstein SW STA 69 kV	69
406	Goodman SW STR - Lakehead Rapid River 69 kV	69
407	Hiawatha (ESE) - Pine River 69 kV (Line # - 6909)	69
408	Hiawatha (ESE) - Pine River 69 kV (Line # - ESE_6908)	69
409	Hillman - Eden 69 kV	69
410	Hillman - Miners 69 kV	69
411	Hillside - Gays Mills SW STR 69 kV	69
412	Hillside - Gran Grae 69 kV	69
413	Hilltop (ALTE) - DPC Mauston SW STR 69 kV	69
414	Hubbard - South Beaver Dam 69 kV	69
415	Indian Lake - Hiawatha (ESE) 69 kV	69
416	Indian Lake - Manistique 69 kV (Line # - 6915)	69
417	Indian Lake - Manistique 69 kV (Line # - ESE_6910)	69
418	Iola - Arnott 69 kV	69
419	Iola - Whitcomb 69 kV	69
420	Janesville General SW YD - McCue 69 kV	69
421	Kegonsa - Sun Prairie 69 kV	69
422	Kilbourn - Chaffee Creek 69 kV	69
423	Kilbourn - Finnegan Tap 69 kV	69
424	Kilbourn - Hilltop (ALTE) 69 kV	69
425	Lake Geneva Sw Str - South Lake Geneva 69 kV	69
426	Lakefront SW YD - Dewey 69 kV	69
427	Lake Mine - Winona	69
428	Lakota Rd - Conover 69 kV	69
429	LaMar - Sheepskin 69 kV	69
430	Lincoln - ACEC Coloma WC9T - Chaffee Creek 69 kV	69
431	Lone Rock - Richland SW STR 69 kV	69
432	Lone Rock - Spring Green 69 kV	69
433	M-38 - Baraga VLG Tap 69 kV	69
434	Manrap - Shoto 69 kV	69
435	Mass - Conover 69 kV	69
436	Mauston Tap - Hilltop (ALTE) 69 kV	69
437	Mckenna - Big Pond 69 kV	69
438	Mckenna - Castle Rock 69 kV	69
439	Mead Pump SW STR - Bayview Tap 69 kV	69
440	Menominee - Wells St 69 kV	69
441	Metomen - Ripon 69 kV	69
442	Metomen - Rosendale Tap 69 kV	69
443	Miners - Shullsburg SW STR 69 kV	69
444	Monroe Central SW STR - Monroe Central 69 kV	69
445	Mullet River - North Mullet River 69 kV	69
446	Munising - Blamey Park 69 kV	69
447	Munising - Gwinn 69 kV	69
448	Nelson Dewey SW YD - Hillside 69 kV	69
449	New Holstein SW STA - Tecumseh Rd 69 kV	69
450	Nine Springs - Pflaum 69 kV	69

**ATC's Transmission Facilities Transitioning to the Study Based Ratings
Methodology Starting June 1, 2013**

Transmission Line Names		Line Voltage
451	Nordic - Powers 69 kV	69
452	Nordic - Feltch Mountain - Cornell Tap	69
453	North Beaver Dam - South Beaver Dam 69 kV	69
454	North Fond Du Lac - South Fond Du Lac SW YD 69 kV	69
455	North Monroe - Belleville 69 kV	69
456	North Randolph - Rio Pumping Station 69 kV	69
457	Northside (ALTE) Tap - Sheboygan Falls 69 kV	69
458	Norwich - Lincoln 69 kV	69
459	Oakfield Sw Str - South Fond Du Lac SW YD 69 kV	69
460	Omro Industrial Park SW STR - Omro Industrial Park 69 kV	69
461	Oregon - Stoughton 69 kV	69
462	Paddock - Shirland Ave SW STR 69 kV	69
463	Pioneer (WPS) - Crivitz 69 kV	69
464	Plains - Aragon 6160 Tap 69 kV	69
465	Plains - Big Quinnesec Falls Hy 69 kV	69
466	Plains - Bluff View 69 kV	69
467	Plains - Twin Falls SW STA 69 kV	69
468	Polar SW STR - Deer Trail 69 kV	69
469	Portage - Portage Ind Park 69 kV	69
470	Portage - Wautoma 69 kV	69
471	Powers - Chalk Hill Hy 69 kV	69
472	Presque Isle SW YD - Marquette Diesel 69 kV	69
473	Pulliam SW YD - Danz Ave SW STA 69 kV	69
474	Pulliam SW YD - Oak St 69 kV	69
475	Pulliam SW YD - Van Buren St 69 kV	69
476	Rapids - Revere Dr 69 kV	69
477	REC Newark SW STR - Brodhead SW STA 69 kV	69
478	REC Shaw - Colley Rd 69 kV	69
479	Revere Dr - Lakefront SW YD 69 kV	69
480	Revere Dr - Northeast 69 kV	69
481	Rio Pumping Station - Academy 69 kV	69
482	Ripon - Berlin 69 kV	69
483	Rock Branch - Mount Horeb 69 kV	69
484	Rock River - Turtle 69 kV	69
485	Russell - McCue 69 kV	69
486	Sadoff Co Tap - Sadoff Co 69 kV	69
487	Sharon SW STR - Brick Church 69 kV	69
488	Sheboygan Falls - Edgewater SW YD 69 kV	69
489	Sheepskin - Stoughton 69 kV	69
490	Shoto - Columbus (WPS) 69 kV	69
491	Sigel - Rozellville 69 kV	69
492	Skillet Creek SW STR - Moore St 69 kV	69
493	South Sheboygan Falls - Sheboygan Falls 69 kV	69
494	Spring Green - Wick Drive 69 kV	69
495	Stage Coach SW STA - Mount Horeb 69 kV	69
496	Stoughton - Kegonsa 69 kV	69
497	Strawberry Hill Tap - Strawberry Hill 69 kV	69
498	Sun Prairie - Reiner Rd 69 kV	69
499	Timberlane SW STR - Timberlane 69 kV	69
500	Twin Falls SW STA - Armory 69 kV	69

**ATC's Transmission Facilities Transitioning to the Study Based Ratings
Methodology Starting June 1, 2013**

Transmission Line Names		Line Voltage
501	Twin Falls SW STA - Nordic 69 kV	69
502	Verona - Sun Valley 69 kV	69
503	Victoria Hy - White Pine Mine 69 kV	69
504	Walworth - North Lake Geneva 69 kV	69
505	Waunakee SW STA - Division Street SW STR 69 kV	69
506	Waupun - South Fond Du Lac SW YD 69 kV	69
507	Wautoma - Chaffee Creek 69 kV	69
508	Wautoma - Harrison 69kV 69 kV	69
509	Wells St - Roosevelt Rd 69 kV	69
510	Wesmark - Rapids 69 kV	69
511	West Marinette SW YD - Menominee 69 kV	69
512	West Marinette SW YD - Wells St 69 kV	69
513	West Middleton - Pheasant Branch 69 kV	69
514	West Towne - Cross Country 69 kV	69
515	West Towne - Tokay 69 kV	69
516	West Wisconsin Rapids - Sigel 69 kV	69
517	Westport - Pheasant Branch 69 kV	69
518	Whitcomb - Deer Trail 69 kV	69
519	Willow Lawn Tap - Mercury Marine Tap 69 kV	69
520	Winona - Atlantic 69 kV	69
521	Winona - Mass 69 kV	69