

**ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied**

<b>Transmission Line Names</b>		<b>Line Voltage</b>
1	Plains - Bluff View SW STR 69kV	69
2	Bluff View SW STR - Bluff View 69kV	69
3	Aragon Tap - Norway 69kV	69
4	Aragon 6160 Tap - Aragon Tap 69kV	69
5	Aragon Tap - Aragon 69kV	69
6	Aragon 6160 Tap - Aragon 6150 Tap 69kV	69
7	Sagola Tap - Nordic 69kV	69
8	Sagola Tap - Sagola 69kV	69
9	Peavy Falls Hy - Sagola Tap 69kV	69
10	Cornell Tap (WEPCO) - Harris Tap 69kV	69
11	Sault SW STR - Sault 69kV	69
12	Sault SW STR - 3 Mile 69kV	69
13	3 Mile - 9 Mile SW STA 69kV	69
14	Nathan Tap - Nathan 69kV	69
15	Newberry Correctional Facility Tap - Newberry Correctional Facility 69kV	69
16	Hiawatha (ESE) - Engadine Tap 69kV	69
17	Engadine Tap - Newberry Tap 69kV	69
18	Engadine Tap - Engadine 69kV	69
19	Newberry Tap - Newberry 69kV	69
20	Newberry Tap - Newberry Correctional Facility Tap 69kV	69
21	Newberry Correctional Facility Tap - Roberts SW STA 69kV	69
22	Curtis Tap - Curtis 69kV	69
23	Blaney Park Sw Str - Curtis Tap 69kV	69
24	Gould City Sw Str - Hiawatha (ESE) 69kV	69
25	9 Mile SW STA - Pine River 69kV	69
26	Kincheloe Main Tap - Tone Tap 69kV	69
27	Tone Tap - Rudyard Tap 69kV	69
28	9 Mile SW STA - Kincheloe Main Tap 69kV	69
29	Rudyard Tap - Pine River 69kV	69
30	Kincheloe SW STA - Kincheloe Housing 69kV	69
31	Kincheloe SW STA - Kincheloe Main 69kV	69
32	Tone Tap - Tone 69kV	69
33	Rudyard Tap - Rudyard 69kV	69
34	Kincheloe Main Tap - Kincheloe SW STA 69kV	69
35	AGA Gas SW STR - AGA Gas 69kV	69
36	Pickford Tap - 6951 Tap (CLEC) 69kV	69
37	Goetzville Tap - Goetzville 69kV	69
38	9 Mile SW STA - Pickford Tap 69kV	69
39	6951 Tap (CLEC) - Goetzville Tap 69kV	69
40	Pickford Tap - Pickford 69kV	69
41	Goetzville Tap - Detour 69kV	69
42	Talentino Tap - Talentino SW STA 69kV	69
43	Talentino Tap - 6951 Tap (CLEC) 69kV	69
44	6951 Tap (ESE) - Talentino Tap 69kV	69
45	Lou Pac Tap - Lou Pac 69kV	69
46	Roberts SW STA - Lou Pac Tap 69kV	69
47	Lou Pac Tap - Newberry Vlg 69kV	69
48	Sycamore SW YD - East Towne 69kV	69

**ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied**

<b>Transmission Line Names</b>		<b>Line Voltage</b>
49	Sycamore SW YD - East Towne 69kV	69
50	Aspen - Michigamme Falls Hy 69kV	69
51	Pine Hy Tap - Pine Hy 69kV	69
52	Pine Hy Tap - Pine Hy 69kV	69
53	Aspen - Brule SW STA 69kV	69
54	Aspen - Peavy Falls Hy 69kV	69
55	Hiawatha Tap (AD-REA) - Hiawatha (AD-REA) 69kV	69
56	Manrap - Rapids 69kV	69
57	Brick Church - Lakehead Pipeline 69kV	69
58	Cornell Tap (UPPCO) - Watson Tap 69kV	69
59	Chandler - Cornell Tap (UPPCO) 69kV	69
60	Watson Tap - Forsyth 69kV	69
61	Oak St - Lost Dauphin 69kV	69
62	Sunset Point - Bowen St 69kV	69
63	Bowen St - Oshkosh 69kV	69
64	Pioneer Tap (WPS) - Sobieski Sw Str 69kV	69
65	Portage St Hy - 3 Mile 69kV	69
66	3 Mile - 9 Mile SW STA 69kV	69
67	Pine Grove Tap - 9 Mile SW STA 69kV	69
68	Magazine - 3 Mile 69kV	69
69	Pine Grove Tap - Pine Grove 69kV	69
70	3 Mile - Pine Grove Tap 69kV	69
71	Rockview SW STR - 6951 Tap (ESE) 69kV	69
72	Rockview SW STR - Rockview 69kV	69
73	Pine River - Rockview SW STR 69kV	69
74	Limeston - Mich Limestone Loading Dock 69kV	69
75	6951 Tap (ESE) - Limeston 69kV	69
76	Straits - St Ignace 69kV	69
77	Trout Lake Tap (ESE) - Trout Lake (ESE) 69kV	69
78	Rexton Tap - Rexton 69kV	69
79	9 Mile SW STA - Dafter 69kV	69
80	Van Buren St - Henry St Tap (WPS) 69kV	69
81	Henry St Tap (WPS) - Finger Rd SW STA 69kV	69
82	Henry St Tap (WPS) - Henry St (WPS) 69kV	69
83	Ryan St - Glenview 69kV	69
84	Lost Dauphin - Ryan St 69kV	69
85	MTU Tap - MTU 69kV	69
86	Atlantic - MTU Tap 69kV	69
87	MTU Tap - Henry St. (UPPCO) 69kV	69
88	Industrial - Canal 69kV	69
89	Sawyer SW STA - Industrial 69kV	69
90	Iron Grove - Strawberry Hill Tap 69kV	69
91	Strawberry Hill Tap - Lakehead Iron River 69kV	69
92	Iron Grove - Strawberry Hill 69kV	69
93	Shingleton Tap - Shingleton 69kV	69
94	Timber Products Tap - Timber Products 69kV	69
95	Algoma SW STR - Algoma 69kV	69
96	Beardsley St - East Krok 69kV	69

**ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied**

<b>Transmission Line Names</b>		<b>Line Voltage</b>
97	Algoma SW STR - Algoma South 69kV	69
98	Barnett - Algoma SW STR 69kV	69
99	Algoma - Algoma City 69kV	69
100	Booster SW STR - Beardsley St 69kV	69
101	Algoma - Canal 69kV	69
102	Luxemburg 24.9 - Booster SW STR 69kV	69
103	Beardsley St - Barnett 69kV	69
104	Booster SW STR - Booster 69kV	69
105	Finger Rd SW STA - Luxemburg 24.9 69kV	69
106	Fox Hills SW STA - Silver Cliff 69kV	69
107	Fox Hills SW STA - Goodman 69kV	69
108	Caldron Falls Hy - Fox Hills SW STA 69kV	69
109	South Broadway Tap - Liberty St Tap 69kV	69
110	Henry St Tap (WPS) - Danz Ave SW STA 69kV	69
111	Finger Rd SW STA - Henry St Tap (WPS) 69kV	69
112	Glenview - Brillion Iron Works 69kV	69
113	Perch Lake - Mich Transmitter Facility 69kV	69
114	Darlington - DPC LaMont 69kV	69
115	Jennings Rd SW STA - DPC Argyle 69kV	69
116	DPC Shullsburg Tap - DPC Shullsburg 69kV	69
117	Shoto - Columbus (WPS) 69kV	69
118	Dorset Corners SW STR - DPC Oakdale 69kV	69
119	Dorset Corners SW STR - Dorset Corners 69kV	69
120	DPC Kendall - Dorset Corners SW STR 69kV	69
121	Hillsboro - DPC Kendall 69kV	69
122	Council Creek - DPC Oakdale 69kV	69
123	Council Creek - DPC Monroe County 69kV	69
124	Humboldt Sw Str - Greenstone 69kV	69
125	North Lake - Humboldt Sw Str 69kV	69
126	Humboldt Sw Str - Humboldt Mine 69kV	69
127	North Lake - Barnum 69kV	69
128	New Holstein SW STA - St Nazianz 69kV	69
129	St Nazianz - Custer 69kV	69
130	Portage (UPPCO) - Atlantic 69kV	69
131	Ellinwood - Oshkosh 69kV	69
132	High Falls Hy - Caldron Falls Hy 69kV	69
133	Centennial Mine Tap - Keweenaw 69kV	69
134	Osceola - Centennial Mine Tap 69kV	69
135	K I Sawyer Tap - K I Sawyer 69kV	69
136	K I Sawyer Tap - Sawyer Lumber 69kV	69
137	Amberg - Daves Falls 69kV	69
138	Suamico - Sobieski Sw Str 69kV	69
139	Pulliam SW YD - Suamico 69kV	69
140	Sobieski Sw Str - Sobieski 69kV	69
141	Wells St Tap - Ogden St 69kV	69
142	Baraga VLG Tap - L'anse 69kV	69
143	L'anse - JH Warden 69kV	69
144	Baraga VLG Tap - Baraga Vlg 69kV	69

**ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied**

<b>Transmission Line Names</b>		<b>Line Voltage</b>
145	DPC Lyndon STA SW STR - DPC Lyndon Station 69kV	69
146	Katzenberg - Richmond Rd SW STR 69kV	69
147	Richmond Rd SW STR - Twin Lakes (ALTE) 69kV	69
148	Sunset Point - Winneconne 69kV	69
149	Hampden SW STR - Hampden 69kV	69
150	Sigel - Vesper Tap 69kV	69
151	Vesper Tap - Vesper 69kV	69
152	Vesper Tap - Pittsville 69kV	69
153	Darlington - Rock Branch 69kV	69
154	Columbus (ALTE) - Columbus Muni 1 69kV	69
155	Gays Mills SW STR - Gays Mills 69kV	69
156	Seneca SW STR - Seneca 69kV	69
157	Lancaster - Lancaster Distribution 69kV	69
158	Hickory St Tap 2 - Macy St Tap 69kV	69
159	North Fond Du Lac - Hickory St 69kV	69
160	Morris St North Tap 2 - Mercury Marine 69kV	69
161	Hillside - Brisbois 69kV	69
162	Oregon - Brooklyn 69kV	69
163	DPC Ocean Spray SW STR - DPC Ocean Spray 69kV	69
164	CWEC Scandinavia Tap - CWEC Scandinavia 69kV	69
165	Amherst Jct SW STR - Amherst Jct 69kV	69
166	Polar SW STR - Polar 69kV	69
167	Centennial Park SW STR - Centennial Park 69kV	69
168	Waunakee Ind Park SW STR - Waunakee Industrial Park 69kV	69
169	Division Street SW STR - Division Street 69kV	69
170	Juneau Muni SW STR - Juneau Northside Tap 69kV	69
171	Juneau Northside Tap - Juneau Downtown Tap 69kV	69
172	Juneau Downtown Tap - Juneau Industrial Tap 1 69kV	69
173	Juneau Industrial Tap 1 - Juneau Industrial 69kV	69
174	Juneau Northside Tap - Juneau Northside 69kV	69
175	Juneau Downtown Tap - Juneau Downtown 69kV	69
176	Token Creek Tap - Token Creek 69kV	69
177	Deforest - Token Creek Tap 69kV	69
178	Bird St Tap - Bird St 69kV	69
179	Bird St Tap - Sun Prairie 69kV	69
180	Ninth Street Tap - Ninth Street 69kV	69
181	Ninth Street Tap - Spruce Street 69kV	69
182	Milwaukee Valve Tap - Milwaukee Valve 69kV	69
183	Dam Heights - Dam Heights South Tap 69kV	69
184	Cross Plains - Stage Coach SW STA 69kV	69
185	Easy Street SW STR - Easy Street 69kV	69
186	Grand Marsh Tap - ACEC Brooks 69kV	69
187	Grand Marsh Tap - Grand Marsh 69kV	69
188	ACEC Brooks SW STR - Grand Marsh Tap 69kV	69
189	Lincoln Pump STA - ACEC Brooks SW STR 69kV	69
190	ACEC Brooks SW STR - Mckenna 69kV	69
191	East Rockton SW STR - East Rockton 69kV	69
192	Browntown - Jennings Rd SW STA 69kV	69

**ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied**

<b>Transmission Line Names</b>		<b>Line Voltage</b>
193	South Monroe - Browntown 69kV	69
194	Ripon - Ripon 2 SW STR 69kV	69
195	Ripon 2 SW STR - Ripon Ind Park 69kV	69
196	Merrimac SW STR - Merrimac 69kV	69
197	Caledonia SW STR - Caledonia (ALTE) 69kV	69
198	Eagle View Sw Str - Eagle View 69kV	69
199	Finnegan Tap - Finnegan 69kV	69
200	Finnegan Tap - Platt 69kV	69
201	Hubbard - Spring Brook 69kV	69
202	Montello Sw Str - ACEC Turtle Lake SW STR 69kV	69
203	ACEC Turtle Lake SW STR - Wautoma 69kV	69
204	ACEC Turtle Lake SW STR - ACEC Turtle Lake 69kV	69
205	Mount Horeb - East Lincoln St 69kV	69
206	ACEC Coloma Tap - ACEC Coloma 69kV	69
207	ACEC Wildrose SW STR - ACEC Wildrose 69kV	69
208	ACEC Wild Rose Pump SW STR - ACEC Wild Rose Pump 69kV	69
209	ACEC Wautoma SW STR - ACEC Wautoma 69kV	69
210	ACEC Doylestown SW STR - ACEC Doylestown 69kV	69
211	Fall River SW STR - Fall River 69kV	69
212	Union Center SW STR 2 - Wonewoc 69kV	69
213	Union Center SW STR 1 - Union Center SW STR 2 69kV	69
214	Union Center SW STR 2 - Union Center 69kV	69
215	Hillsboro Tap - Hillsboro 69kV	69
216	Dorset Corners SW STR - Dorset Corners 69kV	69
217	Kieler Tap - Kieler 69kV	69
218	DPC Dayton - Eagle Tap 69kV	69
219	Burke Tap - Burke 69kV	69
220	Columbus Muni #3 Tap - Maple Street 69kV	69
221	Alto SW STR - Alto 69kV	69
222	Mackford Prairie SW STR - Mackford Prairie 69kV	69
223	Markesan SW STR - Markesan 69kV	69
224	Mackford Prairie SW STR - Ripon 69kV	69
225	Markesan SW STR - Mackford Prairie SW STR 69kV	69
226	North Fond Du Lac - Sadoff Co Tap 69kV	69
227	Macy St Tap - Macy St 69kV	69
228	Sadoff Co Tap - Macy St Tap 69kV	69
229	Saratoga - ACEC Grant 69kV	69
230	Saratoga - ACEC Arrowhead SW STR 69kV	69
231	ACEC Cottonville Tap - ACEC Sherwood 69kV	69
232	ACEC Cottonville Tap - ACEC Cottonville 69kV	69
233	ACEC Arrowhead SW STR - ACEC Arrowhead 69kV	69
234	ACEC Arrowhead SW STR - ACEC Cottonville Tap 69kV	69
235	Monroe St Sw Str - Adams St Sw Str 1 69kV	69
236	Monroe St Sw Str - Monroe St 69kV	69
237	Bemis SW STR - Bemis 69kV	69
238	Reedsburg - Reedsburg Main 69kV	69
239	Reedsburg #6 Industrial Park - Artesian 69kV	69
240	Waupun Prison Tap - Waupun Prison 69kV	69

**ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied**

<b>Transmission Line Names</b>		<b>Line Voltage</b>
241	Com Tech Sw Str - Waupun Tap 69kV	69
242	Waupun Prison Tap - Waupun Southside SW STR 69kV	69
243	Waupun Westside SW STR - Waupun Prison Tap 69kV	69
244	Waupun Southside SW STR - Waupun Southside 69kV	69
245	Com Tech Sw Str - Com Tech 69kV	69
246	Waupun - Waupun Main 69kV	69
247	Waupun Southside SW STR - Com Tech Sw Str 69kV	69
248	North Mullet River - Plymouth Sub 2 69kV	69
249	32nd St Sw Str - 32nd St 69kV	69
250	Nicolet SW STR - 32nd St Sw Str 69kV	69
251	Scot Forge Tap 2 - Scot Forge 1 69kV	69
252	REC Clinton SW STR - REC Clinton 69kV	69
253	Scot Forge Tap 1 - Clinton (ALTE) 69kV	69
254	Scot Forge Tap 1 - Scot Forge Tap 2 69kV	69
255	Clinton SW STR (ALTE) - Scot Forge Tap 1 69kV	69
256	Sharon SW STR - Sharon 69kV	69
257	Enzyme Bio-Systems SW STR - Enzyme Bio-Systems 69kV	69
258	Spring Grove SW STR - Brodhead SW STA 69kV	69
259	Rock Branch - Dodgeville 69kV	69
260	Dodgeville - Hooterville 69kV	69
261	Janesville General SW YD - Badger Pump STA Tap 69kV	69
262	Badger Pump STA Tap - Badger Pump STA 69kV	69
263	Badger Pump STA Tap - Parker High School SW STR 69kV	69
264	Castle Rock - DPC Buckhorn SW STR 69kV	69
265	DPC Buckhorn SW STR - DPC Buckhorn 69kV	69
266	DPC Buckhorn SW STR - Hilltop (ALTE) 69kV	69
267	Belleville - Verona 69kV	69
268	New Glarus SW STR - New Glarus 69kV	69
269	Monticello SW STR - Monticello (ALTE) 69kV	69
270	New Glarus SW STR - Belleville 69kV	69
271	Caroline - Marion SW STR 69kV	69
272	CWEC Tigerton Tap - CWEC Tigerton 69kV	69
273	Marion SW STR - Marion 69kV	69
274	CWEC Tigerton Tap - Whitcomb 69kV	69
275	Marion SW STR - CWEC Tigerton Tap 69kV	69
276	Rudolph SW STR - Rudolph 69kV	69
277	Northern Steel Casting SW STR - Northern Steel Casting 69kV	69
278	ACEC Quincy Tap - ACEC Quincy 69kV	69
279	ACEC Richford SW STR - ACEC Richford 69kV	69
280	North Mullet River - Plymouth Muni 3 Tap 69kV	69

**ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied**

<b>Transmission Line Names</b>		<b>Line Voltage</b>
281	Northside (ALTE) Tap - Northside (sfm) (ALTE) 69kV	69
282	Plymouth Muni 3 Tap - Plymouth Sub 3 69kV	69
283	Zenda SW STR - Zenda 69kV	69
284	Artesian - Reedsburg 69kV	69
285	Reedsburg - Loganville 69kV	69
286	Northwest Beloit Tap - Northwest Beloit 69kV	69
287	Shirland Ave SW STR - Shirland Ave 69kV	69
288	Manawa SW STR - Harrison North 138kV 69kV	69
289	CWEC Iola Tap - CWEC Iola 69kV	69
290	Iola - CWEC Iola Tap 69kV	69
291	Manawa SW STR - Manawa 69kV	69
292	Beaver Dam 3rd St South SW STR - Beaver Dam 3rd St 69kV	69
293	Center St SW STR - Center St 69kV	69
294	Beaver Dam 3rd St North SW STR - Beaver Dam 3rd St 69kV	69
295	Mercury Marine Tap - Mercury Marine 69kV	69
296	Willow Lawn Tap - Willow Lawn 69kV	69
297	South Fond Du Lac SW YD - Willow Lawn Tap 69kV	69
298	Morris St North Tap 1 - Morris St 69kV	69
299	Morris St South Tap 1 - Morris St 69kV	69
300	Dana Corp SW STR - Dana Corp 69kV	69
301	DPC Platteville Tap - Pioneer(ALTE) 69kV	69
302	DPC Platteville Tap - DPC Platteville 69kV	69
303	Hillman - DPC Platteville Tap 69kV	69
304	Sheridan (ALTE) Sw Str - Harrison 69kV SW STR 69kV	69
305	Iola - Sheridan (ALTE) Sw Str 69kV	69
306	CWEC Rosholt Tap - Rosholt CWEC 69kV	69
307	Rosholt CWEC - Groenier 69kV	69
308	CWEC Rosholt Tap - Rosholt 69kV	69
309	Rosholt SW STR - CWEC Rosholt Tap 69kV	69
310	Colt Industrial SW STR - Colt Industries 69kV	69
311	Cranston SW STR - Cranston 69kV	69
312	REC Newark SW STR - REC Newark 69kV	69
313	DPC New Lisbon Tap - DPC New Lisbon 69kV	69
314	West Mauston Tap - Hilltop (ALTE) 69kV	69
315	Council Creek - Camp Douglas Tap 69kV	69
316	DPC New Lisbon Tap - West Mauston Tap 69kV	69
317	Camp Douglas Tap - DPC New Lisbon Tap 69kV	69
318	Camp Douglas Tap - Camp Douglas 69kV	69
319	Dam Heights North Tap - Dam Heights South Tap 69kV	69
320	Island Tap - Island 69kV	69
321	Island Tap - Kirkwood 69kV	69
322	Badger Ordinance Works Tap - Badger Ordinance Works 69kV	69
323	Badger Ordinance Works Tap - Baraboo 69kV	69
324	Moore St Tap - Island Tap 69kV	69
325	Dam Heights - Dam Heights North Tap 69kV	69
326	Moore St Tap - Moore St 69kV	69
327	Dam Heights North Tap - Badger Ordinance Works Tap 69kV	69
328	Baraboo - Moore St Tap 69kV	69

**ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied**

<b>Transmission Line Names</b>		<b>Line Voltage</b>
329	Ripon 1 Tap - Ripon 2 SW STR 69kV	69
330	High Falls Hy - Mountain 69kV	69
331	Milton Lawns Tap - Milton Lawns 69kV	69
332	Cottage Grove SW STR - Cottage Grove 69kV	69
333	Orfordville SW STR - Orfordville 69kV	69
334	Brodhead Muni 1 SW STR - Brodhead North 69kV	69
335	Orfordville SW STR - Bass Creek 69kV	69
336	Brodhead Muni 1 SW STR - REC Orfordville SW STR 69kV	69
337	Brodhead Muni 2 SW STR - Brodhead Tap 69kV	69
338	Brodhead Muni 3 SW STR - Brodhead Muni 2 SW STR 69kV	69
339	Brodhead Muni 2 SW STR - Brodhead Central 69kV	69
340	Brodhead Muni 3 SW STR - Brodhead South 69kV	69
341	Brodhead Tap - Brodhead 69kV	69
342	REC Orfordville SW STR - REC Orfordville 69kV	69
343	Brodhead SW STA - Brodhead Muni 3 SW STR 69kV	69
344	REC Orfordville SW STR - Orfordville SW STR 69kV	69
345	Brodhead Tap - Brodhead Muni 1 SW STR 69kV	69
346	Boscobel - Boscobel Muni 69kV	69
347	West Mauston Tap 2 - Mauston Tap 69kV	69
348	West Mauston Tap 2 - West Mauston Tap 69kV	69
349	West Mauston - West Mauston Tap 2 69kV	69
350	Mauston Tap - Mauston 69kV	69
351	Hillman - McGregor (ALTE) 69kV	69
352	Metomen - Brandon Tap 69kV	69
353	Berlin - Fox River 69kV	69
354	Port Edwards - Georgia Pacific 69kV	69
355	Canal - Sawyer SW STA 69kV	69
356	Nicolet Paper Co - Oak St 69kV	69
357	Highway V - Nicolet Paper Co 69kV	69
358	ACEC Coloma Tap - Chaffee Creek	69



**ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied**

<b>Transmission Line Names</b>		<b>Line Voltage</b>
359	Winneconne - Sunset Point	69