

ATC's Transformers that will not have ratings based on overhead conductors and therefore will not have SBRM applied on June 1, 2013

	Transformer Names	Voltage
1	Academy T31	138-69
2	Amberg T6	138-69
3	Arcadian T2 LV	345-138
4	Arcadian T3 LV	345-138
5	Arcadian T2 HV	345-138
6	Arcadian T1	345-138
7	Arcadian T3 HV	345-138
8	Arnott T31	138-69
9	Arpin T31	138-115
10	Arpin T21	345-138
11	Arrowhead 345/230 kV 8TR	230-230
12	Arrowhead 345/230 kV 9TR	345-230
13	Artesian T31	138-69
14	Artesian T32	138-69
15	Aspen TG1	138-69
16	Aurora St T3	115-69
17	Badger T1	138-115
18	Bain T4	345-138
19	Bain T5	345-138
20	Bass Creek T31	138-69
21	Blackhawk SW YD (ALTE) T33	138-69
22	Blount T4	138-69
23	Bluemound T2	230-138
24	Brick Church T31	138-69
25	Canal T2	138-69
26	Cardinal T2	345-138
27	Cardinal T1	345-138
28	Caroline T61	115-69
29	Chalk Hill Hy TG8	138-69
30	Chandler TG4	138-69
31	Chandler TG7	138-69
32	Columbia SW YD (ALTE) T23	345-138
33	Columbia SW YD (ALTE) T21	345-138
34	Columbia SW YD (ALTE) T31	138-69
35	Council Creek T31	138-69
36	Crivitz T3	138-69
37	Crivitz T1	138-69
38	Cross Country T33	138-69
39	Darlington T31	138-69
40	Dead River (WE) T1	345-138
41	Dead River (WE) T1A	345-138
42	Dunn Rd TG1	138-69
43	Eden T31	138-69
44	Edgewater SW YD T32	138-69
45	Edgewater SW YD T22	345-138
46	Edgewater SW YD T31	138-69
47	Ellinwood T1	138-69
48	Ellinwood T2	138-69
49	Elm Road 345 Sws Yd T895	345-230
50	Erdman T31	138-69

ATC's Transformers that will not have ratings based on overhead conductors and therefore will not have SBRM applied on June 1, 2013

	Transformer Names	Voltage
51	Escanaba Steam Plant #900	69-12.5
52	Femrite 138/69 kV T31	138-69
53	Fitchburg T4	138-69
54	Fitchburg T3	138-69
55	Fitzgerald T1	345-138
56	Forest Junction T2	345-138
57	Forest Junction T1	345-138
58	Forsyth T1	138-69
59	Glenview T2	138-69
60	Glenview T1	138-69
61	Gran Grae T91	161-69
62	Granville T3	345-138
63	Granville T1 HV	345-138
64	Hiawatha (ESE) T1	138-69
65	Hiawatha (ESE) T3	138-69
66	Highway V T1	138-69
67	Highway V T2	138-69
68	Hillman T31	138-69
69	Hubbard T31	138-69
70	Indian Lake T2	138-69
71	Indian Lake T1	138-69
72	Iron Grove TG1	138-69
73	Janesville General SW YD T32	138-69
74	Kewaunee SW YD T10	345-138
75	Kilbourn T32	138-69
76	Kirkwood T32	138-69
77	Lakota Rd TG2	138-69
78	Lakota Rd TG1	138-115
79	Lancaster T31	138-69
80	Lone Rock T42	69-69
81	Lost Dauphin T1	138-69
82	McCue T31	138-69
83	Menominee TG1	138-69
84	Metomen T31	138-69
85	Morgan T1	345-138
86	Mullet River T31	138-69
87	Munising T1	138-69
88	Nelson Dewey SW YD T32	138-69
89	Nelson Dewey SW YD T31	138-69
90	Nelson Dewey SW YD T91	161-138
91	Nordic T8	138-69
92	North Appleton T3	345-138
93	North Appleton T1	345-138
94	North Fond Du Lac T31	138-69
95	North Fond Du Lac T34	138-69
96	North Lake TG2	138-69
97	North Lake TG6	138-69
98	North Lake Geneva T31	138-69
99	North Madison T31	138-69
100	North Madison 345/138 kV T22	345-138

ATC's Transformers that will not have ratings based on overhead conductors and therefore will not have SBRM applied on June 1, 2013

Transformer Names		Voltage
101	North Madison 345/138 kV T21	345-138
102	North Randolph T31	138-69
103	North Randolph T32	138-69
104	Oak Creek SW YD T851	230-138
105	Oak Creek SW YD T88	345-138
106	Oak Creek SW YD T884	345-230
107	Ontonagon T1	138-69
108	Paddock T31	138-69
109	Perch Lake T31	138-69
110	Petenwell T31	138-69
111	Plains T1	345-138
112	Port Edwards T32	138-69
113	Port Edwards T31	138-69
114	Portage T32	138-69
115	Pulliam SW YD T16	138-69
116	Racine T2	345-138
117	Racine T1	345-138
118	Reiner Rd T31	138-69
119	Rock River T32	138-69
120	Rockdale T21	345-138
121	Rocky Run T1	345-115
122	Rocky Run T2	345-115
123	Rocky Run T4	345-115
124	Roosevelt T3	138-69
125	Russell T31	138-69
126	Sand Lake T31	138-69
127	Saratoga T32	138-69
128	Saratoga T33	138-69
129	Saukville T1	345-138
130	Shoto T2	138-69
131	Shoto T1	138-69
132	Sigel T31	138-69
133	South Fond Du Lac SW YD T21	345-138
134	South Fond Du Lac SW YD T32	138-69
135	South Fond Du Lac SW YD T22	345-138
136	South Fond Du Lac SW YD T31	138-69
137	South Sheboygan Falls T31	138-69
138	Stone Lake T9	345-161
139	Straits TG2	138-69
140	Straits TG1	138-69
141	Sunset Point T2	138-69
142	Sunset Point T1	138-69
143	Sycamore SW YD T4	138-69
144	Sycamore SW YD T3	138-69
145	Tecumseh Rd T1	138-69
146	Verona T31	138-69
147	Wautoma T31	138-69
148	Werner West TL1	345-138
149	West Marinette SW YD T1	138-69
150	West Marinette SW YD T2	138-69

ATC's Transformers that will not have ratings based on overhead conductors and therefore will not have SBRM applied on June 1, 2013

Transformer Names		Voltage
151	West Middleton T4	138-69
152	West Middleton T3	138-69
153	West Side ESC2	69-12.5
154	Whitcomb T31	115-69
155	Winona T1	138-69