



***System Impact Study Report
PID 217 Generation
42 MW Plant
Gulfway 230kV Substation***

***Prepared by:
Southwest Power Pool, Independent Coordinator of
Transmission (SPP ICT)
415 North McKinley, Suite 140
Little Rock, AR 72205***

Revision: 1

Rev	Issue Date	Description of Revision	Revised By	Project Manager
0	8/15/2008	Draft for Review	BEF	JDH
1	8/20/2008	Final	BEF	JDH

Objective:

This System Impact Study is the second step of the interconnection process and is based on PID-217 request for interconnection on Entergy's transmission system near the Atlantic Bulk substation. This report is organized in two sections, namely, Section – A, Energy Resource Interconnection Service (ERIS) and when requested, Section – B, Network Resource Interconnection Service (NRIS – Section B).

Scope for the ERIS section (Section – A) includes load flow (steady state) analysis, transient stability analysis and short circuit analysis as defined in FERC orders 2003, 2003A and 2003B. If applicable, the NRIS section (Section – B) contains details of load flow (steady state) analysis only, however, transient stability analysis and short circuit analysis of Section – A are also applicable to Section – B. Additional information on scope for NRIS study would be found in Section – B.

Requestor for PID-217 did request ERIS, however it was determined that a load flow (steady state) analysis was not required because the generator would not be exporting power.

To accommodate this in plant co-generation project PID-217 intends to construct a new switchyard, named Gulfway, configured with a five breaker ring bus and will include facilities for two 230kV interconnections with Total's new 230/69kV substation (Substation AA); 230kV Transmission line L-499 (VFW Park to Hanks) will be cut in/out to the new station; and a third 230kV line will be installed between Sabine to the new Gulfway substation.

The proposed in-service date for this facility is October 1, 2009

TABLE OF CONTENTS FOR ERS

I.	INTRODUCTION.....	1
II.	SHORT CIRCUIT ANALYSIS/ BREAKER RATING ANALYSIS	2
A.	MODEL INFORMATION	2
B.	SHORT CIRCUIT ANALYSIS.....	2
C.	ANALYSIS RESULTS	2
D.	PROBLEM RESOLUTION.....	3
III.	TRANSIENT STABILITY ANALYSIS	4
A.	TRANSIENT STABILITY ANALYSIS METHODOLOGY.....	3
B.	MODEL INFORMATION	4
C.	TRANSIENT STABILITY ANALYSIS.....	8
D.	ANALYSIS RESULTS	11
APPENDIX A.A	DATA SUPPLIED BY CUSTOMER	17
APPENDIX A.B	Substation Configuration For The Adjacent Substations Under Stuck Breaker Fault Conditions.....	39
APPENDIX A.C	Stability Issues in the Western Region of the Entergy System Due To Independent Power Generation	47
APPENDIX A.D	POLICY STATEMENT / GUIDELINES FOR POWER SYSTEM STABILIZER ON THE ENTERGY SYSTEM.....	50
APPENDIX A.E	TRANSIENT STABILITY DATA AND PLOTS	52

I. Introduction

This Energy Resource Interconnection Service (ERIS) is based on PID-217 (42 MW) request for interconnection on Entergy's transmission system near the Atlantic Bulk substation. The objective of this study is to assess the reliability impact of the new facility on the Entergy transmission system with respect to the steady state and transient stability performance of the system as well as its effects on the system's existing short circuit current capability. It is also intended to determine whether the transmission system meets standards established by NERC Reliability Standards and Entergy's planning criteria and guidelines when the plant is connected to Entergy's transmission system. If not, transmission improvements will be identified.

A short circuit analysis is performed to determine whether the generation would cause the available fault current to surpass the fault duty of existing equipment within the Entergy transmission system. A transient stability analysis was conducted to determine whether the new units would cause a stability problem on the Entergy system.

This ERIS System Impact Study was based on information provided by PID-217 and assumptions made by Southwest Power Pool, Independent Coordinator of Transmission (SPP ICT). All supplied information and assumptions are documented in this report. If the actual equipment installed is different from the supplied information or the assumptions made, the results outlined in this report are subject to change.

Any load flow results from the ERIS study are for information only. ERIS does not in and of itself convey any transmission service.

II. Short Circuit Analysis/ Breaker Rating Analysis

A. Model Information

The short circuit analysis was performed on the Entergy system short circuit model using ASPEN software. This model includes all generators interconnected to the Entergy system or interconnected to an adjacent system and having an impact on this interconnection request, IPP's with signed IOAs, and approved future transmission projects on the Entergy transmission system including the proposed PID-217 unit.

B. Short Circuit Analysis

The method used to determine if any short circuit problems would be caused by the addition of the PID-217 generation is as follows:

1. Three phase and single phase to ground faults were simulated on the Entergy base case short circuit model and the worst case short circuit level was determined at each station. The PID-217 generator was then modeled in the base case to generate a revised short circuit model. The base case short circuit results were then compared with the results from the revised model to identify any breakers that were under-rated as a result of additional short circuit contribution from PID-217 generation. The breakers identified to be upgraded through this comparison are *mandatory* upgrades.

C. Analysis Results

The results of the short circuit analysis, including priors PID's 206,207,208,210,211,213,215 and 216 indicates that the additional generation due to PID-217 generators does cause an increase in short circuit current such that they exceed the fault interrupting capability of the high voltage circuit breakers within the vicinity of the proposed generation. Also, when studied with no

generation interconnection queue priors in service, there were breakers identified as being underrated due to the added fault current from the PID-217 generator.

Table I illustrates the station name, worst case fault level, and the number of breakers that were found to be under-rated at the respective locations as a result of the additional short circuit current due to PID-217 generator and includes no priors.

Table I: Underrated Breakers Without Priors

Substation	Breaker	Max Fault w/o PID-217 (amps)	Max Fault with PID-217 (amps)	Interrupting Rating (amps)
SABINE 230kV Bus# 334434	13180-C	49099.0	50547.4	50204.4
	13185-C	49099.0	50547.4	50204.4
	13190-C	49099.0	50547.4	50204.4
	13195-C	49099.0	50547.4	50204.4
	13200-C	49099.0	50547.4	50204.4
	13255-C	49099.0	50547.4	50204.4
	13265-C	49099.0	50547.4	50204.4

D. Problem Resolution

Table II illustrates the station name, and the cost associated with upgrading the breakers at each station both for mandatory and optional breaker upgrades with Priors and without Priors.

Table II: Breaker Upgrade Costs without Priors

<u>Substation</u>	<u>Number of Breakers</u>	<u>Estimated cost of Breaker Upgrades (\$)</u>
SABINE 230kV	7	*\$2,342,900

* Price based on 245kV breaker with 63kA interrupt rating.

The impact on breaker rating due to line upgrades will be evaluated during facilities study phase.

The results of the short circuit analysis are subject to change. They are based upon the current configuration of the Entergy transmission system and Generation Interconnection Study queue.

III. Transient Stability Analysis

A. Transient Stability Analysis Methodology

Using Planning Standards approved by NERC, the following stability definition was applied in the Transient Stability Analysis:

“Power system stability is defined as that condition in which the differences of the angular positions of synchronous machine rotors become constant following an aperiodic system disturbance.”

Stability analysis was performed using Siemens-PTI's PSS/ETM dynamics program V29.4.0. Three-phase (3PH) normally cleared and three-phase stuck breaker faults were simulated for the specified durations and the synchronous machine rotor angles were monitored to make sure they maintained synchronism following the fault removal. Stability of asynchronous machines was monitored as well.

The stability analysis was performed using the PSS/E dynamics program, which only simulates the positive sequence network. Unbalanced faults involve the positive, negative, and zero sequence networks. For unbalanced faults, the equivalent fault admittance must be inserted in the PSS/E positive sequence model between the faulted bus and ground to simulate the effect of the negative and zero sequence networks. For a single-line-to-ground (SLG) fault, the fault admittance equals the inverse of the sum of the positive, negative and zero sequence Thevenin impedances at the faulted bus. Since PSS/E inherently models the positive sequence fault impedance, the sum of the negative and zero sequence Thevenin impedances needs to be added and entered as the fault impedance at the faulted bus.

The single-line-to-ground (SLG) fault impedance was computed to give a positive sequence voltage at the fault location of approximately 60% of pre-fault voltage, which is a typical value.

For three-phase faults, a fault admittance of $-j2E9$ is used (essentially infinite admittance or zero impedance).

B. Model Information

When the Transient Stability Analysis for PID-217 was performed the most realistic model available for the Entergy system was 2015 summer peak load conditions. Beyond the year 2015, the models will involve a number of uncertain projects and upgrades. Hence, the dynamic database representing 2015 summer peak load conditions was used in this analysis. The analysis was carried out on the power flow case without the upgrades identified for PID-217 in either the Power Flow or Short-Circuit analysis. The reason for not including the upgrades identified in the Power Flow and Short Circuit analysis was, if the system was stable without the required upgrades the system performance would only improve with the upgrades. Figure 1V-1 shows the current configuration of the new Gulfway Switching Station (SS). Figure 1V-2 illustrates the changes implemented to the 2015 power flow case to connect the two 230/69kV transformers, the 69/13.8 transformer and the generator into the new Gulfway SS.




Figure 1V-1: Transmission configuration at Gulfway 230kV without PID-217.




Figure 1V-2: Transmission line configuration at Gulfway 230 kV with PID-217.

The new PID-217 generation (existing generation being moved from Entergy's 69kV system and added to the 230kV system) was added to the model via a new 230/69kV interconnection at the New Gulfway S.E.S 230 kV bus. The new Gulfway Switching Station (SS) was added to the model 3.95 miles from Kolbs/Hanks SS and 1.75 miles from VFW Park SS. A line was then added to the model from the new Gulfway SS to Sabine (7 miles). Refer to Figure V1-3 for System Area Study diagram. The stability studies were conducted to assess the impact of PID-217 injecting 42 MW of power into Entergy's system. The loads in the Entergy system were represented as follows: for the active part, 100% was modeled with a constant current model; all of the reactive part was modeled with a constant impedance model.

PID-217 provided dynamic models of their generation equipment for use in this study. The generators were modeled using the standard PSS/E **GENROU** model.

PID-217 also provided data for the excitation system. The data for the PID-217 gas turbine excitation system was modeled using the PSS/E **ESST4B** model. PID-217 provided the data for the turbine-governor controls. The gas turbine generator governor model was modeled using the PSS/E **GGOV1** model. The data used for the proposed PID-217 generator, exciter, and governor models are shown in **Appendix A.A.**

SYSTEM STUDY AREA




Figure IV-3: System Study Area

C. Transient Stability Analysis

Stability simulations were run to examine the transient behavior of the PID-217 generator and their effect on the Entergy system. Stability analysis was performed using the following procedure. Three-phase faults with normal clearing time and three-phase delayed times were simulated on the transmission lines connected to the Gulfway 230kV switching station. The stability analysis was performed using the PSS/E dynamics program. The fault clearing times used for the simulations are given in Table IV-1.

Table IV-1 Fault Clearing Times

Contingency at kV level	Normal Clearing	Delayed Clearing
230	6 cycles	6+9 cycles

The breaker failure scenarios were simulated with the following sequence of events:

- 1) At the normal clearing time for the primary breakers, the faulted line is tripped at the far end from the fault by normal breaker opening.
- 2) The fault remains in place for three-phase stuck-breakers. For single-phase faults the fault is appropriately adjusted to account for the line trip of step 1.
- 3) The fault is then cleared by back-up clearing. If the system is shown to be unstable for this condition, then stability of the system without the PID-217 plant needs to be verified.

All line trips are assumed to be permanent (i.e. no high speed re-closure).

The stability analysis was performed using the PSS/E dynamics program, which only simulates the positive sequence network. Unbalanced faults involve the positive, negative, and zero sequence networks. For unbalanced faults, the equivalent fault admittance must be inserted in the PSS/E positive sequence model between the faulted bus and ground to simulate the effect of the negative and zero sequence networks. For a single-line-to-ground (SLG) fault, the fault admittance equals the inverse of the sum of the positive, negative and zero sequence Thevenin impedances at

the faulted bus. Since PSS/E inherently models the positive sequence fault impedance, the sum of the negative and zero sequence Thevenin impedances needs to be added and entered as the fault impedance at the faulted bus.

For three-phase faults, a fault admittance of $-j2E9$ is used (essentially infinite admittance or zero impedance).

Table IV-2A and Table IV-2B list all the fault cases that were simulated in this study. Fault scenarios were formulated by examining the system configuration shown in Figure IV-3. The substation configurations for the adjacent substations with the fault locations are included in the Appendix A.C for reference.

Faults 1 through 5 of Table IV-2A represent the normal clearing 3-phase faults. Faults 1 through 7 of Table IV-2B represent faults with stuck breakers with the appropriate delayed back-up clearing times.

For all cases analyzed, the initial disturbance was applied at $t = 0.1$ seconds. The breaker clearing was applied at the appropriate time following this fault inception.

Table IV-2A Fault Cases Simulated in this Study: 3 Phase Faults with Normal Clearing

FAULT REF. NO.	CASE	Prior Outage Element	LOCATION	TYPE	Clearing Time (cy)	PRIMARY BRK TRIP #	TRIPPED FACILITIES	Stable?	Acceptable Voltages?
1	FAULT-SABINE	--	GULFWAY	3 PH	6	GEVF12 / VFW12	GULFWAY - SABINE	Yes	Yes
2	FAULT-VFWPARK	--	GULFWAY	3 PH	6	VFW12 / VFW34	GULFWAY - VFW PARK	Yes	Yes
3	FAULT-KOLBS	--	GULFWAY	3 PH	6	KOL12 / KOL34	GULFWAY - KOLBS	Yes	Yes
4	FAULT-GENR1	--	GULFWAY GENR1	3 PH	6	KOL12 / GEVF12	GULFWAY GENR1	Yes	Yes
5	FAULT-GENR2	--	GULFWAY GENR2	3 PH	6	KOL34 / VFW34	GULFWAY GENR2	Yes	Yes

Table V1-2B Fault Cases Simulated in this Study: 3 Phase Faults with Stuck Breaker Conditions

REF. NO.	CASE	LOCATION	TYPE	CLEARING TIME (cycles)		STUCK BRK #	PRIMARY (Normal) BRK TRIP #	SECONDARY BRK (Backup) TRIP	TRIPPED FACILITIES	Stable?	Acceptable Voltages?
				PRIMARY	Back-up						
1	FAULT-SABINE_SB	GULFWAY	3PH	6	9	VFW12	GEVF12	VFW34	GULFWAY - SABINE / GULFWAY - VFW PARK	Yes	Yes
2	FAULT-VFWPARK_SB	GULFWAY	3PH	6	9	VFW12	VFW34	GEVF12	GULFWAY - VFW PARK GULFWAY - SABINE	Yes	Yes
3	FAULT-KOLBS_SB	GULFWAY	3PH	6	9	KOL12	KOL34	GEVF12	GULFWAY - KOLBS	Yes	Yes
4	FAULT-KOLBS2_SB	GULFWAY	3PH	6	9	KOL34	KOL12	VFW34	GULFWAY - KOLBS	Yes	Yes
5	FAULT-GENR1_SB	GULFWAY GENR1	3PH	6	9	KOL12	GEVF12	KOL34	GULFWAY GENR1 GULFWAY - KOLBS	Yes	Yes
6	FAULT-GENR1_SB2	GULFWAY GENR1	3PH	6	9	GEVF12	KOL12	VFW12	GULFWAY GENR1 GULFWAY - SABINE	Yes	Yes
7	FAULT-GENR2_SB	GULFWAY GENR2	3PH	6	9	VFW34	KOL34	VFW12	GULFWAY GENR2 GULFWAY - VFW PARKS	Yes	Yes

IV. Analysis Results

All of the three-phase faults with stuck breaker conditions were stable. Even though none of these were unstable, three-phase faults with normal clearing were simulated as well, for completeness. All of the three-phase faults with normal clearing were stable as well. The plots are provided in Appendix A.B.

In addition to criteria for the stability of the machines, Entergy has evaluation criteria for the transient voltage dip as follows:

- 3-phase fault or single-line-ground fault with normal clearing resulting in the loss of a single component (generator, transmission, circuit, or transformer) or a loss of a single component without fault:

Not to exceed 20% for more than 20 cycles at any bus

Not to exceed 25% at any load bus

Not to exceed 30% at any non-load bus

- 3-phase faults with normal clearing resulting in the loss of two or more components (generator, transmission circuit or transformer), and SLG fault with delayed clearing resulting in the loss of one or more components:

Not to exceed 20% for more than 40 cycles at any bus

Not to exceed 30% at any bus

The duration of the transient voltage dip excludes the duration of the fault. The transient voltage dip criteria will not be applied to single-phase faults followed by stuck breaker conditions unless the determined impact is extremely widespread.

The voltages at all buses in the Entergy system (138 kV and above) were monitored during each of the fault cases as appropriate. No voltage violations were observed for normally cleared three-phase faults.

Hence, it can be concluded that the proposed PID-217 unit does not degrade the Entergy system performance.


The plots for voltages, frequency and machine angles in the local area following Fault 1 of Table V1-2B are shown in Figure IV-4 through Figure IV-6. Plots of relevant parameters (machine angles, frequencies, and bus voltages) are shown in Appendix A.B.



GW
 GW-SABINE, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-SABINE, STUCK BRKR CONDS (VFW12)

FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out

1.2000	CHNL# 11: [VOLT 334431 [G1SABIN 20.000]]	0.20000
1.2000	CHNL# 9: [VOLT 334441 [G5SABIN 24.000]]	0.20000
1.2000	CHNL# 7: [VOLT 334440 [G4SABIN 24.000]]	0.20000
1.2000	CHNL# 5: [VOLT 334036 [PID 217 13.800]]	0.20000
1.2000	CHNL# 3: [VOLT 334035 [GULFWAYA 69.000]]	0.20000
1.2000	CHNL# 1: [VOLT 334034 [GULFWAY 230.000]]	0.20000



THU, JUL 31 2008 15:31
 PG 1: VOLTAGE

Figure IV-4: Local area voltages following Fault-1 Table IV-2B with PID-217



GW
GW-SABINE, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-SABINE, STUCK BRKR CONDS (VFW12)

FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out

61.000	CHNL# 31: CFREQ 334431 CG1SABIN 20.000]]*60+60	59.000
61.000	CHNL# 30: CFREQ 334441 CG5SABIN 24.000]]*60+60	59.000
61.000	CHNL# 29: CFREQ 334440 CG4SABIN 24.000]]*60+60	59.000
61.000	CHNL# 28: CFREQ 334036 CPID 217 13.800]]*60+60	59.000
61.000	CHNL# 27: CFREQ 334035 CGULFWAYA 69.000]]*60+60	59.000
61.000	CHNL# 26: CFREQ 334034 CGULFWAY 230.00]]*60+60	59.000





Figure IV-5: Local area frequency following Fault-1 Table IV-2B with PID-217



GW
GW-SABINE, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-SABINE, STUCK BRKR CONDS (VFW12)

FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out

250.00	CHNL# 12: CANGL 334431 CG1SABIN	20.000]]	0.0
250.00	CHNL# 10: CANGL 334441 CG5SABIN	24.000]]	0.0
250.00	CHNL# 8: CANGL 334440 CG4SABIN	24.000]]	0.0
250.00	CHNL# 6: CANGL 334036 CPID 217	13.800]]	0.0
250.00	CHNL# 4: CANGL 334035 CGULFWAYA	69.000]]	0.0
250.00	CHNL# 2: CANGL 334034 CGULFWAY	230.000]]	0.0



THU, JUL 31 2008 15:31
PG 7: ANGLE

Figure IV-6: Local area angles following Fault-1 Table IV-2B with PID-217

In summary, when considering the new PID-217 (42 MW) generation at the Gulfway S.E.S. 230 kV bus, all the simulated faults are stable. No violations of the voltage dip criteria were observed. This meets Entergy's performance criteria when the PID-217 plant is in-service.

APPENDIX A-A DATA PROVIDED BY CUSTOMER

A.A.1 LARGE GENERATING FACILITY DATA

APPENDIX 1 to LGIP INTERCONNECTION REQUEST FOR A LARGE GENERATING FACILITY

1. The undersigned Interconnection Customer submits this request to interconnect its Large Generating Facility with Transmission Provider's Transmission System pursuant to a Tariff.
2. This Interconnection Request is for (check one):
 A proposed new Large Generating Facility. (Existing, but will be removed from Entergy's 69 kV system and added to the 230 kV system.)
 An increase in the generating capacity or a Material Modification of an existing Generating Facility.
3. The type of interconnection service requested (check one):
 Energy Resource Interconnection Service (no export)
 Network Resource Interconnection Service
4. Check here only if Interconnection Customer requesting Network Resource Interconnection Service also seeks to have its Generating Facility studied for Energy Resource Interconnection Service
5. Interconnection Customer provides the following information:
 - a. Location: **ENTERGEN, 11000 RIVER ROAD, TOTTEN, VT 05461**
 - b. Maximum summer net output: **42,400 kW**
Maximum winter net output: **42,400 kW**
 - c. General description of the equipment configuration: **Frame 6B, GE Turbine. No exportation of energy. (See one line diagram)**
 - d. Commercial Operation Date (Day, Month, and Year): **10/2009**
 - e. Name, address, telephone number, and e-mail address of Interconnection Customer's contact person;

- f. Approximate location of the proposed Point of Interconnection (optional):
 - g. Interconnection Customer Data (set forth in Attachment A)
6. Applicable deposit amount as specified in the LGIP: **\$50,000.00**
7. Evidence of Site Control as specified in the LGIP (check one)
 Is attached to this Interconnection Request: "Attachment I Evidence of Site Control.pdf"
 Will be provided at a later date in accordance with this LGIP
8. This Interconnection Request shall be submitted to the representative indicated below:

[To be completed by Transmission Provider]
9. Representative of Interconnection Customer to contact:

**Attachment A to Appendix I
Interconnection Request**

LARGE GENERATING FACILITY DATA

UNIT RATINGS

kVA 44,180 *max. Cold Air Temp.* Voltage 13,800
 Power Factor 0.90 °F 104 (40°C)
 Speed (RPM) 3,600 Connection (e.g. Wye) Wye

Short Circuit Ratio _____ Frequency, Hertz 60
 Stator Amperes at Rated kVA 351 Field Volts 250
 Max Turbine MW 42,240 °F 69

COMBINED TURBINE-GENERATOR-EXCITER INERTIA DATA

Inertia Constant, H = 6.6 kW sec/kVA
 Moment-of-Inertia, WR² = 96,801 lb. ft.²

REACTANCE DATA (PER UNIT-RATED KVA)

	DIRECT AXIS	QUADRATURE AXIS
Synchronous – saturated	X _{dv} <u>2.025</u>	X _{qv} <u>1.917</u>
Synchronous – unsaturated	X _{di} <u>2.025</u>	X _{qi} <u>1.917</u>
Transient – saturated	X' _{dv} <u>0.187</u>	X' _{qv} _____
Transient – unsaturated	X' _{di} <u>0.261</u>	X' _{qi} _____
Subtransient – saturated	X'' _{dv} <u>0.115</u>	X'' _{qv} <u>0.112</u>
Subtransient – unsaturated	X'' _{di} <u>0.169</u>	X'' _{qi} <u>0.167</u>
Negative Sequence – saturated	X _{2v} <u>0.108</u>	
Negative Sequence – unsaturated	X _{2i} <u>0.159</u>	X' _q <u>0.430</u>
Zero Sequence – saturated	X _{0v} <u>0.072</u>	
Zero Sequence – unsaturated	X _{0i} <u>0.087</u>	
Leakage Reactance	X _{lm} _____	

X_{lm}, OEX 0.138

X_{lm}, UEX 0.138

FIELD TIME CONSTANT DATA (SEC)

Open Circuit	T'_{do}	<u>5.513</u>	T'_{qo}	<u>0.454</u>
Three-Phase Short Circuit Transient	T'_{d3}	<u>0.509</u>	T'_q	<u>0.454</u>
Line to Line Short Circuit Transient	T'_{d2}	<u>0.764</u>		
Line to Neutral Short Circuit Transient	T'_{d1}	<u>0.919</u>		
Short Circuit Subtransient	T''_d	<u>0.015</u>	T''_q	<u>0.015</u>
Open Circuit Subtransient	T''_{do}	<u>12.024</u>	T''_{qo}	<u>0.058</u>

ARMATURE TIME CONSTANT DATA (SEC)

Three Phase Short Circuit	T_{a3}	<u>0.126</u>
Line to Line Short Circuit	T_{a2}	<u>0.126</u>
Line to Neutral Short Circuit	T_{a1}	<u>0.112</u>

NOTE: If requested information is not applicable, indicate by marking "N/A."

**MW CAPABILITY AND PLANT CONFIGURATION
LARGE GENERATING FACILITY DATA**

ARMATURE WINDING RESISTANCE DATA (PER UNIT)

Positive	R_1	<u>0.005</u>
Negative	R_2	<u>0.017</u>
Zero	R_0	<u>0.009</u>

Rotor Short Time Thermal Capacity $I_2^2 t =$ 30
 Field Current at Rated kVA, Armature Voltage and PF = 351.4 amps
 Field Current at Rated kVA and Armature Voltage, 0 PF = 428.6 amps
 Three Phase Armature Winding Capacitance = 0.400 microfarad
 Field Winding Resistance = 0.637 ohms 125 °C
 Armature Winding Resistance (Per Phase) = 0.00486 ohms 100 °C

CURVES

Provide Saturation, Vee, Reactive Capability, Capacity Temperature Correction curves. Designate normal and emergency Hydrogen Pressure operating range for multiple curves.

GENERATOR STEP-UP TRANSFORMER DATA RATINGS

Capacity Self-cooled/
Maximum Nameplate
40,000 / 53,330 kVA @ 55°C

Voltage Ratio(Generator Side/System side/Tertiary)
13.8 / 69 / N/A kV

Winding Connections (Low V/High V/Tertiary V (Delta or Wye))
Wye / Delta / N/A

Fixed Taps Available
Yes = 2 x 2 1/2 %

Present Tap Setting
0% (Nominal)

IMPEDANCE

Positive Z_1 (on self-cooled kVA rating) _____ % _____ X/R

Zero Z_0 (on self-cooled kVA rating) _____ % _____ X/R

$$Z = 8.29\% @ 4,000 \text{ kVA}$$

$$\pm \text{Seq } Z \quad R = 0.2959 \quad X = 8.2847$$

$$X/R = 28.0$$

DESIGN NO. D205T26

GENERATOR DATA

CUSTOMER: Fina Oil
GENERATOR NO. 335X470 FIELD NO. 335X470 D.L. NO. 335X470

NAMEPLATE DATA

2 Poles, 3 Phase, Wye Connected, 60 Hertz, 3600 RPM

Total Temp. at Rating Guaranteed not to Exceed: 130 C on Armature by Detector
145 C on Field by Resistance
Maximum Cold Gas/Air Temperature 40 C.

	<u>Rating</u>
KVA (0 Ft.)	<u>44,180</u>
Armature Amps	<u>1,848</u>
Armature Volts	<u>13,800</u>
Field Amps	<u>351</u>
Exciter Volts	<u>250</u>
Power Factor.	<u>0.90</u>

DESIGN DATA

Voltage Range at 60 Hertz ± 5 Percent

COLLECTOR AND BRUSH DATA

Collector Brushes, 14 Per Set Recommended Grade, National Carbon 634
Collector Minimum Safe Operating Diameter 12.5 inches
Shaft Grounding Brushes, 2 Per Set Recommended Grade, National Carbon 634

GAS COOLER DATA

Inlet Water Temperature	<u>95</u> F.
Water Flow at Rated Load	<u>1104</u> GPM
Head Loss Through Cooler.	<u>13.5</u> Ft.
Gas Flow Through Generator	<u>35,754</u> CFM
Gas Space in Generator.	<u>752</u> Cu.Ft.

GEN. NO. 335X470

ESTIMATED GENERATOR DATA

<u>REACTANCE DATA: (PER UNIT)</u>	<u>DIRECT AXIS</u>	<u>QUADRATURE AXIS</u>
Saturated Synchronous	(X _{dv}) <u>2.025</u>	(X _{qv}) <u>1.917</u>
Unsaturated Synchronous	(X _{di}) <u>2.025</u>	(X _{qi}) <u>1.917</u>
Saturated Transient	(X' _{dv}) <u>0.187</u>	(X' _q) <u>0.430</u>
Unsaturated Transient	(X' _{di}) <u>0.261</u>	
Saturated Subtransient.	(X'' _{dv}) <u>0.115</u>	(X'' _{qv}) <u>0.112</u>
Unsaturated Subtransient.	(X'' _{di}) <u>0.169</u>	(X'' _{qi}) <u>0.167</u>
Saturated Negative Sequence	(X _{2v}) <u>0.108</u>	
Unsaturated Negative Sequence	(X _{2i}) <u>0.159</u>	
Saturated Zero Sequence	(X _{0v}) <u>0.072</u>	
Unsaturated Zero Sequence	(X _{0i}) <u>0.089</u>	
Leakage Reactance	(X _{LM,OEX}) <u>0.138</u>	
Leakage Reactance	(X _{LM,UEX}) <u>0.138</u>	

<u>FIELD TIME CONSTANT DATA: (Sec. at 125 C)</u>		
Open Circuit.	(T' _{do}) <u>5.513</u>	(T' _{qo}) <u>0.454</u>
Three Phase Short Circuit Transient	(T' _{d3}) <u>0.509</u>	(T' _q) <u>0.454</u>
Line to Line Short Circuit Transient.	(T' _{d2}) <u>0.764</u>	
Line to Neutral Short Circuit Transient (T' _{d1})	<u>0.919</u>	
Short Circuit Subtransient.	(T'' _d) <u>0.015</u>	(T'' _q) <u>0.015</u>
Open Circuit Subtransient	(T'' _{do}) <u>0.024</u>	(T'' _{qo}) <u>0.058</u>

ARMATURE DC COMPONENT TIME CONSTANT DATA - (Sec. AT 100C)


Three Phase Short Circuit	(T _{a3}) <u>0.126</u>
Line to Line Short Circuit	(T _{a2}) <u>0.126</u>
Line to Neutral Short Circuit	(T _{a1}) <u>0.112</u>

ARMATURE WINDING SEQUENCE RESISTANCE DATA - (Per Unit)

Positive	(R ₁) <u>0.005</u>
Negative	(R ₂) <u>0.017</u>
Zero	(R ₀) <u>0.009</u>


Rotor Short Time Thermal Capacity, (I₂)²T = 30
 Three Phase Armature Winding Capacitance = 0.400 Microfarads
 Armature Winding DC Resistance (Per Phase) = 0.00986 Ohms at 100C
 Field Winding DC Resistance = 0.637 Ohms at 125C
 Field Current at Rated KVA, Armature Voltage and PF = 351.4 Amps
 Field Current at Rated KVA and Armature Voltage, 0 PF Lagging
 (FOR SYSTEMS STUDY ONLY - NOT ALLOWABLE OPERATING POINT). = 428.6 Amps

ESTIMATED SATURATION AND SYNCHRONOUS IMPEDANCE CURVES
 44180 KVA - 3600 RPM - 13800 VOLTS - 0.90 PF
 250 FLD VOLTS - 40 C COLD AIR - 0 FT ALT




ESTIMATED REACTIVE CAPABILITY CURVES

44180 KVA - 3600 RPM - 13800 VOLTS - 0.90 PF
 250 FLD VOLTS - 40 C COLD AIR - 0 FT ALT



ESTIMATED EXCITATION V CURVES

44180 KVA - 3600 RPM - 13800 VOLTS - 0.90 PF
250 FLD VOLTS - 40 C COLD AIR - 0 FT ALT



GENERAL ELECTRIC GENERATOR



MODEL GENERATOR NO. 358K470
 2 POLES 3 PHASE WYE CONN. 60 HERTZ
 TOTAL TEMPERATURE AT RATING
 GUARANTEED NOT TO EXCEED:
 55° C. ON ARMATURE BY DETECTOR
 55° C. ON FIELD BY RESISTANCE
 WINDING CASE AIR TEMPERATURE 40° C.
 INLET WATER 35° F.
 KVA: 1000
 ARMATURE AMPS: 1000
 ARMATURE VOLTS: 2300
 FIELD AMPS: 100
 EXCITATION VOLTS: 100
 POWER FACTOR: 0.85
 EFF: 90%

ALL OTHERS BEFORE INSTALLING, OPERATING OR DISMANTLING, READ INSTRUCTIONS

MADE IN MASSACHUSETTS MADE IN U.S.A.

GENERAL  ELECTRIC

329A7642

REV. NO.	TITLE	COPIES ON SHEET	F	EN. NO.	1
329A7642	NAMEPLATE DATA				
COPIES ON SHEET	F	EN. NO.	1	FIRST MADE FOR	GAS TURBINE
					A004

© GENERAL  ELECTRIC ©
GAS TURBINE DIVISION

NO: (A) AIR IN: 69° F ALT: SEA LEVEL
BASE: 38,360 KW PEAK: 42,240 KW FUEL: NATURAL GAS
TURBINE EXHAUST BASE: 1011° F PEAK: 1072° F PRESS: 14 IN H2O
CPRSR: STAGES 17 RPM 5100 CPRSR TURBINE: STAGES
POWER TURBINE: STAGES 3 RPM 5100

CAUTION! BEFORE INSTALLING, OPERATING, OR DISMANTLING - READ GEN 96004

© SCHENECTADY, N.Y. - GREENVILLE, S.C. ©
N.P. 169487

Note: Make from N.P. 169487. Data to be engraved or etched and filled with black baking enamel. Letter size and style shall be per nameplate drawing. Do not engrave or etch encircled letter. Data as identified above must be located in approximate center of allotted space.

BT - GAO - OC - WPT - OC - LI
MI - SG - SR - OS - ROP - B
SP - G - SC - SE - OS

NAMEPLATE UNIT RATING			
UNIT NO.	TURBINE NO.	RT. NO.	TURBINE NO.
1	295357	(A)	(A)


MADE BY <i>Qu. ticks Oct 23, 81</i>	APPROVALS <i>124</i>	GAS TURBINE GREENVILLE, S.C.	329A7642
October 26, 1987			COPIES ON SHEET F EN. NO. 1

Worksheet - EX2000 Bus Fed Excitation System				
IEEE ST4B Model Format	input	output	4/2/2007 9:02	HCS
AFSI	596.0			0
AFNL	302			
Rfd (125C) - ohms	0.1341			
Rfd (100C) - ohms		0.1248		
airgapMMF	24692			
totalMMF	27175			
N/FT/P		90.00		
IFAG	274.4	274.4		
VFAG100 = IFAG*RFG100		34.2		
IFFL	857.0			
VFFL125=AFFL*RFG125		115		
EDV=1.025*VFFL125		118		
VFFL100=IFFL*RFG100		106.9		
IM current margin	1.15		cold day	
EDA=IM*IFFL		985.55	needs	951
VCF ceiling factor	2.14		PG&E Grid Code	1.5 pu@70%
VC1=VFC*VFFL100		228.834	minimum	
VC3=7*VFNL125	0	0	not applied	
Transformer (PPT)				
IPPT=EDA*0.78	780	768.729	minimum fundamental	
VPPT=VC1/1.25	185	183.067	minimum	
PPT KVA=sqrt(3)*V*I/1000	250	243.75	minimum	
VC2=VPPT*1.25		231.25	actual	
Impedance %	6.00%		typical	
XT (ohms -sec)		0.0082		
KC = 1.654 *XT/RFG100		0.1089	revised 3-3-99	
Kp = Vsec*1.35/VFAG		7.29		
VBmax = 125% Kp		9.12		
Vceiling(pu)= Kp - KC*I _{fd} (FL)*0.577		7.10	revised 3-12-99	
Vceiling (volts) (xVFAG)		243		
Desired Transient Gain, Ktr	20		standard	
KPR = Ktr/Kp		2.74		
VPS, pole slip voltage	1500		unknown	
PRV1=(VPS+1.05*sqrt(2)*VPPT)/0.85		2087.9	W/out PRV resistors	
PRV2=0.75*PRV1		1565.9	with PRV resistors	
RR=(VC2/VFFL100-1)*3.8		4.42		

Customer				
unit				
Generator				
Design	D215P19	6A6 OV		
MVA Rating	54		KV Rating	13.8
RPM	3600		PF	0.85
SCR	0.48			
Volts DC	125		RFG at 100 C	0.1248
AFAG amps	274		AFFL amps	857

EX2000 Busfed Exciter Model Parameters

IEEE ST4B Model Format	Exciter Nominal Response at rated input		
TR	0	KC	4.4
KPR	2.74	KIR	0.11
VRMAX	1.00	KIR	2.74
TA	0.01	VRMIN	-0.87
KPM	1.00	KG	0
VMMAX	1.00	KIM	0
KP	7.29	VMIMIN	-0.87
VBMAX	9.12	KI	0
		XL	0



"Computer Models for Representation of Digital-Based Excitation Systems",
 IEEE Trans. EC, Vol. 11, No. 3, September 1996, pp 607-615.

Harold C. Sanderson

4/2/2007 9:02

GE Excitation/Controls Engineering
 ex2000/

.xls

GE PSLF **ggov1** governor/turbine model parameters for 6B Gas Turbine Units.


Parameter	Value ¹
MWCAP	41.67
r	0.04
rselect	1
T _{pelcc} (sec)	1.0
Max _{ERR} (pu)	0.05
Min _{ERR} (pu)	-0.05
K _{PGOV}	10.0
K _{IGOV}	2.0
K _{DGOV}	0.0
T _{DGOV} (sec)	1.0
V _{MAX}	1.0
V _{MIN}	0.15
T _{ACT} (sec)	0.5
K _{TURB}	1.5
W _{FNL}	0.2
T _B (sec)	0.1
T _C (sec)	0.0
flag	1.0
T _{ENG} (sec)	0.0
T _{FLOAD} (sec)	3.0
K _{PLOAD}	2.0
K _{ILOAD}	0.67

¹ Except for MWCAP the values for the model parameters are typical and reasonable for grid studies. Validation of values by testing is recommended.

GE PSLF ggov1 governor/turbine model parameters for 6B Gas Turbine Units

Parameter	Value
L _{DREF}	1.0 ²
D _M	0.0
R _{OPEN} (pu/sec)	0.10
R _{CLOSE} (pu/sec)	-0.1
K _{IMW}	0.0
P _{MWSET} (pu)	N/A
A _{SET} (pu)	0.01
K _A (pu)	10.0
T _A (sec)	0.1
db (pu)	0.0
T _{SA} (sec)	4.0
T _{SB} (sec)	5.0
R _{UP} (pu)	99.0
R _{DOWN} (pu)	-99.0
T _{LLN} (sec)	0.0
T _{LLD} (sec)	0.0

² Value for ldref will vary for changes of ambient temperature. A value of 1.0 is valid for 59°F, 14.7psia.



Note: The Kpgov/Kdgv and Kload/Kload controllers includes tracking logic to ensure smooth transfer between active controllers. This logic is not shown.

Block Diagram for ggov1 Governor/Turbine Model

Westinghouse



THREE PHASE 60 HERTZ TYPE XL TRANSFORMER CLASS B-1/F INSULATION	WIRING	55' E. AIR. RISE	65' S. AIR. RISE
	69000 GRD. Y / 39425 VOLTS 13800 VOLTS	40000/23333 KVA	44800/29333 KVA
	L-1112 MNL.5380-10 SERIAL NO. 101.5300-104	SERIAL	

ALLIANCE OIL TANK, TANK


POLE RATE IMPULSE TEST LEVEL: HV-NOS 350 KV, LV-NOS 110 KV, HV NEUTRAL 110 KV, HV NEUTRAL BUSHING 110 KV.

IMPEDANCE 8.77% AT 40000 KVA 69000 GRD Y - 13800 VOLTS


APPROX. WEIGHT IN LBS. OF EACH COIL

MADE IN USA WESTINGHOUSE ELECTRIC CORPORATION MNL.5380-10 SUB A

DO NOT ATTEMPT TO REPAIR, INSTALL, USE OR SERVICE THIS TRANSFORMER BEFORE READING INSTRUCTIONS FROM MANUFACTURER'S LITERATURE TO PREVENT LOSS TO INDUSTRY THROUGH IMPROPER INSTALLATION OR USE.



WINDING	VOLTAGE	APPROX. WT. LBS.	NO. OF TAPS	NO. OF CONTACTS IN EACH PHASE
H.V.	13800	275.0	3	18
H.V.	11000	275.0	3	18
H.V.	8700	275.0	3	18
L.V.	4000	499.6	3	36
L.V.	3300	499.6	3	36
L.V.	2640	499.6	3	36
L.V.	1980	499.6	3	36
L.V.	1320	499.6	3	36
L.V.	660	499.6	3	36
L.V.	330	499.6	3	36
L.V.	165	499.6	3	36
L.V.	82.5	499.6	3	36
L.V.	41.25	499.6	3	36
L.V.	20.625	499.6	3	36
L.V.	10.3125	499.6	3	36
L.V.	5.15625	499.6	3	36
L.V.	2.578125	499.6	3	36
L.V.	1.2890625	499.6	3	36
L.V.	0.64453125	499.6	3	36
L.V.	0.322265625	499.6	3	36
L.V.	0.1611328125	499.6	3	36
L.V.	0.08056640625	499.6	3	36
L.V.	0.040283203125	499.6	3	36
L.V.	0.0201416015625	499.6	3	36
L.V.	0.01007080078125	499.6	3	36
L.V.	0.005035400390625	499.6	3	36
L.V.	0.0025177001953125	499.6	3	36
L.V.	0.00125885009765625	499.6	3	36
L.V.	0.000629425048828125	499.6	3	36
L.V.	0.0003147125244140625	499.6	3	36
L.V.	0.00015735626220703125	499.6	3	36
L.V.	0.000078678131103515625	499.6	3	36
L.V.	0.0000393390655517578125	499.6	3	36
L.V.	0.00001966953277587890625	499.6	3	36
L.V.	0.000009834766387939453125	499.6	3	36
L.V.	0.0000049173831939697265625	499.6	3	36
L.V.	0.00000245869159698486328125	499.6	3	36
L.V.	0.000001229345798492431640625	499.6	3	36
L.V.	0.0000006146728992462158203125	499.6	3	36
L.V.	0.0000003073364496231091141015625	499.6	3	36
L.V.	0.00000015366822481155454555578125	499.6	3	36
L.V.	0.000000076834112405777272777890625	499.6	3	36
L.V.	0.0000000384170562028886363889453125	499.6	3	36
L.V.	0.00000001920852810144431819447265625	499.6	3	36
L.V.	0.000000009604264050722159097236328125	499.6	3	36
L.V.	0.0000000048021320253610795486181640625	499.6	3	36
L.V.	0.00000000240106601268053977430808203125	499.6	3	36
L.V.	0.000000001200533006340269887154041015625	499.6	3	36
L.V.	0.0000000006002665031701349435770205078125	499.6	3	36
L.V.	0.00000000030013325158506747178851025390625	499.6	3	36
L.V.	0.0000000001500666257925337358942551269765625	499.6	3	36
L.V.	0.00000000007503331289626686794712756323828125	499.6	3	36
L.V.	0.000000000037516656448133433973563781619140625	499.6	3	36
L.V.	0.00000000001875832822406671698678189075953125	499.6	3	36
L.V.	0.00000000000937916411203335849339394545469765625	499.6	3	36
L.V.	0.000000000004689582056016679246697222723828125	499.6	3	36
L.V.	0.00000000000234479102800833962334861113619140625	499.6	3	36
L.V.	0.000000000001172395514004169811674305555578125	499.6	3	36
L.V.	0.0000000000005861977570020849058371527777890625	499.6	3	36
L.V.	0.00000000000029309887850104245291763889453125	499.6	3	36
L.V.	0.000000000000146549439252121226458819447265625	499.6	3	36
L.V.	0.0000000000000732747196260606132294097236328125	499.6	3	36
L.V.	0.0000000000000366373598130303064588119075953125	499.6	3	36
L.V.	0.0000000000000183186799065151532294097236328125	499.6	3	36
L.V.	0.000000000000009159339953257576614712756323828125	499.6	3	36
L.V.	0.0000000000000045796699766287883073563781619140625	499.6	3	36
L.V.	0.000000000000002289834988314394153678189075953125	499.6	3	36
L.V.	0.000000000000001144917494157197076839447265625	499.6	3	36
L.V.	0.00000000000000057245874707859853819447265625	499.6	3	36
L.V.	0.000000000000000286229373539299269097236328125	499.6	3	36
L.V.	0.000000000000000143114686769649634545469765625	499.6	3	36
L.V.	0.00000000000000007155734338482481727277890625	499.6	3	36
L.V.	0.0000000000000000357786716924124086363889453125	499.6	3	36
L.V.	0.00000000000000001788933584620620431819447265625	499.6	3	36
L.V.	0.00000000000000000894466792310310219075953125	499.6	3	36
L.V.	0.00000000000000000447233396151510113619140625	499.6	3	36
L.V.	0.00000000000000000223616698075755056839447265625	499.6	3	36
L.V.	0.0000000000000000011180834903787752819447265625	499.6	3	36
L.V.	0.00000000000000000055904174518938764097236328125	499.6	3	36
L.V.	0.000000000000000000279520872594693820486119075953125	499.6	3	36
L.V.	0.00000000000000000013976043629734691024430555578125	499.6	3	36
L.V.	0.000000000000000000069880218148673456233486119075953125	499.6	3	36
L.V.	0.000000000000000000034940109074336728119075953125	499.6	3	36
L.V.	0.0000000000000000000174700545371683640595378125	499.6	3	36
L.V.	0.00000000000000000000873502726858420297890625	499.6	3	36
L.V.	0.000000000000000000004367513634292101489453125	499.6	3	36
L.V.	0.0000000000000000000021837568171464507447265625	499.6	3	36
L.V.	0.000000000000000000001091878408573225371819447265625	499.6	3	36
L.V.	0.0000000000000000000005459392042866126839447265625	499.6	3	36
L.V.	0.000000000000000000000272969602143306319447265625	499.6	3	36
L.V.	0.0000000000000000000001364848010716531597236328125	499.6	3	36
L.V.	0.00000000000000000000006824240053582657986119075953125	499.6	3	36
L.V.	0.000000000000000000000034121200267913289447265625	499.6	3	36
L.V.	0.0000000000000000000000170606001339566447265625	499.6	3	36
L.V.	0.000000000000000000000008530300066977371819447265625	499.6	3	36
L.V.	0.0000000000000000000000042651500334886839447265625	499.6	3	36
L.V.	0.00000000000000000000000213257500167443447265625	499.6	3	36
L.V.	0.0000000000000000000000010662875000837217236328125	499.6	3	36
L.V.	0.00000000000000000000000053314375000418609140625	499.6	3	36
L.V.	0.000000000000000000000000266571875000209304555578125	499.6	3	36
L.V.	0.00000000000000000000000013328593750001046522777890625	499.6	3	36
L.V.	0.000000000000000000000000066642968750005232613889453125	499.6	3	36
L.V.	0.00000000000000000000000003332148437500026163069447265625	499.6	3	36
L.V.	0.0000000000000000000000000166607421875001308153347265625	499.6	3	36
L.V.	0.00000000000000000000000000833037109375006540766736328125	499.6	3	36
L.V.	0.0000000000000000000000000041651855468750032703831619140625	499.6	3	36
L.V.	0.0000000000000000000000000020825927734375163519165953125	499.6	3	36
L.V.	0.000000000000000000000000001041296386718758175957986119075953125	499.6	3	36
L.V.	0.0000000000000000000000000005206481933593754087986119075953125	499.6	3	36
L.V.	0.00000000000000000000000000026032409667968752043986119075953125	499.6	3	36
L.V.	0.000000000000000000000000000130162048339843751021986119075953125	499.6	3	36
L.V.	0.000000000000000000000000000065081024169921875510986119075953125	499.6	3	36
L.V.	0.0000000000000000000000000000325405120849609375255486119075953125	499.6	3	36
L.V.	0.000000000000000000000000000016270256042480468751277430555578125	499.6	3	36
L.V.	0.00000000000000000000000000000813512802124023437563869447265625	499.6	3	36
L.V.	0.0000000000000000000000000000040675640106201171869447265625	499.6	3	36
L.V.	0.0000000000000000000000000000020337820053100585937236328125	499.6	3	36
L.V.	0.00000000000000000000000000000101689100265502929688119075953125	499.6	3	36
L.V.	0.000000000000000000000000000000508445501327514648447265625	499.6	3	36
L.V.	0.00000000000000000000000000000025422275066375732421819447265625	499.6	3	36
L.V.	0.00000000000000000000000000000012711137533187866209140625	499.6	3	36
L.V.	0.00000000000000000000000000000006355568766593933104555578125	499.6	3	36
L.V.	0.000000000000000000000000000000031777843832969665522777890625	499.6	3	36
L.V.	0.000000000000000000000000000000015888921916484832763889453125	499.6	3	36
L.V.	0.0000000000000000000000000000000079444609582424163819447265625	499.6	3	36
L.V.	0.00000000000000000000000000000000397223047912208169447265625	499.6	3	36
L.V.	0.0000000000000000000000000000000019861153956110404097236328125	499.6	3	36
L.V.	0.0000000000000000000000000000000009930576978052020486119075953125	499.6	3	36
L.V.	0.00000000000000000000000000000000049652884890260102430555578125	499.6	3	36
L.V.	0.00000000000000000000000000000000024826442445130051222777890625	499.6	3	36
L.V.	0.000000000000000000000000000000000124132212222565026113889453125	499.6	3	36
L.V.	0.000000000000000000000000000000000062066106112825253059447265625	499.6	3	36
L.V.	0.0000000000000000000000000000000000310330			



REFINERY OVERALL DISTRIBUTION DIAGRAM

Current

REFERENCE DRAWINGS

NOTES

1. SEE DRAWING NO. 750-440 FOR ELECTRICAL SYMBOLS.
2. SEE DRAWING NO. 750-440 FOR ELECTRICAL SYMBOLS.
3. SEE DRAWING NO. 750-440 FOR ELECTRICAL SYMBOLS.
4. SEE DRAWING NO. 750-440 FOR ELECTRICAL SYMBOLS.
5. SEE DRAWING NO. 750-440 FOR ELECTRICAL SYMBOLS.
6. SEE DRAWING NO. 750-440 FOR ELECTRICAL SYMBOLS.
7. SEE DRAWING NO. 750-440 FOR ELECTRICAL SYMBOLS.
8. SEE DRAWING NO. 750-440 FOR ELECTRICAL SYMBOLS.
9. SEE DRAWING NO. 750-440 FOR ELECTRICAL SYMBOLS.
10. SEE DRAWING NO. 750-440 FOR ELECTRICAL SYMBOLS.




TOTAL PETROCHEMICALS

OVERALL DISTRIBUTION DIAGRAM

NO.	DESCRIPTION	DATE	BY	CHKD.
1	ISSUED FOR CONSTRUCTION	09/27/2007
2
3
4
5
6
7
8
9
10

REFERENCE DRAWINGS



Proposed

NOTES

- 1. SEE REFERENCE DRAWINGS FOR DETAILS OF EQUIPMENT.
- 2. ALL EQUIPMENT TO BE SUPPLIED BY THE CONTRACTOR.
- 3. ALL WORK TO BE IN ACCORDANCE WITH THE IEC STANDARDS.
- 4. ALL WORK TO BE COMPLETED WITHIN THE SPECIFIED TIME FRAME.
- 5. ALL WORK TO BE SUBJECT TO THE APPROVAL OF THE PROJECT MANAGER.

NO.	DESCRIPTION	DATE
1	ISSUED FOR TENDER	15/01/2007
2	ISSUED FOR TENDER	15/01/2007
3	ISSUED FOR TENDER	15/01/2007
4	ISSUED FOR TENDER	15/01/2007
5	ISSUED FOR TENDER	15/01/2007
6	ISSUED FOR TENDER	15/01/2007
7	ISSUED FOR TENDER	15/01/2007
8	ISSUED FOR TENDER	15/01/2007
9	ISSUED FOR TENDER	15/01/2007
10	ISSUED FOR TENDER	15/01/2007

TOTAL PETROCHEMICALS
REFINERY OVERALL DISTRIBUTION DIAGRAM
 SHEET NO. 7951-410

A.A.2 DATA USED IN STABILITY MODEL

Load Flow Models

The **PID-217** plant equipment data are listed in Appendix A.A. No other elements were added to the Entergy system.

Stability Models

The **PID-217** plant equipment stability model data are listed in Appendix A.A. The resulting PSS/E model data is as follows:

Load Flow data in Stability Models


```
334034,'GULFWAY ',230.0000,1, 0.000, 0.000, 351, 109,1.00006,-19.6604, 1
334035,'GULFWAY A ', 69.0000, 1, 0.000, 0.000, 351, 109,1.00004,-19.6604, 1
334036,'PID 217 ', 13.8000, 2, 0.000, 0.000, 351, 109, 1.00000,-19.6604, 1
334034,'GULFWAY ',230.0000,1, 0.000, 0.000, 351, 109,1.00086,109.7619, 1
334434,'6SABINE ',230.0000,1, 0.000, 0.000, 351, 105,1.01000,110.4304, 1
0 / END OF BUS DATA, BEGIN LOAD DATA
0 / END OF LOAD DATA, BEGIN GENERATOR DATA
334036,'1 ', -0.361, -40.198, 9999.000,-9999.000,1.00000, 0, 100.000, 0.00000, 1.00000, 0.00000, 0.00000,1.00000,1,
100.0, 42.000, 0.000, 1,1.0000
0 / END OF GENERATOR DATA, BEGIN BRANCH DATA
334034,-334434,'1 ', 0.00140, 0.01040, 0.02080, 685.00, 685.00, 0.00, 0.00000, 0.00000, 0.00000, 0.00000,1, 0.00,
1,1.0000
0 / END OF BRANCH DATA, BEGIN TRANSFORMER DATA
334034,334035, 0,'1','1,1,1, 0.00000, 0.00000,2,' ',1, 1,1.0000
0.00000, 0.00010, 100.00
1.00000, 0.000, 0.000, 0.00, 0.00, 0.00, 0, 0, 1.10000,0.90000,1.10000,0.90000, 33,0,0.00000,0.00000
1.00000, 0.000
334034,334035, 0,'2','1,1,1, 0.00000, 0.00000,2,' ',1, 1,1.0000
0.00000, 0.00010, 100.00
1.00000, 0.000, 0.000, 0.00, 0.00, 0.00, 0, 0, 1.10000,0.90000,1.10000,0.90000, 33,0,0.00000,0.00000
1.00000, 0.000
334035,334036, 0,'1','1,1,1, 0.00000, 0.00000,2,' ',1, 1,1.0000
0.00000, 0.00010, 100.00
1.00000, 0.000, 0.000, 0.00, 0.00, 0.00, 0, 0, 1.10000,0.90000,1.10000,0.90000, 33,0,0.00000,0.00000
1.00000, 0.000
0 / END OF TRANSFORMER DATA, BEGIN AREA DATA
351,337653, 1361.200, 10.000,'EES '
0 / END OF AREA DATA, BEGIN TWO-TERMINAL DC DATA
0 / END OF TWO-TERMINAL DC DATA, BEGIN VSC DC LINE DATA
0 / END OF VSC DC LINE DATA, BEGIN SWITCHED SHUNT DATA
0 / END OF SWITCHED SHUNT DATA, BEGIN IMPEDANCE CORRECTION DATA
0 / END OF IMPEDANCE CORRECTION DATA, BEGIN MULTI-TERMINAL DC DATA
0 / END OF MULTI-TERMINAL DC DATA, BEGIN MULTI-SECTION LINE DATA
0 / END OF MULTI-SECTION LINE DATA, BEGIN ZONE DATA
109,'GSTPTA '
0 / END OF ZONE DATA, BEGIN INTER-AREA TRANSFER DATA
0 / END OF INTER-AREA TRANSFER DATA, BEGIN OWNER DATA
1,'CENT HUD '
0 / END OF OWNER DATA, BEGIN FACTS DEVICE DATA
0 / END OF FACTS DEVICE DATA
```

Dynamics Data in Stability Models


334036 'GENROU' 1	5.513	0.024	0.454	0.058	
	6.6	0.0	2.025	1.917	0.261
	0.43	0.169	0.15	0.05	0.3
					/ GN1_PID217 13.8 \ EMC_04June08
334036 'GGOV1'	1	1	0	0.04	1.0
	0.05	-0.05	10.0	2.0	0.0
	1.0	1.0	0.15	0.5	1.5
	0.2	0.1	0.00	0.0	3.0
	2.0	0.67	1.0	0.0	0.10
	-0.1	0.0	0.01	10.0	0.1
	41.67	0.0	4.0	5.0	99.0
	-99.0				
					/ GN1_PID217 13.8 \ EMC_04June08
334036 'ESST4B'	1	0.0	2.74	2.74	1.0
	-0.87	0.01	1.00	0.0	1.0
	-0.87	0.0	7.29	0.0	9.12
	0.11	0.0	0.0		
					/ GN1_PID217 13.8 \ EMC_04June08

APPENDIX A-B SUBSTATION CONFIGURATION FOR THE ADJACENT SUBSTATIONS UNDER STUCK BREAKER FAULT CONDITIONS


**Fault 1: Fault on the Gulfway-Sabine 230kV
Stuck Circuit Breaker (CB) VFW12 with VFW34 Last to Open**




Fault 2: Fault on the Gulfway-VFWPark 230kV Stuck Circuit Breaker (CB) VFW12 with GEV12 Last to Open




Fault 3: Fault on the Gulfway-Kolbs 230kV Stuck Circuit Breaker (CB) KOL12 with GEV12 Last to Open




Fault 4: Fault on the Gulfway-Kolbs 230kV Stuck Circuit Breaker (CB) KOL34 with VFW34 Last to Open




Fault 5: Fault on the Gulfway-Genr1 230/69kV Stuck Circuit Breaker (CB) KOL12 with KOL34 Last to Open



Fault 6: Fault on the Gulfway-Genr1 230/69kV Stuck Circuit Breaker (CB) GEF12 with VFW12 Last to Open



**Fault 7: Fault on the Gulfway-Genr2 230/69kV
Stuck Circuit Breaker (CB) VFW34 with VFW12 Last to Open**



APPENDIX A-C Stability Issues in the Western Region of the Entergy System Due to Independent Power Generation

Introduction

The WOTAB (West of the Atchafalaya Basin) Area is defined as Entergy's systems in Southwestern Louisiana, and Southeastern Texas. The WOTAB area is a major load center for the Entergy System. The load to generation ratio requires a significant amount of power to be imported into the WOTAB area. However, because of the influx of new generating projects proposed for the area, it is likely that by the year 2003 this area may turn into a significant exporter of power. There have been a significant number of requests for interconnection studies to evaluate the potential interconnection of new generating facilities in the WOTAB area. It is anticipated that by 2003 there may be approximately 4000 – 6000 MW of new merchant generation within the WOTAB area.

Entergy's transmission system was planned, designed and built to serve approximately 5000 – 6000 MW of native and network loads in the WOTAB area. The addition of a significant amount of merchant generation will result in the export of power out of the WOTAB area. A high level of export power has the potential to create major problems, such as voltage and dynamic stability. The main objective of this study is to establish an estimated power export limit for the WOTAB area based on stability criteria.

Signing an interconnection agreement provides the generator the right to interconnection to the transmission system, but does not provide it any right to move its power onto or over the transmission system. The right to use the transmission system to transmit power can only be obtained by submitting a transmission request for service pursuant to Entergy's FERC-approved transmission tariff. Solutions to stability problems to increase export limits, such as construction of 500 kV line, have very long lead-times and tend to be very expensive.

Entergy believes that it is important to post this study publicly on its OASIS site so that entities that have already executed interconnection agreements, as well as entities that are proposing to site new generation within the WOTAB area, can incorporate this information into their decision-making process.

Analysis

In order to establish stability limits from the WOTAB area, all merchant generating that have signed an interconnection agreement were dispatched at their maximum capability along with the native generation in the area. In order to accommodate this export and simulate a worst case scenario, generation was reduced in the northern part of the Entergy System.

In this analysis the export limits were determined without the addition of any Power System Stabilizers (PSSs). However, sensitivity studies were conducted to determine the impact of stabilizers. If voltage stability limits were found to be lower than the dynamic stability limits, they were captured in this analysis.

One important assumption made in this study was to ignore thermal limitations. Thermal issues will be addressed as part of Transmission Service Request as they are based on source to sink information and generation dispatch within the WOTAB area.

The two cases analyzed in this study are as follows:

1. Base case with no merchant generation
2. Base case with merchant generation

Voltage stability analysis was performed for the pre-contingency condition and contingencies on four critical lines: Hartburg-Mt. Olive 500 kV, Richard-Webre 500 kV, Nelson-Richard 500 kV, and Grimes-Crockett 345 kV lines. As part of the voltage stability analysis, PV curves were developed in order to determine the maximum power that can be exported from the WOTAB area without experiencing voltage decline or voltage collapse. Entergy's guideline on voltage decline states that voltage at any station should not fall below 0.92 pu of nominal system voltage on single contingency.

Transient stability analysis was performed by applying a 3 phase to ground fault on the lines mentioned earlier. The fault clearing time was assumed to be 5 cycles for 500 kV and 345 kV lines and 6 cycles for the 230 kV lines. The transient stability plots show the machine angle as a function of time and indicate whether machine is stable and well damped, transiently unstable or dynamically unstable. A three percent damping criteria was used to screen the damping problem.

Results

Case 1 – Base Case with no Merchant Generation

No voltage stability problems were identified in this case. The transient stability plots in Figures 1 and 2 for a three-phase fault on the Hartburg – Mt.Olive 500 kV and Richard – Webre 500 kV lines show that the machines are stable and well damped.

Case 2 – Base case with Merchant Generation

A. Voltage Stability Analysis

The voltage stability plot or PV Curve for this case is shown in Figure 3. The X-axis of this plot is the power export level from the WOTAB area corresponding to the pre-contingency condition and the contingency of the four critical lines described earlier. The Y-axis represents the voltage at the Cane River 115 kV bus in the North Louisiana area. This station is representative of the voltage collapse occurring in that area. From the PV plot it can be observed that the most limiting contingency from the point of view of export from the area is the Hartburg – Mt. Olive 500 kV line. Based on the voltage decline guideline, the export limit from the area on the contingency of Hartburg-Mt. Olive line is 2100 MW. Figure 3 also shows that voltage collapse will eventually occur at about 3300 MW.

B. Transient/Dynamic Stability Analysis

The transient stability simulations were performed with the assumption that there are no Power System Stabilizers (PSS) installed on the proposed merchant generating units. The maximum export under this condition where the units are marginally damped was determined to be approximately 2700 MW. The stability plot for this simulation is shown in Figure 4. It was determined that export limits can be improved by adding PSS to the merchant generation. Henceforth, it will be a requirement that all new units in the area be equipped with stabilizers.

Conclusions:

The West of the Atchafalaya Basin (WOTAB) area can experience a voltage and dynamic stability problem if a significant amount of new merchant generation is operating in the area by year 2003. The export limit from this area is determined to be 2700 MW based on dynamic stability and 2100 MW based on voltage decline. As this area can experience dynamic problems beyond a certain export limit it will be mandatory for all IPPs in the area to install PSS on their units. Any *further* increase in the export level may require major upgrades, such as construction of 500 kV transmission lines.

The thermal limits were not evaluated in this study because they are source and sink specific and based on the generation dispatch. These limits will be evaluated when transmission service is requested and a System Impact Study is conducted.

APPENDIX A-D POLICY STATEMENT/GUIDELINES FOR POWER SYSTEM STABILIZER ON THE ENTERGY SYSTEM

Background:

A Power System Stabilizer (PSS) is an electronic feedback control that is a part of the excitation system control for generating units. The PSS acts to modulate the generator field voltage to damp the Power System oscillation.

Due to restructuring of the utility industry, there has been a significant amount of merchant generation activity on the Entergy system. These generators are typically equipped with modern exciters that have a high gain and a fast response to enhance transient stability. However, these fast response exciters, if used without stabilizers, can lead to oscillatory instability affecting local or regional reliability. This problem is exacerbated particularly in areas where there is a large amount of generation with limited transmission available for exporting power.

Stability studies carried out at Entergy have validated this concern. Furthermore, based on the understanding of operational problems experienced in the WSCC area over the last several years and the opinion of leading experts in the stability area, PSS are an effective and a low cost means of mitigating dynamic stability problems. In particular, PSS cost can be low if it is included in power plant procurement specifications.

Therefore, as a pre-emptive measure, Entergy requires all new generation (including affiliates and qualifying facilities) intending to interconnect to its transmission system to install PSS on their respective units.

The following guidelines shall be followed for PSS installation:

- PSS shall be installed on all new synchronous generators (50 MVA and larger) connecting to the transmission system that were put into service after January 1, 2000.
- PSS shall be installed on synchronous generators (50 MVA and larger) installed before January 1, 2000 subject to confirmation by Entergy that these units are good candidates for PSS and installing PSS on these units will enhance stability in the region. The decision to install PSS on a specific unit will be based on the effectiveness of the PSS in controlling oscillations, the suitability of the excitation system, and cost of retrofitting.
- In areas where a dynamic stability problem has not been explicitly identified, all synchronous generators (50 MVA and larger) will still be required to install stabilizers. However, in such cases the tuning will not be required and the stabilizer may remain disconnected until further advised by Entergy.
- Need for testing and tuning of PSS on units requesting transmission service from areas where stability problem has not been explicitly identified will be determined on an as-needed basis as part of transmission service study.
- The plants are responsible for testing and tuning of exciter and stabilizer controls for optimum performance and providing PSS model and data for use with PSS/E stability program.
- PSS equipment shall be tested and calibrated in conjunction with automatic voltage regulation (AVR) testing and calibration at-least every five years in accordance with the NERC Compliance Criteria on Generator Testing. PSS re-calibration must be performed if AVR parameters are modified.
- The PSS equipment to be installed is required to be of the Delta-P-omega type.

References:

WOTAB Area Stability Study for the Entergy System

WSCC Draft Policy Statement on Power System Stabilizers

PSEC Application Notes: Power System Stabilizer helps need plant stability margins for Simple Cycle and Combined Cycle Power Plants

APPENDIX A-E TRANSIENT STABILITY DATA AND PLOTS

Plots illustrating the results from the simulated cases have been provided. For all cases, machine angle and frequency plots are given for representative generators in the vicinity of major 138kV or 230kV buses in the area near the proposed PID-217 generation.

PLOTS
TABLE IV-2A FAULT CASES SIMULATED IN THIS STUDY:
3 PHASE FAULTS WITH NORMAL CLEARING


**FAULT REFERENCE NO. 1
FAULT-SABINE- LOCATION GULFWAY**




GW
GW-SABINE, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT SABINE

FILE: C:\SPP PID-217\GW-SABINE-1.out

1.2000	CHNL# 11: CVOLT 334431 CG1SABIN	20.000	→-----→	0.20000
1.2000	CHNL# 9: CVOLT 334441 CG5SABIN	24.000	X-----X	0.20000
1.2000	CHNL# 7: CVOLT 334440 CG4SABIN	24.000	+-----+	0.20000
1.2000	CHNL# 5: CVOLT 334036 CPID 217	13.800	◆-----◆	0.20000
1.2000	CHNL# 3: CVOLT 334035 CGULFWAYA	69.000	←-----←	0.20000
1.2000	CHNL# 1: CVOLT 334034 CGULFWAY	230.00	▣-----▣	0.20000




TUE, JUL 29 2008 10:31
PG 1: VOLTAGE



GW
 GW-SABINE, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT SABINE

FILE: C:\SPP PID-217\GW-SABINE-1.out

1.2000	CHNL# 20: CVOLT 334414 [4LINDE	138.00]]	→-----→	0.20000
1.2000	CHNL# 19: CVOLT 334413 [4PNEC BK	138.00]]	X-----X	0.20000
1.2000	CHNL# 18: CVOLT 334399 [4NECHESO	138.00]]	+-----+	0.20000
1.2000	CHNL# 17: CVOLT 334398 [4HAMPTON	138.00]]	◆-----◆	0.20000
1.2000	CHNL# 15: CVOLT 334433 [G3SABIN	22.000]]	←-----←	0.20000
1.2000	CHNL# 13: CVOLT 334432 [G2SABIN	20.000]]	▣-----▣	0.20000



TUE, JUL 29 2008 10:31
 PG 2: VOLTAGE




GW
GW-SABINE, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT SABINE

FILE: C:\SPP PID-217\GW-SABINE-1.out

TUE, JUL 29 2008 10:31
PG 3: VOLTAGE

1.2000	CHNL# 25: CVOLT 334453 C4COW 13 138.00	X-----X	0.20000
1.2000	CHNL# 24: CVOLT 334450 C4ORANGE 138.00	+-----+	0.20000
1.2000	CHNL# 23: CVOLT 335071 C6BTHREE 230.00	◇-----◇	0.20000
1.2000	CHNL# 22: CVOLT 334364 C6GEOTOWN 230.00	←-----→	0.20000
1.2000	CHNL# 21: CVOLT 334204 C6CHINA 230.00	□-----□	0.20000






GW
 GW-SABINE, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT SABINE

FILE: C:\SPP PID-217\GW-SABINE-1.out

61.000	CHNL# 31: CFREQ 334431 CG1SABIN	20.000]]x60+60	→-----→	59.000
61.000	CHNL# 30: CFREQ 334441 CG5SABIN	24.000]]x60+60	x-----x	59.000
61.000	CHNL# 29: CFREQ 334440 CG4SABIN	24.000]]x60+60	+-----+	59.000
61.000	CHNL# 28: CFREQ 334036 CPID 217	13.800]]x60+60	◆-----◆	59.000
61.000	CHNL# 27: CFREQ 334035 CGULFWAYA	69.000]]x60+60	←-----←	59.000
61.000	CHNL# 26: CFREQ 334034 CGULFWAY	230.00]]x60+60	□-----□	59.000




TUE, JUL 29 2008 10:31
 PG 4: FREQUENCY



GW
 GW-SABINE, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT SABINE

FILE: C:\SPP PID-217\GW-SABINE-1.out

61.000	CHNL# 37: [CFREQ 334414 [4LINDE 138.00]]*60+60	59.000
61.000	CHNL# 36: [CFREQ 334413 [4PNEC BK 138.00]]*60+60	59.000
61.000	CHNL# 35: [CFREQ 334399 [4NECHESO 138.00]]*60+60	59.000
61.000	CHNL# 34: [CFREQ 334398 [4HAMPTON 138.00]]*60+60	59.000
61.000	CHNL# 33: [CFREQ 334433 [63SABIN 22.00]]*60+60	59.000
61.000	CHNL# 32: [CFREQ 334432 [62SABIN 20.00]]*60+60	59.000



TUE, JUL 29 2008 10:31
 PG 5: FREQUENCY




GW
GW-SABINE, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT SABINE

FILE: C:\SPP PID-217\GW-SABINE-1.out

TUE, JUL 29 2008 10:31
PG 6: FREQUENCY

61.000	CHNL# 42: CFREQ 334453 C4COW 13 138.00]]*60+60	x-----x	59.000
61.000	CHNL# 41: CFREQ 334450 C4ORANGE 138.00]]*60+60	+-----+	59.000
61.000	CHNL# 40: CFREQ 335071 C6BTHREE 230.00]]*60+60	◆-----◆	59.000
61.000	CHNL# 39: CFREQ 334364 C6GEOTOWN 230.00]]*60+60	←-----←	59.000
61.000	CHNL# 38: CFREQ 334204 C6CHINA 230.00]]*60+60	□-----□	59.000






GW
 GW-SABINE, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT SABINE

FILE: C:\SPP PID-217\GW-SABINE-1.out
 CHNL# 12: [ANGL 334431 [G1SABIN 20.000]]

250.00	CHNL# 12: [ANGL 334431 [G1SABIN 20.000]]	→-----→	0.0
250.00	CHNL# 10: [ANGL 334441 [G5SABIN 24.000]]	x-----x	0.0
250.00	CHNL# 8: [ANGL 334440 [G4SABIN 24.000]]	+-----+	0.0
250.00	CHNL# 6: [ANGL 334036 [PID 217 13.800]]	◇-----◇	0.0
250.00	CHNL# 4: [ANGL 334035 [GULFWAYA 69.000]]	←-----←	0.0
250.00	CHNL# 2: [ANGL 334034 [GULFWAY 230.00]]	□-----□	0.0




TUE, JUL 29 2008 10:31
 PG 7: ANGLE



GW
GW-SABINE, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT SABINE

FILE: C:\SPP PID-217\GW-SABINE-1.out
CHNL# 46: [ANGL BUS 334033 MACH '1 ']

250.00	CHNL# 45: [ANGL BUS 334032 MACH '1 ']	0.0
250.00	CHNL# 44: [ANGL BUS 334031 MACH '1 ']	0.0
250.00	CHNL# 43: [ANGL BUS 334030 MACH '1 ']	0.0
250.00	CHNL# 16: [ANGL 334433 [G3SABIN 22.000]]	0.0
250.00	CHNL# 14: [ANGL 334432 [G2SABIN 20.000]]	0.0




TUE, JUL 29 2008 10:31
PG 8: ANGLE



GW
GW-SABINE, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT SABINE

FILE: C:\SPP PID-217\GW-SABINE-1.out

250.00	CHNL# 52: CANGI BUS 334335 MACH '1 ']	→-----→	0.0
250.00	CHNL# 51: CANGI BUS 334299 MACH '1 ']	x-----x	0.0
250.00	CHNL# 50: CANGI BUS 334298 MACH '1 ']	+-----+	0.0
250.00	CHNL# 49: CANGI BUS 334282 MACH '1 ']	◆-----◆	0.0
250.00	CHNL# 48: CANGI BUS 334071 MACH '1 ']	←-----←	0.0
250.00	CHNL# 47: CANGI BUS 334070 MACH '1 ']	□-----□	0.0




TUE, JUL 29 2008 10:31
PG 9: ANGLE



GW
GW-SABINE, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT SABINE

FILE: C:\SPP PID-217\GW-SABINE-1.out

250.00	CHNL# 58: [ANGL BUS 334393 MACH '1 ']	0.0
250.00	CHNL# 57: [ANGL BUS 334392 MACH '1 ']	0.0
250.00	CHNL# 56: [ANGL BUS 334377 MACH '1 ']	0.0
250.00	CHNL# 55: [ANGL BUS 334376 MACH '1 ']	0.0
250.00	CHNL# 54: [ANGL BUS 334375 MACH '1 ']	0.0
250.00	CHNL# 53: [ANGL BUS 334374 MACH '1 ']	0.0




TUE, JUL 29 2008 10:31
PG 10: ANGLE



GW
 GW-SABINE, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT SABINE

FILE: C:\SPP PID-217\GW-SABINE-1.out

250.00	CHNL# 64: CANGI BUS 334738 MACH '1 ']	→-----→	0.0
250.00	CHNL# 63: CANGI BUS 334467 MACH '1 ']	x-----x	0.0
250.00	CHNL# 62: CANGI BUS 334458 MACH '1 ']	+-----+	0.0
250.00	CHNL# 61: CANGI BUS 334457 MACH '1 ']	◇-----◇	0.0
250.00	CHNL# 60: CANGI BUS 334456 MACH '1 ']	←-----←	0.0
250.00	CHNL# 59: CANGI BUS 334394 MACH '1 ']	□-----□	0.0




TUE, JUL 29 2008 10:31
 PG 11: ANGLE



GW
GW-SABINE, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT SABINE

FILE: C:\SPP PID-217\GW-SABINE-1.out

250.00	CHNL# 70: C ANGL BUS 335177 MACH '4 'J	→-----→	0.0
250.00	CHNL# 69: C ANGL BUS 335137 MACH '2 'J	X-----X	0.0
250.00	CHNL# 68: C ANGL BUS 335076 MACH '1 'J	+-----+	0.0
250.00	CHNL# 67: C ANGL BUS 335075 MACH '1 'J	◆-----◆	0.0
250.00	CHNL# 66: C ANGL BUS 334740 MACH '1 'J	←-----←	0.0
250.00	CHNL# 65: C ANGL BUS 334739 MACH '1 'J	□-----□	0.0




TUE, JUL 29 2008 10:31
PG 12: ANGLE



GW
 GW-SABINE, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT SABINE

FILE: C:\SPP PID-217\GW-SABINE-1.out

250.00	CHNL# 76: [ANGL BUS 335204 MACH '1 ']	0.0
250.00	CHNL# 75: [ANGL BUS 335203 MACH '1 ']	0.0
250.00	CHNL# 74: [ANGL BUS 335202 MACH '1 ']	0.0
250.00	CHNL# 73: [ANGL BUS 335201 MACH '1 ']	0.0
250.00	CHNL# 72: [ANGL BUS 335179 MACH '6 ']	0.0
250.00	CHNL# 71: [ANGL BUS 335178 MACH '5 ']	0.0




TUE, JUL 29 2008 10:31
 PG 13: ANGLE



GW
GW-SABINE, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT SABINE

FILE: C:\SPP PID-217\GW-SABINE-1.out

TUE, JUL 29 2008 10:31
PG 14: ANGLE




FAULT REFERENCE NO. 2
FAULT-VFWPARK- LOCATION GULFWAY



GW
 GW-VFWPK, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT VFWPK

FILE: C:\SPP PID-217\GW-VFWPK-1.out

1.2000	CHNL# 11: CVOLT 334431 CG1SABIN	20.0000	→-----→	0.20000
1.2000	CHNL# 9: CVOLT 334441 CG5SABIN	24.0000	x-----x	0.20000
1.2000	CHNL# 7: CVOLT 334440 CG4SABIN	24.0000	+-----+	0.20000
1.2000	CHNL# 5: CVOLT 334036 CPID 217	13.8000	◆-----◆	0.20000
1.2000	CHNL# 3: CVOLT 334035 CGULFWAYA	69.0000	←-----←	0.20000
1.2000	CHNL# 1: CVOLT 334034 CGULFWAY	230.0000	□-----□	0.20000



TUE, JUL 29 2008 10:31
 PG 1: VOLTAGE




GW
 GW-VFWPK, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT VFWPK

FILE: C:\SPP PID-217\GW-VFWPK-1.out

1.2000	CHNL# 20: CVDLT 334414 C4LINDE	138.0000	0.20000
1.2000	CHNL# 19: CVDLT 334413 C4PNEC BK	138.0000	0.20000
1.2000	CHNL# 18: CVDLT 334399 C4NECHESO	138.0000	0.20000
1.2000	CHNL# 17: CVDLT 334398 C4HAMPTON	138.0000	0.20000
1.2000	CHNL# 15: CVDLT 334433 C63SABIN	22.0000	0.20000
1.2000	CHNL# 13: CVDLT 334432 C62SABIN	20.0000	0.20000

TUE, JUL 29 2008 10:31
 PG 2: VOLTAGE






GW
 GW-VFWPK, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT VFWPK

FILE: C:\SPP PID-217\GW-VFWPK-1.out

TUE, JUL 29 2008 10:31
 PG 3: VOLTAGE

1.2000	CHNL# 25: CVOLT 334453 C4COW 13	138.00	X-----X	0.20000
1.2000	CHNL# 24: CVOLT 334450 C4ORANGE	138.00	+-----+	0.20000
1.2000	CHNL# 23: CVOLT 335071 C6BTHREE	230.00	◆-----◆	0.20000
1.2000	CHNL# 22: CVOLT 334364 C6GEOTOWN	230.00	▲-----▲	0.20000
1.2000	CHNL# 21: CVOLT 334204 C6CHINA	230.00	□-----□	0.20000






GW
 GW-VFWPK, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT VFWPK

FILE: C:\SPP PID-217\GW-VFWPK-1.out

61.000	CHNL# 31: CFREQ 334431 CG1SABIN	20.000]]*60+60	→-----→	59.000
61.000	CHNL# 30: CFREQ 334441 CG5SABIN	24.000]]*60+60	x-----x	59.000
61.000	CHNL# 29: CFREQ 334440 CG4SABIN	24.000]]*60+60	+-----+	59.000
61.000	CHNL# 28: CFREQ 334036 CPID 217	13.800]]*60+60	◆-----◆	59.000
61.000	CHNL# 27: CFREQ 334035 CGULFWAYA	69.000]]*60+60	←-----←	59.000
61.000	CHNL# 26: CFREQ 334034 CGULFWAY	230.000]]*60+60	□-----□	59.000




TUE, JUL 29 2008 10:31
 PG 4: FREQUENCY



GW
 GW-VFWPK, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT VFWPK

FILE: C:\SPP PID-217\GW-VFWPK-1.out

61.000	CHNL# 37: CFREQ 334414 C4LINDE	138.0000*60+60	→-----→	59.000
61.000	CHNL# 36: CFREQ 334413 C4PNEC BK	138.0000*60+60	x-----x	59.000
61.000	CHNL# 35: CFREQ 334399 C4NECHESO	138.0000*60+60	+-----+	59.000
61.000	CHNL# 34: CFREQ 334398 C4HAMPTDN	138.0000*60+60	◊-----◊	59.000
61.000	CHNL# 33: CFREQ 334433 C63SABIN	22.0000*60+60	←-----←	59.000
61.000	CHNL# 32: CFREQ 334432 C62SABIN	20.0000*60+60	□-----□	59.000




TUE, JUL 29 2008 10:31
 PG 5: FREQUENCY



GW
GW-VFWPK, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT VFWPK

FILE: C:\SPP PID-217\GW-VFWPK-1.out

61.000	CHNL# 42: CFREQ 334453 C4COW 13	138.000	x-----x	59.000
61.000	CHNL# 41: CFREQ 334450 C4ORANGE	138.000	+-----+	59.000
61.000	CHNL# 40: CFREQ 335071 C6BTHREE	230.000	o-----o	59.000
61.000	CHNL# 39: CFREQ 334364 C6GEOTOWN	230.000	^-----^	59.000
61.000	CHNL# 38: CFREQ 334204 C6CHINA	230.000	o-----o	59.000




TUE, JUL 29 2008 10:31
PG 6: FREQUENCY



GW
GW-VFWPK, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT VFWPK

FILE: C:\SPP PID-217\GW-VFWPK-1.out

250.00	CHNL# 12: CANGL 334431 CGISABIN	20.0000	→	0.0
250.00	CHNL# 10: CANGL 334441 CG5SABIN	24.0000	x	0.0
250.00	CHNL# 8: CANGL 334440 CG4SABIN	24.0000	+	0.0
250.00	CHNL# 6: CANGL 334036 CPID 217	19.8000	◆	0.0
250.00	CHNL# 4: CANGL 334035 CGULFWAYA	69.0000	←	0.0
250.00	CHNL# 2: CANGL 334034 CGULFWAY	230.0000	□	0.0




TUE, JUL 29 2008 10:31
PG 7: ANGLE



GW
GW-VFWPK, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT VFWPK

FILE: C:\SPP PID-217\GW-VFWPK-1.out

250.00	CHNL# 46: [ANGL BUS 334033 MACH '1 ']	→-----→	0.0
250.00	CHNL# 45: [ANGL BUS 334032 MACH '1 ']	x-----x	0.0
250.00	CHNL# 44: [ANGL BUS 334031 MACH '1 ']	+-----+	0.0
250.00	CHNL# 43: [ANGL BUS 334030 MACH '1 ']	◆-----◆	0.0
250.00	CHNL# 16: [ANGL 334433 CG3SABIN 22.000]]	←-----←	0.0
250.00	CHNL# 14: [ANGL 334432 CG2SABIN 20.000]]	□-----□	0.0




TUE, JUL 29 2008 10:31
PG 8: ANGLE



GW
GW-VFWPK, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT VFWPK

FILE: C:\SPP PID-217\GW-VFWPK-1.out

250.00	CHNL# 52: CANGI BUS 334335 MACH '1 'J	→-----→	0.0
250.00	CHNL# 51: CANGI BUS 334299 MACH '1 'J	x-----x	0.0
250.00	CHNL# 50: CANGI BUS 334298 MACH '1 'J	+-----+	0.0
250.00	CHNL# 49: CANGI BUS 334282 MACH '1 'J	◆-----◆	0.0
250.00	CHNL# 48: CANGI BUS 334071 MACH '1 'J	←-----←	0.0
250.00	CHNL# 47: CANGI BUS 334070 MACH '1 'J	□-----□	0.0




TUE, JUL 29 2008 10:31
PG 9: ANGLE



GW
GW-VFWPK, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT VFWPK

FILE: C:\SPP PID-217\GW-VFWPK-1.out

250.00	CHNL# 58: C ANGL BUS 334393 MACH '1 'J	→-----→	0.0
250.00	CHNL# 57: C ANGL BUS 334392 MACH '1 'J	X-----X	0.0
250.00	CHNL# 56: C ANGL BUS 334377 MACH '1 'J	+-----+	0.0
250.00	CHNL# 55: C ANGL BUS 334376 MACH '1 'J	◆-----◆	0.0
250.00	CHNL# 54: C ANGL BUS 334375 MACH '1 'J	←-----←	0.0
250.00	CHNL# 53: C ANGL BUS 334374 MACH '1 'J	□-----□	0.0




TUE, JUL 29 2008 10:31
PG 10: ANGLE



GW
GW-VFWPK, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT VFWPK

FILE: C:\SPP PID-217\GW-VFWPK-1.out

250.00	CHNL# 64: C ANGL BUS 33473B MACH '1 'J	0.0
250.00	CHNL# 63: C ANGL BUS 334467 MACH '1 'J	0.0
250.00	CHNL# 62: C ANGL BUS 334458 MACH '1 'J	0.0
250.00	CHNL# 61: C ANGL BUS 334457 MACH '1 'J	0.0
250.00	CHNL# 60: C ANGL BUS 334456 MACH '1 'J	0.0
250.00	CHNL# 59: C ANGL BUS 334394 MACH '1 'J	0.0




TUE, JUL 29 2008 10:31
PG 11: ANGLE



GW
GW-VFWPK, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT VFWPK

FILE: C:\SPP PID-217\GW-VFWPK-1.out

250.00	CHNL# 70: C ANGL BUS 335177 MACH '4 'J	0.0
250.00	CHNL# 69: C ANGL BUS 335137 MACH '2 'J	0.0
250.00	CHNL# 68: C ANGL BUS 335076 MACH '1 'J	0.0
250.00	CHNL# 67: C ANGL BUS 335075 MACH '1 'J	0.0
250.00	CHNL# 66: C ANGL BUS 334740 MACH '1 'J	0.0
250.00	CHNL# 65: C ANGL BUS 334739 MACH '1 'J	0.0




TUE, JUL 29 2008 10:31
PG 12: ANGLE



GW
GW-VFWPK, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT VFWPK

FILE: C:\SPP PID-217\GW-VFWPK-1.out

250.00	CHNL# 76: [ANGL BUS 335204 MACH '1 ']	0.0
250.00	CHNL# 75: [ANGL BUS 335203 MACH '1 ']	0.0
250.00	CHNL# 74: [ANGL BUS 335202 MACH '1 ']	0.0
250.00	CHNL# 73: [ANGL BUS 335201 MACH '1 ']	0.0
250.00	CHNL# 72: [ANGL BUS 335179 MACH '6 ']	0.0
250.00	CHNL# 71: [ANGL BUS 335178 MACH '5 ']	0.0




TUE, JUL 29 2008 10:31
PG 13: ANGLE



GW
GW-VFWPK, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT VFWPK

FILE: C:\SPP PID-217\GW-VFWPK-1.out

TUE, JUL 29 2008 10:31
PG 14: ANGLE




**FAULT REFERENCE NO. 3
FAULT-KOLBS/HANKS- LOCATION GULFWAY**



GW
GW-HANKS, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT HANKS

FILE: C:\SPP PID-217\GW-HANKS-1.out

1.2000	CHNL# 11: CVOLT 334431 CG1SABIN	20.0000	0.20000
1.2000	CHNL# 9: CVOLT 334441 CG5SABIN	24.0000	0.20000
1.2000	CHNL# 7: CVOLT 334440 CG4SABIN	24.0000	0.20000
1.2000	CHNL# 5: CVOLT 334036 CPID 217	13.8000	0.20000
1.2000	CHNL# 3: CVOLT 334035 CGULFWAYA	69.0000	0.20000
1.2000	CHNL# 1: CVOLT 334034 CGULFWAY	230.0000	0.20000




TUE, JUL 29 2008 10:31
PG 1: VOLTAGE



GW
 GW-HANKS, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT HANKS

FILE: C:\SPP PID-217\GW-HANKS-1.out

1.2000	CHNL# 20: CVDLT 334414 C4LINDE	138.0000	→-----→	0.20000
1.2000	CHNL# 19: CVDLT 334413 C4PNEC BK	138.0000	X-----X	0.20000
1.2000	CHNL# 18: CVDLT 334399 C4NECHESO	138.0000	+-----+	0.20000
1.2000	CHNL# 17: CVDLT 334398 C4HAMPTDN	138.0000	◇-----◇	0.20000
1.2000	CHNL# 15: CVDLT 334433 CG3SABIN	22.0000	←-----←	0.20000
1.2000	CHNL# 13: CVDLT 334432 CG2SABIN	20.0000	▣-----▣	0.20000



TUE, JUL 29 2008 10:31
 PG 2: VOLTAGE




GW
 GW-HANKS, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT HANKS

FILE: C:\SPP PID-217\GW-HANKS-1.out

TUE, JUL 29 2008 10:31
 PG 3: VOLTAGE

1.2000	CHNL# 25: CVDLT 334453 C4COW 13 138.00]]	X-----X	0.20000
1.2000	CHNL# 24: CVDLT 334450 C4ORANGE 138.00]]	+-----+	0.20000
1.2000	CHNL# 23: CVDLT 335071 C6BTHREE 230.00]]	◆-----◆	0.20000
1.2000	CHNL# 22: CVDLT 334364 C6GEOTOWN 230.00]]	←-----→	0.20000
1.2000	CHNL# 21: CVDLT 334204 C6CHINA 230.00]]	□-----□	0.20000






GW
GW-HANKS, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT HANKS

FILE: C:\SPP PID-217\GW-HANKS-1.out

61.000	CHNL# 31: CFREQ 334431 CG1SABIN	20.000000x60+60	59.000
61.000	CHNL# 30: CFREQ 334441 CG5SABIN	24.000000x60+60	59.000
61.000	CHNL# 29: CFREQ 334440 CG4SABIN	24.000000x60+60	59.000
61.000	CHNL# 28: CFREQ 334036 CPID 217	13.800000x60+60	59.000
61.000	CHNL# 27: CFREQ 334035 CGULFWAYA	69.000000x60+60	59.000
61.000	CHNL# 26: CFREQ 334034 CGULFWAY	230.000000x60+60	59.000




TUE, JUL 29 2008 10:31
PG 4: FREQUENCY




GW
 GW-HANKS, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT HANKS

FILE: C:\SPP PID-217\GW-HANKS-1.out

61.000	CHNL# 37: CFREQ 334414 C4LINDE	138.0000]x60+60	59.000
61.000	CHNL# 36: CFREQ 334413 C4PNEC BK	138.0000]x60+60	59.000
61.000	CHNL# 35: CFREQ 334399 C4NECHESO	138.0000]x60+60	59.000
61.000	CHNL# 34: CFREQ 334398 C4HAMPTDN	138.0000]x60+60	59.000
61.000	CHNL# 33: CFREQ 334433 C63SABIN	22.0000]x60+60	59.000
61.000	CHNL# 32: CFREQ 334432 C62SABIN	20.0000]x60+60	59.000



TUE, JUL 29 2008 10:31
 PG 5: FREQUENCY




GW
GW-HANKS, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT HANKS

FILE: C:\SPP PID-217\GW-HANKS-1.out

TUE, JUL 29 2008 10:31
PG 6: FREQUENCY

61.000	CHNL# 42: CFREQ 334453 C4CDW 13 138.00]]*60+60	X-----X	59.000
61.000	CHNL# 41: CFREQ 334450 C4ORANGE 138.00]]*60+60	+-----+	59.000
61.000	CHNL# 40: CFREQ 335071 C6BTHREE 230.00]]*60+60	◆-----◆	59.000
61.000	CHNL# 39: CFREQ 334364 C6GEOTOWN 230.00]]*60+60	←-----←	59.000
61.000	CHNL# 38: CFREQ 334204 C6CHINA 230.00]]*60+60	□-----□	59.000






GW
 GW-HANKS, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT HANKS

FILE: C:\SPP PID-217\GW-HANKS-1.out

250.00	CHNL# 12: CANGL 334431 CG1SABIN	20.000]]	→-----→	0.0
250.00	CHNL# 10: CANGL 334441 CG5SABIN	24.000]]	x-----x	0.0
250.00	CHNL# 8: CANGL 334440 CG4SABIN	24.000]]	+-----+	0.0
250.00	CHNL# 6: CANGL 334036 CPID 217	13.800]]	◆-----◆	0.0
250.00	CHNL# 4: CANGL 334035 CGULFWAYA	69.000]]	←-----←	0.0
250.00	CHNL# 2: CANGL 334034 CGULFWAY	230.000]]	□-----□	0.0




TUE, JUL 29 2008 10:31
 PG 7: ANGLE



GW
GW-HANKS, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT HANKS

FILE: C:\SPP PID-217\GW-HANKS-1.out

250.00	CHNL# 46: CANGI BUS 334033 MACH '1 'J	0.0
250.00	CHNL# 45: CANGI BUS 334032 MACH '1 'J	0.0
250.00	CHNL# 44: CANGI BUS 334031 MACH '1 'J	0.0
250.00	CHNL# 43: CANGI BUS 334030 MACH '1 'J	0.0
250.00	CHNL# 16: CANGI 334433 CG3SABIN 22.000J	0.0
250.00	CHNL# 14: CANGI 334432 CG2SABIN 20.000J	0.0




TUE, JUL 29 2008 10:31
PG 8: ANGLE



GW
GW-HANKS, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT HANKS

FILE: C:\SPP PID-217\GW-HANKS-1.out

250.00	CHNL# 52: [ANGL BUS 334335 MACH '1 ']	→-----→	0.0
250.00	CHNL# 51: [ANGL BUS 334299 MACH '1 ']	x-----x	0.0
250.00	CHNL# 50: [ANGL BUS 334298 MACH '1 ']	+-----+	0.0
250.00	CHNL# 49: [ANGL BUS 334282 MACH '1 ']	◆-----◆	0.0
250.00	CHNL# 48: [ANGL BUS 334071 MACH '1 ']	←-----←	0.0
250.00	CHNL# 47: [ANGL BUS 334070 MACH '1 ']	□-----□	0.0




TUE, JUL 29 2008 10:31
PG 9: ANGLE



GW
GW-HANKS, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT HANKS

FILE: C:\SPP PID-217\GW-HANKS-1.out

250.00	CHNL# 58: C ANGL BUS 334393 MACH '1 'J	→-----→	0.0
250.00	CHNL# 57: C ANGL BUS 334392 MACH '1 'J	X-----X	0.0
250.00	CHNL# 56: C ANGL BUS 334377 MACH '1 'J	+-----+	0.0
250.00	CHNL# 55: C ANGL BUS 334376 MACH '1 'J	◆-----◆	0.0
250.00	CHNL# 54: C ANGL BUS 334375 MACH '1 'J	←-----←	0.0
250.00	CHNL# 53: C ANGL BUS 334374 MACH '1 'J	□-----□	0.0




TUE, JUL 29 2008 10:31
PG 10: ANGLE



GW
GW-HANKS, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT HANKS

FILE: C:\SPP PID-217\GW-HANKS-1.out

250.00	CHNL# 64: [ANGL BUS 33473B MACH '1 ']	→-----→	0.0
250.00	CHNL# 63: [ANGL BUS 334467 MACH '1 ']	x-----x	0.0
250.00	CHNL# 62: [ANGL BUS 334458 MACH '1 ']	+-----+	0.0
250.00	CHNL# 61: [ANGL BUS 334457 MACH '1 ']	◆-----◆	0.0
250.00	CHNL# 60: [ANGL BUS 334456 MACH '1 ']	←-----←	0.0
250.00	CHNL# 59: [ANGL BUS 334394 MACH '1 ']	□-----□	0.0




TUE, JUL 29 2008 10:31
PG 11: ANGLE



GW
 GW-HANKS, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT HANKS

FILE: C:\SPP PID-217\GW-HANKS-1.out

250.00	CHNL# 70: C ANGL BUS 335177 MACH '4 'J	0.0
250.00	CHNL# 69: C ANGL BUS 335137 MACH '2 'J	0.0
250.00	CHNL# 68: C ANGL BUS 335076 MACH '1 'J	0.0
250.00	CHNL# 67: C ANGL BUS 335075 MACH '1 'J	0.0
250.00	CHNL# 66: C ANGL BUS 334740 MACH '1 'J	0.0
250.00	CHNL# 65: C ANGL BUS 334739 MACH '1 'J	0.0



TUE, JUL 29 2008 10:31
 PG 12: ANGLE



GW
 GW-HANKS, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 FAULT HANKS

FILE: C:\SPP PID-217\GW-HANKS-1.out

250.00	CHNL# 76: C ANGL BUS 335204 MACH '1 'J	→-----→	0.0
250.00	CHNL# 75: C ANGL BUS 335203 MACH '1 'J	X-----X	0.0
250.00	CHNL# 74: C ANGL BUS 335202 MACH '1 'J	+-----+	0.0
250.00	CHNL# 73: C ANGL BUS 335201 MACH '1 'J	◆-----◆	0.0
250.00	CHNL# 72: C ANGL BUS 335179 MACH '6 'J	←-----←	0.0
250.00	CHNL# 71: C ANGL BUS 335178 MACH '5 'J	□-----□	0.0




TUE, JUL 29 2008 10:31
 PG 13: ANGLE



GW
GW-HANKS, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
FAULT HANKS

FILE: C:\SPP PID-217\GW-HANKS-1.out

TUE, JUL 29 2008 10:31
PG 14: ANGLE




FAULT REFERENCE NO. 4
FAULT-GENR1- LOCATION GULFWAY GENR1



GW
GW-GULFWAY #1 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #1 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY_1-1.out

1.2000	CHNL# 11: CVOLT 334431 CG1SABIN	20.0000	→-----→	0.20000
1.2000	CHNL# 9: CVOLT 334441 CG5SABIN	24.0000	X-----X	0.20000
1.2000	CHNL# 7: CVOLT 334440 CG4SABIN	24.0000	+-----+	0.20000
1.2000	CHNL# 5: CVOLT 334036 CPID 217	13.8000	◆-----◆	0.20000
1.2000	CHNL# 3: CVOLT 334035 CGULFWAYA	69.0000	←-----←	0.20000
1.2000	CHNL# 1: CVOLT 334034 CGULFWAY	230.0000	□-----□	0.20000




TUE, JUL 29 2008 10:31
PG 1: VOLTAGE



GW
GW-GULFWAY #1 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #1 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY_1-1.out

1.2000	CHNL# 20: CVDLT 334414 C4LINDE	138.0000	→-----→	0.20000
1.2000	CHNL# 19: CVDLT 334413 C4PNEC BK	138.0000	x-----x	0.20000
1.2000	CHNL# 18: CVDLT 334399 C4NECHESO	138.0000	+-----+	0.20000
1.2000	CHNL# 17: CVDLT 334398 C4HAMPTDN	138.0000	◆-----◆	0.20000
1.2000	CHNL# 15: CVDLT 334433 C63SABIN	22.0000	←-----←	0.20000
1.2000	CHNL# 13: CVDLT 334432 C62SABIN	20.0000	□-----□	0.20000




TUE, JUL 29 2008 10:31
PG 2: VOLTAGE



GW
 GW-GULFWAY #1 TRANSFORMER, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 GULFWAY #1 TRANSFORMER, NORMAL CLEARING
 FILE: C:\SPP PID-217\GW-GULFWAY_1-1.out

TUE, JUL 29 2008 10:31
 PG 3: VOLTAGE

1.2000	CHNL# 25: CVDLT 334453 C4COW 13	130.0000	X-----X	0.20000
1.2000	CHNL# 24: CVDLT 334450 C4ORANGE	130.0000	+-----+	0.20000
1.2000	CHNL# 23: CVDLT 335071 C6BTHREE	230.0000	◆-----◆	0.20000
1.2000	CHNL# 22: CVDLT 334364 C6GEOTOWN	230.0000	◀-----▶	0.20000
1.2000	CHNL# 21: CVDLT 334204 C6CHINA	230.0000	□-----□	0.20000






GW
GW-GULFWAY #1 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #1 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY_1-1.out

61.000	CHNL# 31: CFREQ 334431 CG1SABIN	20.0000]]x60+60	59.000
61.000	CHNL# 30: CFREQ 334441 CG5SABIN	24.0000]]x60+60	59.000
61.000	CHNL# 29: CFREQ 334440 CG4SABIN	24.0000]]x60+60	59.000
61.000	CHNL# 28: CFREQ 334036 CPID 217	13.8000]]x60+60	59.000
61.000	CHNL# 27: CFREQ 334035 CGULFWAYA	69.0000]]x60+60	59.000
61.000	CHNL# 26: CFREQ 334034 CGULFWAY	230.0000]]x60+60	59.000




TUE, JUL 29 2008 10:31
PG 4: FREQUENCY



GW
 GW-GULFWAY #1 TRANSFORMER, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 GULFWAY #1 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY_1-1.out
 CHNL# 37: CFREQ 334414 C4LINDE 138.0000*60+60

61.000				→-----→	59.000
	CHNL# 36: CFREQ 334413 C4PNEC BK	138.0000*60+60		x-----x	
61.000					59.000
	CHNL# 35: CFREQ 334399 C4NECHESO	138.0000*60+60		+-----+	
61.000					59.000
	CHNL# 34: CFREQ 334398 C4HAMPTDN	138.0000*60+60		◊-----◊	
61.000					59.000
	CHNL# 33: CFREQ 334433 C63SABIN	22.0000*60+60		←-----←	
61.000					59.000
	CHNL# 32: CFREQ 334432 C62SABIN	20.0000*60+60		□-----□	
61.000					59.000




TUE, JUL 29 2008 10:31
 PG 5: FREQUENCY



GW
 GW-GULFWAY #1 TRANSFORMER, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 GULFWAY #1 TRANSFORMER, NORMAL CLEARING
 FILE: C:\SPP PID-217\GW-GULFWAY_1-1.out

TUE, JUL 29 2008 10:32
 PG 6: FREQUENCY

61.000	CHNL# 42: CFREQ 334453 C4COW 13	138.00]]*60+60	X-----X	59.000
61.000	CHNL# 41: CFREQ 334450 C4ORANGE	138.00]]*60+60	+-----+	59.000
61.000	CHNL# 40: CFREQ 335071 C6BTHREE	230.00]]*60+60	◆-----◆	59.000
61.000	CHNL# 39: CFREQ 334364 C6GEOTOWN	230.00]]*60+60	←-----→	59.000
61.000	CHNL# 38: CFREQ 334204 C6CHINA	230.00]]*60+60	□-----□	59.000






GW
GW-GULFWAY #1 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #1 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY_1-1.out

250.00	CHNL# 12: CANGL 334431 CG1SABIN	20.0000	→-----→	0.0
250.00	CHNL# 10: CANGL 334441 CG5SABIN	24.0000	x-----x	0.0
250.00	CHNL# 8: CANGL 334440 CG4SABIN	24.0000	+-----+	0.0
250.00	CHNL# 6: CANGL 334036 CPID 217	13.8000	◆-----◆	0.0
250.00	CHNL# 4: CANGL 334035 CGULFWAYA	69.0000	←-----←	0.0
250.00	CHNL# 2: CANGL 334034 CGULFWAY	230.0000	□-----□	0.0




TUE, JUL 29 2008 10:32
PG 7: ANGLE



GW
GW-GULFWAY #1 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #1 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY_1-1.out

250.00	CHNL# 46: [ANGL BUS 334033 MACH '1 ']	0.0
250.00	CHNL# 45: [ANGL BUS 334032 MACH '1 ']	0.0
250.00	CHNL# 44: [ANGL BUS 334031 MACH '1 ']	0.0
250.00	CHNL# 43: [ANGL BUS 334030 MACH '1 ']	0.0
250.00	CHNL# 16: [ANGL 334433 [G3SABIN 22.000]]	0.0
250.00	CHNL# 14: [ANGL 334432 [G2SABIN 20.000]]	0.0




TUE, JUL 29 2008 10:32
PG 8: ANGLE



GW
GW-GULFWAY #1 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #1 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY_1-1.out

250.00	CHNL# 52: C ANGL BUS 334335 MACH '1 'J	0.0
250.00	CHNL# 51: C ANGL BUS 334299 MACH '1 'J	0.0
250.00	CHNL# 50: C ANGL BUS 334298 MACH '1 'J	0.0
250.00	CHNL# 49: C ANGL BUS 334282 MACH '1 'J	0.0
250.00	CHNL# 48: C ANGL BUS 334071 MACH '1 'J	0.0
250.00	CHNL# 47: C ANGL BUS 334070 MACH '1 'J	0.0




TUE, JUL 29 2008 10:32
PG 9: ANGLE



GW
 GW-GULFWAY #1 TRANSFORMER, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 GULFWAY #1 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY_1-1.out

250.00	CHNL# 58: C ANGL BUS 334393 MACH '1 'J	→-----→	0.0
250.00	CHNL# 57: C ANGL BUS 334392 MACH '1 'J	X-----X	0.0
250.00	CHNL# 56: C ANGL BUS 334377 MACH '1 'J	+-----+	0.0
250.00	CHNL# 55: C ANGL BUS 334376 MACH '1 'J	◆-----◆	0.0
250.00	CHNL# 54: C ANGL BUS 334375 MACH '1 'J	←-----←	0.0
250.00	CHNL# 53: C ANGL BUS 334374 MACH '1 'J	□-----□	0.0




TUE, JUL 29 2008 10:32
 PG 10: ANGLE



GW
GW-GULFWAY #1 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #1 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY_1-1.out

250.00	CHNL# 64: CANGL BUS 334738 MACH '1 'J	0.0
250.00	CHNL# 63: CANGL BUS 334467 MACH '1 'J	0.0
250.00	CHNL# 62: CANGL BUS 334458 MACH '1 'J	0.0
250.00	CHNL# 61: CANGL BUS 334457 MACH '1 'J	0.0
250.00	CHNL# 60: CANGL BUS 334456 MACH '1 'J	0.0
250.00	CHNL# 59: CANGL BUS 334394 MACH '1 'J	0.0




TUE, JUL 29 2008 10:32
PG 11: ANGLE



GW
GW-GULFWAY #1 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #1 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY_1-1.out

250.00	CHNL# 70: C ANGL BUS 335177 MACH '4 'J	0.0
250.00	CHNL# 69: C ANGL BUS 335137 MACH '2 'J	0.0
250.00	CHNL# 68: C ANGL BUS 335076 MACH '1 'J	0.0
250.00	CHNL# 67: C ANGL BUS 335075 MACH '1 'J	0.0
250.00	CHNL# 66: C ANGL BUS 334740 MACH '1 'J	0.0
250.00	CHNL# 65: C ANGL BUS 334739 MACH '1 'J	0.0




TUE, JUL 29 2008 10:32
PG 12: ANGLE



GW
 GW-GULFWAY #1 TRANSFORMER, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 GULFWAY #1 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY_1-1.out

250.00	CHNL# 76: [ANGL BUS 335204 MACH '1 ']	0.0
250.00	CHNL# 75: [ANGL BUS 335203 MACH '1 ']	0.0
250.00	CHNL# 74: [ANGL BUS 335202 MACH '1 ']	0.0
250.00	CHNL# 73: [ANGL BUS 335201 MACH '1 ']	0.0
250.00	CHNL# 72: [ANGL BUS 335179 MACH '6 ']	0.0
250.00	CHNL# 71: [ANGL BUS 335178 MACH '5 ']	0.0




TUE, JUL 29 2008 10:32
 PG 13: ANGLE



GW
GW-GULFWAY #1 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #1 TRANSFORMER, NORMAL CLEARING
FILE: C:\SPP PID-217\GW-GULFWAY_1-1.out

TUE, JUL 29 2008 10:32
PG 14: ANGLE




Fault Reference No. 5
Fault-GENR2- Location Gulfway Genr2



GW
GW-GULFWAY #2 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #2 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY-2.out

1.2000	CHNL# 11: CVOLT 334431 CG1SABIN	20.0000	→-----→	0.20000
1.2000	CHNL# 9: CVOLT 334441 CG5SABIN	24.0000	x-----x	0.20000
1.2000	CHNL# 7: CVOLT 334440 CG4SABIN	24.0000	+-----+	0.20000
1.2000	CHNL# 5: CVOLT 334036 CPID 217	13.8000	◆-----◆	0.20000
1.2000	CHNL# 3: CVOLT 334035 CGULFWAYA	69.0000	←-----←	0.20000
1.2000	CHNL# 1: CVOLT 334034 CGULFWAY	230.0000	□-----□	0.20000




TUE, JUL 29 2008 10:32
PG 1: VOLTAGE



GW
GW-GULFWAY #2 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #2 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY-2.out

1.2000	CHNL# 20: CVDLT 334414 C4LINDE	138.0000	→-----→	0.20000
1.2000	CHNL# 19: CVDLT 334413 C4PNEC BK	138.0000	X-----X	0.20000
1.2000	CHNL# 18: CVDLT 334399 C4NECHESO	138.0000	+-----+	0.20000
1.2000	CHNL# 17: CVDLT 334398 C4HAMPTDN	138.0000	◆-----◆	0.20000
1.2000	CHNL# 15: CVDLT 334433 C63SABIN	22.0000	←-----←	0.20000
1.2000	CHNL# 13: CVDLT 334432 C62SABIN	20.0000	□-----□	0.20000




TUE, JUL 29 2008 10:32
PG 2: VOLTAGE



GW
 GW-GULFWAY #2 TRANSFORMER, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 GULFWAY #2 TRANSFORMER, NORMAL CLEARING
 FILE: C:\SPP PID-217\GW-GULFWAY-2.out

TUE, JUL 29 2008 10:32
 PG 3: VOLTAGE

1.2000	CHNL# 25: CVDLT 334453 C4COW 13 138.00]]	X-----X	0.20000
1.2000	CHNL# 24: CVDLT 334450 C4ORANGE 138.00]]	+-----+	0.20000
1.2000	CHNL# 23: CVDLT 335071 C6BTHREE 230.00]]	◆-----◆	0.20000
1.2000	CHNL# 22: CVDLT 334364 C6GEOTOWN 230.00]]	▲-----▲	0.20000
1.2000	CHNL# 21: CVDLT 334204 C6CHINA 230.00]]	■-----■	0.20000






GW
 GW-GULFWAY #2 TRANSFORMER, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 GULFWAY #2 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY-2.out

61.000	CHNL# 31: CFREQ 334431 CG1SABIN	20.000000*60+60	59.000
61.000	CHNL# 30: CFREQ 334441 CG5SABIN	24.000000*60+60	59.000
61.000	CHNL# 29: CFREQ 334440 CG4SABIN	24.000000*60+60	59.000
61.000	CHNL# 28: CFREQ 334036 CPID 217	13.800000*60+60	59.000
61.000	CHNL# 27: CFREQ 334035 CGULFWAYA	69.000000*60+60	59.000
61.000	CHNL# 26: CFREQ 334034 CGULFWAY	230.000000*60+60	59.000




TUE, JUL 29 2008 10:32
 PG 4: FREQUENCY



GW
GW-GULFWAY #2 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #2 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY-2.out

61.000	CHNL# 37: CFREQ 334414 C4LINDE	138.000]]*60+60	59.000
61.000	CHNL# 36: CFREQ 334413 C4PNEC BK	138.000]]*60+60	59.000
61.000	CHNL# 35: CFREQ 334399 C4NECHESO	138.000]]*60+60	59.000
61.000	CHNL# 34: CFREQ 334398 C4HAMPTDN	138.000]]*60+60	59.000
61.000	CHNL# 33: CFREQ 334433 CG3SABIN	22.000]]*60+60	59.000
61.000	CHNL# 32: CFREQ 334432 CG2SABIN	20.000]]*60+60	59.000




TUE, JUL 29 2008 10:32
PG 5: FREQUENCY



GW
 GW-GULFWAY #2 TRANSFORMER, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 GULFWAY #2 TRANSFORMER, NORMAL CLEARING
 FILE: C:\SPP PID-217\GW-GULFWAY-2.out

TUE, JUL 29 2008 10:32
 PG 6: FREQUENCY

61.000	CHNL# 42: CFREQ 334453 C4COW 13	138.000	x-----x	59.000
61.000	CHNL# 41: CFREQ 334450 C4ORANGE	138.000	+-----+	59.000
61.000	CHNL# 40: CFREQ 335071 C6BTHREE	230.000	o-----o	59.000
61.000	CHNL# 39: CFREQ 334364 C6GEOTOWN	230.000	^-----^	59.000
61.000	CHNL# 38: CFREQ 334204 C6CHINA	230.000	o-----o	59.000






GW
 GW-GULFWAY #2 TRANSFORMER, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 GULFWAY #2 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY-2.out
 CHNL# 12: CANGL 334431 CG1SABIN 20.000]]

250.00				→-----→	0.0
	CHNL# 10: CANGL 334441 CG5SABIN	24.000]]		x-----x	0.0
250.00					
	CHNL# 8: CANGL 334440 CG4SABIN	24.000]]		+-----+	0.0
250.00					
	CHNL# 6: CANGL 334036 CPID 217	13.800]]		◆-----◆	0.0
250.00					
	CHNL# 4: CANGL 334035 CGULFWAYA	69.000]]		←-----←	0.0
250.00					
	CHNL# 2: CANGL 334034 CGULFWAY	230.000]]		□-----□	0.0
250.00					




TUE, JUL 29 2008 10:32
 PG 7: ANGLE



GW
 GW-GULFWAY #2 TRANSFORMER, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 GULFWAY #2 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY-2.out

250.00	CHNL# 46: CANGL BUS 334033 MACH '1 ']	0.0
250.00	CHNL# 45: CANGL BUS 334032 MACH '1 ']	0.0
250.00	CHNL# 44: CANGL BUS 334031 MACH '1 ']	0.0
250.00	CHNL# 43: CANGL BUS 334030 MACH '1 ']	0.0
250.00	CHNL# 16: CANGL 334433 CG3SABIN 22.000]]	0.0
250.00	CHNL# 14: CANGL 334432 CG2SABIN 20.000]]	0.0




TUE, JUL 29 2008 10:32
 PG 8: ANGLE



GW
 GW-GULFWAY #2 TRANSFORMER, NORMAL CLEARING
 CLEAR LOCAL AND REMOVE IN 7CYC
 GULFWAY #2 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY-2.out

250.00	CHNL# 52: C ANGL BUS 334335 MACH '1 'J	0.0
250.00	CHNL# 51: C ANGL BUS 334299 MACH '1 'J	0.0
250.00	CHNL# 50: C ANGL BUS 334298 MACH '1 'J	0.0
250.00	CHNL# 49: C ANGL BUS 334282 MACH '1 'J	0.0
250.00	CHNL# 48: C ANGL BUS 334071 MACH '1 'J	0.0
250.00	CHNL# 47: C ANGL BUS 334070 MACH '1 'J	0.0




TUE, JUL 29 2008 10:32
 PG 9: ANGLE



GW
GW-GULFWAY #2 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #2 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY-2.out

250.00	CHNL# 58: C ANGL BUS 334393 MACH '1 ']	0.0
250.00	CHNL# 57: C ANGL BUS 334392 MACH '1 ']	0.0
250.00	CHNL# 56: C ANGL BUS 334377 MACH '1 ']	0.0
250.00	CHNL# 55: C ANGL BUS 334376 MACH '1 ']	0.0
250.00	CHNL# 54: C ANGL BUS 334375 MACH '1 ']	0.0
250.00	CHNL# 53: C ANGL BUS 334374 MACH '1 ']	0.0




TUE, JUL 29 2008 10:32
PG 10: ANGLE



GW
GW-GULFWAY #2 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #2 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY-2.out

250.00	CHNL# 64: [ANGL BUS 33473B MACH '1 ']	0.0
250.00	CHNL# 63: [ANGL BUS 334467 MACH '1 ']	0.0
250.00	CHNL# 62: [ANGL BUS 334458 MACH '1 ']	0.0
250.00	CHNL# 61: [ANGL BUS 334457 MACH '1 ']	0.0
250.00	CHNL# 60: [ANGL BUS 334456 MACH '1 ']	0.0
250.00	CHNL# 59: [ANGL BUS 334394 MACH '1 ']	0.0




TUE, JUL 29 2008 10:32
PG 11: ANGLE



GW
GW-GULFWAY #2 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #2 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY-2.out

250.00	CHNL# 70: C ANGL BUS 335177 MACH '4 'J	→	0.0
250.00	CHNL# 69: C ANGL BUS 335137 MACH '2 'J	x	0.0
250.00	CHNL# 68: C ANGL BUS 335076 MACH '1 'J	+	0.0
250.00	CHNL# 67: C ANGL BUS 335075 MACH '1 'J	◆	0.0
250.00	CHNL# 66: C ANGL BUS 334740 MACH '1 'J	←	0.0
250.00	CHNL# 65: C ANGL BUS 334739 MACH '1 'J	□	0.0




TUE, JUL 29 2008 10:32
PG 12: ANGLE



GW
GW-GULFWAY #2 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #2 TRANSFORMER, NORMAL CLEARING

FILE: C:\SPP PID-217\GW-GULFWAY-2.out

250.00	CHNL# 76: CANGL BUS 335204 MACH '1 'J	→-----→	0.0
250.00	CHNL# 75: CANGL BUS 335203 MACH '1 'J	X-----X	0.0
250.00	CHNL# 74: CANGL BUS 335202 MACH '1 'J	+-----+	0.0
250.00	CHNL# 73: CANGL BUS 335201 MACH '1 'J	◆-----◆	0.0
250.00	CHNL# 72: CANGL BUS 335179 MACH '6 'J	←-----←	0.0
250.00	CHNL# 71: CANGL BUS 335178 MACH '5 'J	□-----□	0.0




TUE, JUL 29 2008 10:32
PG 13: ANGLE



GW
GW-GULFWAY #2 TRANSFORMER, NORMAL CLEARING
CLEAR LOCAL AND REMOVE IN 7CYC
GULFWAY #2 TRANSFORMER, NORMAL CLEARING
FILE: C:\SPP PID-217\GW-GULFWAY-2.out

TUE, JUL 29 2008 10:32
PG 14: ANGLE



PLOTS
TABLE V1-2B FAULT CASES SIMULATED IN THIS STUDY:
FAULTS WITH STUCK BREAKER CONDITIONS


FAULT REFERENC NO. 1
FAULT-SABINE-STUCK BKR –VFW12- LOCATION GULFWAY



GW
GW-SABINE, STUCK BRAK CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-SABINE, STUCK BRAK CONDS (VFW12)

FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out

1.2000	CHNL# 11: CVOLT 334431 CG1SABIN	20.000	→-----→	0.20000
1.2000	CHNL# 9: CVOLT 334441 CG5SABIN	24.000	x-----x	0.20000
1.2000	CHNL# 7: CVOLT 334440 CG4SABIN	24.000	+-----+	0.20000
1.2000	CHNL# 5: CVOLT 334036 CPID 217	13.800	◆-----◆	0.20000
1.2000	CHNL# 3: CVOLT 334035 CGULFWAYA	69.000	←-----←	0.20000
1.2000	CHNL# 1: CVOLT 334034 CGULFWAY	230.00	□-----□	0.20000




THU, JUL 31 2008 15:31
PG 1: VOLTAGE



GW
 GW-SABINE, STUCK BRAK CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-SABINE, STUCK BRAK CONDS (VFW12)

FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out

1.2000	CHNL# 20: CVDLT 334414 C4LINDE	138.0000	→-----→	0.20000
1.2000	CHNL# 19: CVDLT 334413 C4PNEC BK	138.0000	X-----X	0.20000
1.2000	CHNL# 18: CVDLT 334399 C4NECHESO	138.0000	+-----+	0.20000
1.2000	CHNL# 17: CVDLT 334398 C4HAMPTDN	138.0000	◆-----◆	0.20000
1.2000	CHNL# 15: CVDLT 334433 C63SABIN	22.0000	←-----←	0.20000
1.2000	CHNL# 13: CVDLT 334432 C62SABIN	20.0000	□-----□	0.20000




THU, JUL 31 2008 15:31
 PG 2: VOLTAGE



GW
GW-SABINE, STUCK BRAK CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-SABINE, STUCK BRAK CONDS (VFW12)
FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out

THU, JUL 31 2008 15:31
PG 3: VOLTAGE

Time (s)	Channel	Value	Symbol	Scale
1.2000	CHNL# 25: CVOLT 334453 C4COW 13	138.00	X	0.20000
1.2000	CHNL# 24: CVOLT 334450 C4ORANGE	138.00	+	0.20000
1.2000	CHNL# 23: CVOLT 335071 C6BTHREE	230.00	◆	0.20000
1.2000	CHNL# 22: CVOLT 334364 C6GEOTOWN	230.00	◄	0.20000
1.2000	CHNL# 21: CVOLT 334204 C6CHINA	230.00	□	0.20000






GW
GW-SABINE, STUCK BRKA CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-SABINE, STUCK BRKA CONDS (VFW12)

FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out
CHNL# 31: CFREQ 334431 CG1SABIN 20.000]]*60+60

61.000				→-----→	59.000
	CHNL# 30: CFREQ 334441 CG5SABIN	24.000]]*60+60			
61.000				x-----x	59.000
	CHNL# 29: CFREQ 334440 CG4SABIN	24.000]]*60+60			
61.000				+-----+	59.000
	CHNL# 28: CFREQ 334036 CPID 217	13.800]]*60+60			
61.000				◊-----◊	59.000
	CHNL# 27: CFREQ 334035 CGULFWAYA	69.000]]*60+60			
61.000				←-----←	59.000
	CHNL# 26: CFREQ 334034 CGULFWAY	230.000]]*60+60			
61.000				▣-----▣	59.000




THU, JUL 31 2008 15:31
PG 4: FREQUENCY



GW
 GW-SABINE, STUCK BRAK CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-SABINE, STUCK BRAK CONDS (VFW12)

FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out
 CHNL# 37: CFREQ 334414 C4LINDE 138.0000x60+60

61.000										59.000
61.000	CHNL# 36: CFREQ 334413 C4PNEC BK	138.0000x60+60								59.000
61.000	CHNL# 35: CFREQ 334399 C4NECHESO	138.0000x60+60								59.000
61.000	CHNL# 34: CFREQ 334398 C4HAMPTDN	138.0000x60+60								59.000
61.000	CHNL# 33: CFREQ 334433 C63SABIN	22.0000x60+60								59.000
61.000	CHNL# 32: CFREQ 334432 C625SABIN	20.0000x60+60								59.000




THU, JUL 31 2008 15:31
 PG 5: FREQUENCY



GW
 GW-SABINE, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-SABINE, STUCK BRKR CONDS (VFW12)
 FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out

THU, JUL 31 2008 15:31
 PG 6: FREQUENCY

61.000	CHNL# 42: CFREQ 334453 C4COW 13	138.0000*60+60	x-----x	59.000
61.000	CHNL# 41: CFREQ 334450 C4ORANGE	138.0000*60+60	+-----+	59.000
61.000	CHNL# 40: CFREQ 335071 C6BTHREE	230.0000*60+60	o-----o	59.000
61.000	CHNL# 39: CFREQ 334364 C6GEOTOWN	230.0000*60+60	o-----o	59.000
61.000	CHNL# 38: CFREQ 334204 C6CHINA	230.0000*60+60	o-----o	59.000






GW
 GW-SABINE, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-SABINE, STUCK BRKR CONDS (VFW12)

FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out

250.00	CHNL# 12: CANGL 334431 CG1SABIN	20.0000	→-----→	0.0
250.00	CHNL# 10: CANGL 334441 CG5SABIN	24.0000	X-----X	0.0
250.00	CHNL# 8: CANGL 334440 CG4SABIN	24.0000	+-----+	0.0
250.00	CHNL# 6: CANGL 334036 CPID 217	13.8000	◆-----◆	0.0
250.00	CHNL# 4: CANGL 334035 CGULFWAYA	69.0000	←-----←	0.0
250.00	CHNL# 2: CANGL 334034 CGULFWAY	230.0000	□-----□	0.0




THU, JUL 31 2008 15:31
 PG 7: ANGLE



GW
GW-SABINE, STUCK BRKA CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-SABINE, STUCK BRKA CONDS (VFW12)

FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out

250.00	CHNL# 46: CANGL BUS 334033 MACH '1 'J	0.0
250.00	CHNL# 45: CANGL BUS 334032 MACH '1 'J	0.0
250.00	CHNL# 44: CANGL BUS 334031 MACH '1 'J	0.0
250.00	CHNL# 43: CANGL BUS 334030 MACH '1 'J	0.0
250.00	CHNL# 16: CANGL 334433 CG3SABIN 22.000JJ	0.0
250.00	CHNL# 14: CANGL 334432 CG25ABIN 20.000JJ	0.0




THU, JUL 31 2008 15:31
PG 8: ANGLE



GW
 GW-SABINE, STUCK BRAK COND
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-SABINE, STUCK BRAK COND (VFW12)

FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out

250.00	CHNL# 52: C ANGL BUS 334335 MACH '1 'J	0.0
250.00	CHNL# 51: C ANGL BUS 334299 MACH '1 'J	0.0
250.00	CHNL# 50: C ANGL BUS 334298 MACH '1 'J	0.0
250.00	CHNL# 49: C ANGL BUS 334282 MACH '1 'J	0.0
250.00	CHNL# 48: C ANGL BUS 334071 MACH '1 'J	0.0
250.00	CHNL# 47: C ANGL BUS 334070 MACH '1 'J	0.0




THU, JUL 31 2008 15:31
 PG 9: ANGLE



GW
GW-SABINE, STUCK BRAK CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-SABINE, STUCK BRAK CONDS (VFW12)

FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out

250.00	CHNL# 58: [ANGL BUS 334393 MACH '1 ']	0.0
250.00	CHNL# 57: [ANGL BUS 334392 MACH '1 ']	0.0
250.00	CHNL# 56: [ANGL BUS 334377 MACH '1 ']	0.0
250.00	CHNL# 55: [ANGL BUS 334376 MACH '1 ']	0.0
250.00	CHNL# 54: [ANGL BUS 334375 MACH '1 ']	0.0
250.00	CHNL# 53: [ANGL BUS 334374 MACH '1 ']	0.0




THU, JUL 31 2008 15:31
PG 10: ANGLE



GW
 GW-SABINE, STUCK BRKA CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-SABINE, STUCK BRKA CONDS (VFW12)

FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out

250.00	CHNL# 64: CANGL BUS 33473B MACH '1 'J	→-----→	0.0
250.00	CHNL# 63: CANGL BUS 334467 MACH '1 'J	x-----x	0.0
250.00	CHNL# 62: CANGL BUS 334458 MACH '1 'J	+-----+	0.0
250.00	CHNL# 61: CANGL BUS 334457 MACH '1 'J	◆-----◆	0.0
250.00	CHNL# 60: CANGL BUS 334456 MACH '1 'J	←-----←	0.0
250.00	CHNL# 59: CANGL BUS 334394 MACH '1 'J	□-----□	0.0




THU, JUL 31 2008 15:31
 PG 11: ANGLE



GW
GW-SABINE, STUCK BRAK CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-SABINE, STUCK BRAK CONDS (VFW12)

FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out

250.00	CHNL# 70: CANG BUS 335177 MACH '4 'J	0.0
250.00	CHNL# 69: CANG BUS 335137 MACH '2 'J	0.0
250.00	CHNL# 68: CANG BUS 335076 MACH '1 'J	0.0
250.00	CHNL# 67: CANG BUS 335075 MACH '1 'J	0.0
250.00	CHNL# 66: CANG BUS 334740 MACH '1 'J	0.0
250.00	CHNL# 65: CANG BUS 334739 MACH '1 'J	0.0




THU, JUL 31 2008 15:31
PG 12: ANGLE



GW
GW-SABINE, STUCK BRAK CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-SABINE, STUCK BRAK CONDS (VFW12)

FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out

250.00	CHNL# 76: C ANGL BUS 335204 MACH '1 'J	0.0
250.00	CHNL# 75: C ANGL BUS 335203 MACH '1 'J	0.0
250.00	CHNL# 74: C ANGL BUS 335202 MACH '1 'J	0.0
250.00	CHNL# 73: C ANGL BUS 335201 MACH '1 'J	0.0
250.00	CHNL# 72: C ANGL BUS 335179 MACH '6 'J	0.0
250.00	CHNL# 71: C ANGL BUS 335178 MACH '5 'J	0.0




THU, JUL 31 2008 15:31
PG 13: ANGLE



GW
GW-SABINE, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-SABINE, STUCK BRKR CONDS (VFW12)
FILE: C:\SPP PID-217\GW-Sabine-SB2_9.out

THU, JUL 31 2008 15:31
PG 14: ANGLE




FAULT REFERENCE NO. 2
FAULT-VFWPARK-STUCK BKR-VFW12- LOCATION GULFWAY



GW
GW-VFW PARK, STUCK BRAK CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-VFWPK, STUCK BRAK CONDS (VFW12)

FILE: C:\SPP PID-217\GW-VFWPK-SB_9.out

1.2000	CHNL# 11: CVOLT 334431 CG1SABIN	20.0000	→-----→	0.20000
1.2000	CHNL# 9: CVOLT 334441 CG5SABIN	24.0000	x-----x	0.20000
1.2000	CHNL# 7: CVOLT 334440 CG4SABIN	24.0000	+-----+	0.20000
1.2000	CHNL# 5: CVOLT 334036 CPID 217	19.8000	◆-----◆	0.20000
1.2000	CHNL# 3: CVOLT 334035 CGULFWAYA	69.0000	←-----←	0.20000
1.2000	CHNL# 1: CVOLT 334034 CGULFWAY	230.0000	□-----□	0.20000




THU, JUL 31 2008 15:25
PG 1: VOLTAGE



GW
GW-VFW PARK, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-VFWPK, STUCK BRKR CONDS (VFW12)

FILE: C:\SPP PID-217\GW-VFWPK-SB_9.out

1.2000	CHNL# 20: CVDLT 334414 C4LINDE	138.0000	→-----→	0.20000
1.2000	CHNL# 19: CVDLT 334413 C4PNEC BK	138.0000	x-----x	0.20000
1.2000	CHNL# 18: CVDLT 334399 C4NECHESO	138.0000	+-----+	0.20000
1.2000	CHNL# 17: CVDLT 334398 C4HAMPTON	138.0000	◆-----◆	0.20000
1.2000	CHNL# 15: CVDLT 334433 CG3SABIN	22.0000	←-----←	0.20000
1.2000	CHNL# 13: CVDLT 334432 CG2SABIN	20.0000	□-----□	0.20000




THU, JUL 31 2008 15:25
PG 2: VOLTAGE



GW
 GW-VFW PARK, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-VFWPK, STUCK BRKR CONDS (VFW12)
 FILE: C:\SPP PID-217\GW-VFWPK-SB_9.out

THU, JUL 31 2008 15:25
 PG 3: VOLTAGE

1.2000	CHNL# 25: CVDLT 334453 C4COW 13	138.0000	X-----X	0.20000
1.2000	CHNL# 24: CVDLT 334450 C4ORANGE	138.0000	+-----+	0.20000
1.2000	CHNL# 23: CVDLT 335071 C6BTHREE	230.0000	◆-----◆	0.20000
1.2000	CHNL# 22: CVDLT 334364 C6GEOTOWN	230.0000	←-----←	0.20000
1.2000	CHNL# 21: CVDLT 334204 C6CHINA	230.0000	□-----□	0.20000






GW
 GW-VFW PARK, STUCK BAKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-VFWPK, STUCK BAKR CONDS (VFW12)

FILE: C:\SPP PID-217\GW-VFWPK-SB_9.out

61.000	CHNL# 31: CFREQ 334431 CG1SABIN	20.000	→-----→	59.000
61.000	CHNL# 30: CFREQ 334441 CG5SABIN	24.000	x-----x	59.000
61.000	CHNL# 29: CFREQ 334440 CG4SABIN	24.000	+-----+	59.000
61.000	CHNL# 28: CFREQ 334036 CPID 217	13.800	◆-----◆	59.000
61.000	CHNL# 27: CFREQ 334035 CGULFWAYA	69.000	←-----←	59.000
61.000	CHNL# 26: CFREQ 334034 CGULFWAY	230.000	□-----□	59.000




THU, JUL 31 2008 15:25
 PG 4: FREQUENCY



GW
 GW-VFW PARK, STUCK BRAK CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-VFWPK, STUCK BRAK CONDS (VFW12)

FILE: C:\SPP PID-217\GW-VFWPK-SB_9.out
 CHNL# 37: CFREQ 334414 C4LINDE 138.0000x60+60

61.000				→-----→	59.000
	CHNL# 36: CFREQ 334413 C4PNEC BK	138.0000	x60+60	X-----X	59.000
61.000				+-----+	59.000
	CHNL# 35: CFREQ 334399 C4NECHESO	138.0000	x60+60	◆-----◆	59.000
61.000				◊-----◊	59.000
	CHNL# 34: CFREQ 334398 C4HAMPTDN	138.0000	x60+60	◄-----◄	59.000
61.000				◻-----◻	59.000
	CHNL# 33: CFREQ 334433 C63SABIN	22.0000	x60+60		
61.000					59.000
	CHNL# 32: CFREQ 334432 C62SABIN	20.0000	x60+60		
61.000					59.000




THU, JUL 31 2008 15:25
 PG 5: FREQUENCY



GW
 GW-VFW PARK, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-VFWPK, STUCK BRKR CONDS (VFW12)
 FILE: C:\SPP PID-217\GW-VFWPK-SB_9.out

THU, JUL 31 2008 15:25
 PG 6: FREQUENCY

61.000	CHNL# 42: CFREQ 334453 C4COW 13 138.0000*60+60	X-----X	59.000
61.000	CHNL# 41: CFREQ 334450 C4ORANGE 138.0000*60+60	+-----+	59.000
61.000	CHNL# 40: CFREQ 335071 C6BTHREE 230.0000*60+60	◆-----◆	59.000
61.000	CHNL# 39: CFREQ 334364 C6GEOTOWN 230.0000*60+60	←-----←	59.000
61.000	CHNL# 38: CFREQ 334204 C6CHINA 230.0000*60+60	□-----□	59.000






GW
 GW-VFW PARK, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-VFWPK, STUCK BRKR CONDS (VFW12)

FILE: C:\SPP PID-217\GW-VFWPK-SB_9.out

250.00	CHNL# 12: CANGL 334431 CG1SABIN	20.0000	→-----→	0.0
250.00	CHNL# 10: CANGL 334441 CG5SABIN	24.0000	X-----X	0.0
250.00	CHNL# 8: CANGL 334440 CG4SABIN	24.0000	+-----+	0.0
250.00	CHNL# 6: CANGL 334036 CPID 217	13.8000	◆-----◆	0.0
250.00	CHNL# 4: CANGL 334035 CGULFWAYA	69.0000	←-----←	0.0
250.00	CHNL# 2: CANGL 334034 CGULFWAY	230.0000	□-----□	0.0




THU, JUL 31 2008 15:25
 PG 7: ANGLE



GW
 GW-VFW PARK, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-VFWPK, STUCK BRKR CONDS (VFW12)

FILE: C:\SPP PID-217\GW-VFWPK-SB_9.out

250.00	CHNL# 46: CANGL BUS 334033 MACH '1 ']	0.0
250.00	CHNL# 45: CANGL BUS 334032 MACH '1 ']	0.0
250.00	CHNL# 44: CANGL BUS 334031 MACH '1 ']	0.0
250.00	CHNL# 43: CANGL BUS 334030 MACH '1 ']	0.0
250.00	CHNL# 16: CANGL 334433 CG3SABIN 22.000]]	0.0
250.00	CHNL# 14: CANGL 334432 CG2SABIN 20.000]]	0.0




THU, JUL 31 2008 15:25
 PG 8: ANGLE



GW
GW-VFW PARK, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-VFWPK, STUCK BRKR CONDS (VFW12)

FILE: C:\SPP PID-217\GW-VFWPK-SB_9.out

250.00	CHNL# 52: CANGL BUS 334335 MACH '1 ']	→-----→	0.0
250.00	CHNL# 51: CANGL BUS 334299 MACH '1 ']	X-----X	0.0
250.00	CHNL# 50: CANGL BUS 334298 MACH '1 ']	+-----+	0.0
250.00	CHNL# 49: CANGL BUS 334282 MACH '1 ']	◆-----◆	0.0
250.00	CHNL# 48: CANGL BUS 334071 MACH '1 ']	←-----←	0.0
250.00	CHNL# 47: CANGL BUS 334070 MACH '1 ']	□-----□	0.0




THU, JUL 31 2008 15:25
PG 9: ANGLE



GW
GW-VFW PARK, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-VFWPK, STUCK BRKR CONDS (VFW12)

FILE: C:\SPP PID-217\GW-VFWPK-SB_9.out

250.00	CHNL# 58: CANGI BUS 334393 MACH '1 'J	0.0
250.00	CHNL# 57: CANGI BUS 334392 MACH '1 'J	0.0
250.00	CHNL# 56: CANGI BUS 334377 MACH '1 'J	0.0
250.00	CHNL# 55: CANGI BUS 334376 MACH '1 'J	0.0
250.00	CHNL# 54: CANGI BUS 334375 MACH '1 'J	0.0
250.00	CHNL# 53: CANGI BUS 334374 MACH '1 'J	0.0




THU, JUL 31 2008 15:25
PG 10: ANGLE



GW
 GW-VFW PARK, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-VFWPK, STUCK BRKR CONDS (VFW12)

FILE: C:\SPP PID-217\GW-VFWPK-SB_9.out

250.00	CHNL# 64: CANGL BUS 334738 MACH '1 ']	→-----→	0.0
250.00	CHNL# 63: CANGL BUS 334467 MACH '1 ']	x-----x	0.0
250.00	CHNL# 62: CANGL BUS 334458 MACH '1 ']	+-----+	0.0
250.00	CHNL# 61: CANGL BUS 334457 MACH '1 ']	◆-----◆	0.0
250.00	CHNL# 60: CANGL BUS 334456 MACH '1 ']	←-----←	0.0
250.00	CHNL# 59: CANGL BUS 334394 MACH '1 ']	□-----□	0.0




THU, JUL 31 2008 15:25
 PG 11: ANGLE



GW
GW-VFW PARK, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-VFWPK, STUCK BRKR CONDS (VFW12)

FILE: C:\SPP PID-217\GW-VFWPK-SB_9.out

250.00	CHNL# 70: C ANGL BUS 335177 MACH '4 'J	0.0
250.00	CHNL# 69: C ANGL BUS 335137 MACH '2 'J	0.0
250.00	CHNL# 68: C ANGL BUS 335076 MACH '1 'J	0.0
250.00	CHNL# 67: C ANGL BUS 335075 MACH '1 'J	0.0
250.00	CHNL# 66: C ANGL BUS 334740 MACH '1 'J	0.0
250.00	CHNL# 65: C ANGL BUS 334739 MACH '1 'J	0.0




THU, JUL 31 2008 15:25
PG 12: ANGLE



GW
 GW-VFW PARK, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-VFWPK, STUCK BRKR CONDS (VFW12)

FILE: C:\SPP PID-217\GW-VFWPK-SB_9.out

250.00	CHNL# 76: CANGL BUS 335204 MACH '1 ']	→-----→	0.0
250.00	CHNL# 75: CANGL BUS 335203 MACH '1 ']	x-----x	0.0
250.00	CHNL# 74: CANGL BUS 335202 MACH '1 ']	+-----+	0.0
250.00	CHNL# 73: CANGL BUS 335201 MACH '1 ']	◆-----◆	0.0
250.00	CHNL# 72: CANGL BUS 335179 MACH '6 ']	←-----←	0.0
250.00	CHNL# 71: CANGL BUS 33517B MACH '5 ']	□-----□	0.0




THU, JUL 31 2008 15:25
 PG 13: ANGLE



GW
GW-VFW PARK, STUCK BAKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-VFWPK, STUCK BAKR CONDS (VFW12)
FILE: C:\SPP PID-217\GW-VFWPK-SB_9.out

THU, JUL 31 2008 15:25
PG 14: ANGLE




FAULT REFERENCE NO. 3
FAULT-KOLBS-STUCK BKR –KOL12- LOCATION GULFWAY



GW
GW-KOLBS, STUCK BRAK CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRAK CONDS (KOL12)

FILE: C:\SPP PID-217\GW-Kolbs-SB_9.out

1.2000	CHNL# 11: CVOLT 334431 CG1SABIN	20.0000	0.20000
1.2000	CHNL# 9: CVOLT 334441 CG5SABIN	24.0000	0.20000
1.2000	CHNL# 7: CVOLT 334440 CG4SABIN	24.0000	0.20000
1.2000	CHNL# 5: CVOLT 334036 CPID 217	13.8000	0.20000
1.2000	CHNL# 3: CVOLT 334035 CGULFWAYA	69.0000	0.20000
1.2000	CHNL# 1: CVOLT 334034 CGULFWAY	230.0000	0.20000




THU, JUL 31 2008 14:43
PG 1: VOLTAGE



GW
GW-KOLBS, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL12)

FILE: C:\SPP PID-217\GW-Kolbs-SB_9.out

1.2000	CHNL# 20: CVOLT 334414 C4LINDE	138.0000	→-----→	0.20000
1.2000	CHNL# 19: CVOLT 334413 C4PNEC BK	138.0000	x-----x	0.20000
1.2000	CHNL# 18: CVOLT 334399 C4NECHESO	138.0000	+-----+	0.20000
1.2000	CHNL# 17: CVOLT 334398 C4HAMPTDN	138.0000	◆-----◆	0.20000
1.2000	CHNL# 15: CVOLT 334433 C63SABIN	22.0000	←-----←	0.20000
1.2000	CHNL# 13: CVOLT 334432 C62SABIN	20.0000	▣-----▣	0.20000



THU, JUL 31 2008 14:43
PG 2: VOLTAGE




GW
 GW-KOLBS, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-KOLBS, STUCK BRKR CONDS (KOL12)

FILE: C:\SPP PID-217\GW-Kolbs-SB_9.out

THU, JUL 31 2008 14:43
 PG 3: VOLTAGE

1.2000	CHNL# 25: CVOLT 334453 C4COW 13	138.0000	x-----x	0.20000
1.2000	CHNL# 24: CVOLT 334450 C4ORANGE	138.0000	+-----+	0.20000
1.2000	CHNL# 23: CVOLT 335071 C6BTHREE	230.0000	◆-----◆	0.20000
1.2000	CHNL# 22: CVOLT 334364 C6GEOTOWN	230.0000	◀-----▶	0.20000
1.2000	CHNL# 21: CVOLT 334204 C6CHINA	230.0000	▣-----▣	0.20000






GW
 GW-KOLBS, STUCK BRAK COND
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-KOLBS, STUCK BRAK COND (KOL12)

FILE: C:\SPP PID-217\GW-Kolbs-SB_9.out

61.000	CHNL# 31: CFREQ 334431 CG1SABIN	20.000]]*60+60	→-----→	59.000
61.000	CHNL# 30: CFREQ 334441 CG5SABIN	24.000]]*60+60	x-----x	59.000
61.000	CHNL# 29: CFREQ 334440 CG4SABIN	24.000]]*60+60	+-----+	59.000
61.000	CHNL# 28: CFREQ 334036 CPID 217	13.800]]*60+60	◆-----◆	59.000
61.000	CHNL# 27: CFREQ 334035 CGULFWAYA	69.000]]*60+60	←-----←	59.000
61.000	CHNL# 26: CFREQ 334034 CGULFWAY	230.000]]*60+60	□-----□	59.000




THU, JUL 31 2008 14:43
 PG 4: FREQUENCY



GW
 GW-KOLBS, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-KOLBS, STUCK BRKR CONDS (KOL12)

FILE: C:\SPP PID-217\GW-Kolbs-SB_9.out

61.000	CHNL# 37: CFREQ 334414 C4LINDE	138.0000	*60+60	59.000
61.000	CHNL# 36: CFREQ 334413 C4PNEC BK	138.0000	*60+60	59.000
61.000	CHNL# 35: CFREQ 334399 C4NECHES0	138.0000	*60+60	59.000
61.000	CHNL# 34: CFREQ 334398 C4HAMPTDN	138.0000	*60+60	59.000
61.000	CHNL# 33: CFREQ 334433 C63SABIN	22.0000	*60+60	59.000
61.000	CHNL# 32: CFREQ 334432 C62SABIN	20.0000	*60+60	59.000



THU, JUL 31 2008 14:43
 PG 5: FREQUENCY




GW
 GW-KOLBS, STUCK BRAK CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-KOLBS, STUCK BRAK CONDS (KOL12)

FILE: C:\SPP PID-217\GW-Kolbs-SB_9.out

THU, JUL 31 2008 14:43
 PG 6: FREQUENCY

61.000	CHNL# 42: CFREQ 334453 C4COW 13	138.0000x60+60	X-----X	59.000
61.000	CHNL# 41: CFREQ 334450 C4ORANGE	138.0000x60+60	+-----+	59.000
61.000	CHNL# 40: CFREQ 335071 C6BTHREE	230.0000x60+60	o-----o	59.000
61.000	CHNL# 39: CFREQ 334364 C6GEOTOWN	230.0000x60+60	o-----o	59.000
61.000	CHNL# 38: CFREQ 334204 C6CHINA	230.0000x60+60	o-----o	59.000






GW
 GW-KOLBS, STUCK BRAK COND
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-KOLBS, STUCK BRAK COND (KOL12)

FILE: C:\SPP PID-217\GW-Kolbs-SB_9.out

250.00	CHNL# 12: CANGL 334431 CG1SABIN	20.0000	0.0
250.00	CHNL# 10: CANGL 334441 CG5SABIN	24.0000	0.0
250.00	CHNL# 8: CANGL 334440 CG4SABIN	24.0000	0.0
250.00	CHNL# 6: CANGL 334036 CPID 217	13.8000	0.0
250.00	CHNL# 4: CANGL 334035 CGULFWAYA	69.0000	0.0
250.00	CHNL# 2: CANGL 334034 CGULFWAY	230.0000	0.0




THU, JUL 31 2008 14:43
 PG 7: ANGLE



GW
 GW-KOLBS, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-KOLBS, STUCK BRKR CONDS (KOL12)

FILE: C:\SPP PID-217\GW-Kolbs-SB_9.out

250.00	CHNL# 46: CANGL BUS 334033 MACH '1 ']	0.0
250.00	CHNL# 45: CANGL BUS 334032 MACH '1 ']	0.0
250.00	CHNL# 44: CANGL BUS 334031 MACH '1 ']	0.0
250.00	CHNL# 43: CANGL BUS 334030 MACH '1 ']	0.0
250.00	CHNL# 16: CANGL 334433 CG3SABIN 22.000]]	0.0
250.00	CHNL# 14: CANGL 334432 CG2SABIN 20.000]]	0.0




THU, JUL 31 2008 14:43
 PG 8: ANGLE



GW
GW-KOLBS, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL12)

FILE: C:\SPP PID-217\GW-Kolbs-SB_9.out

250.00	CHNL# 52: C ANGL BUS 334335 MACH '1 'J	0.0
250.00	CHNL# 51: C ANGL BUS 334299 MACH '1 'J	0.0
250.00	CHNL# 50: C ANGL BUS 334298 MACH '1 'J	0.0
250.00	CHNL# 49: C ANGL BUS 334282 MACH '1 'J	0.0
250.00	CHNL# 48: C ANGL BUS 334071 MACH '1 'J	0.0
250.00	CHNL# 47: C ANGL BUS 334070 MACH '1 'J	0.0




THU, JUL 31 2008 14:43
PG 9: ANGLE



GW
GW-KOLBS, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL12)

FILE: C:\SPP PID-217\GW-Kolbs-SB_9.out

250.00	CHNL# 58: CANGL BUS 334393 MACH '1 'J	0.0
250.00	CHNL# 57: CANGL BUS 334392 MACH '1 'J	0.0
250.00	CHNL# 56: CANGL BUS 334377 MACH '1 'J	0.0
250.00	CHNL# 55: CANGL BUS 334376 MACH '1 'J	0.0
250.00	CHNL# 54: CANGL BUS 334375 MACH '1 'J	0.0
250.00	CHNL# 53: CANGL BUS 334374 MACH '1 'J	0.0




THU, JUL 31 2008 14:43
PG 10: ANGLE



GW
 GW-KOLBS, STUCK BRAK COND
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-KOLBS, STUCK BRAK COND (KOL12)

FILE: C:\SPP PID-217\GW-Kolbs-SB_9.out

250.00	CHNL# 64: C ANGL BUS 334738 MACH '1 'J	0.0
250.00	CHNL# 63: C ANGL BUS 334467 MACH '1 'J	0.0
250.00	CHNL# 62: C ANGL BUS 334458 MACH '1 'J	0.0
250.00	CHNL# 61: C ANGL BUS 334457 MACH '1 'J	0.0
250.00	CHNL# 60: C ANGL BUS 334456 MACH '1 'J	0.0
250.00	CHNL# 59: C ANGL BUS 334394 MACH '1 'J	0.0




THU, JUL 31 2008 14:43
 PG 11: ANGLE



GW
GW-KOLBS, STUCK BAKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BAKR CONDS (KOL12)

FILE: C:\SPP PID-217\GW-Kolbs-SB_9.out

250.00	CHNL# 70: [ANGL BUS 335177 MACH '4 ']	0.0
250.00	CHNL# 69: [ANGL BUS 335137 MACH '2 ']	0.0
250.00	CHNL# 68: [ANGL BUS 335076 MACH '1 ']	0.0
250.00	CHNL# 67: [ANGL BUS 335075 MACH '1 ']	0.0
250.00	CHNL# 66: [ANGL BUS 334740 MACH '1 ']	0.0
250.00	CHNL# 65: [ANGL BUS 334739 MACH '1 ']	0.0




THU, JUL 31 2008 14:43
PG 12: ANGLE



GW
GW-KOLBS, STUCK BRAK COND
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRAK COND (KOL12)

FILE: C:\SPP PID-217\GW-Kolbs-SB_9.out

250.00	CHNL# 76: C ANGL BUS 335204 MACH '1 'J	→	0.0
250.00	CHNL# 75: C ANGL BUS 335203 MACH '1 'J	x	0.0
250.00	CHNL# 74: C ANGL BUS 335202 MACH '1 'J	+	0.0
250.00	CHNL# 73: C ANGL BUS 335201 MACH '1 'J	◊	0.0
250.00	CHNL# 72: C ANGL BUS 335179 MACH '6 'J	←	0.0
250.00	CHNL# 71: C ANGL BUS 335178 MACH '5 'J	□	0.0




THU, JUL 31 2008 14:43
PG 13: ANGLE




GW
GW-KOLBS, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL12)
FILE: C:\SPP PID-217\GW-Kolbs-SB_9.out

THU, JUL 31 2008 14:43
PG 14: ANGLE




FAULT REFERENCE NO. 4
FAULT-KOLBS2-STUCK BKR –KOL34- LOCATION GULFWAY



CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL34)

FILE: C:\SPP PID-217\GW-kolbs-SBkol34_9.out

1.2000	CHNL# 11: CVOLT 334431 CG1SABIN	20.0000	→-----→	0.20000
1.2000	CHNL# 9: CVOLT 334441 CG5SABIN	24.0000	x-----x	0.20000
1.2000	CHNL# 7: CVOLT 334440 CG4SABIN	24.0000	+-----+	0.20000
1.2000	CHNL# 5: CVOLT 334036 CPID 217	13.8000	◆-----◆	0.20000
1.2000	CHNL# 3: CVOLT 334035 CGULFWAYA	69.0000	←-----←	0.20000
1.2000	CHNL# 1: CVOLT 334034 CGULFWAY	230.0000	□-----□	0.20000




THU, JUL 31 2008 14:43
PG 1: VOLTAGE



CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL34)

FILE: C:\SPP PID-217\GW-kolbs-SBkol34_9.out

1.2000	CHNL# 20: CVOLT 334414 C4LINDE	138.0000	→-----→	0.20000
1.2000	CHNL# 19: CVOLT 334413 C4PNEC BK	138.0000	x-----x	0.20000
1.2000	CHNL# 18: CVOLT 334399 C4NECHESO	138.0000	+-----+	0.20000
1.2000	CHNL# 17: CVOLT 334398 C4HAMPTDN	138.0000	◆-----◆	0.20000
1.2000	CHNL# 15: CVOLT 334433 C63SABIN	22.0000	←-----←	0.20000
1.2000	CHNL# 13: CVOLT 334432 C625ABIN	20.0000	□-----□	0.20000



THU, JUL 31 2008 14:43
PG 2: VOLTAGE




CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-KOLBS, STUCK BRKR CONDS (KOL34)

FILE: C:\SPP PID-217\GW-kolbs-SBkol34_9.out

THU, JUL 31 2008 14:43
 PG 3: VOLTAGE

1.2000	CHNL# 25: CVOLT 334453 C4COW 13 130.00]]	X-----X	0.20000
1.2000	CHNL# 24: CVOLT 334450 C4ORANGE 130.00]]	+-----+	0.20000
1.2000	CHNL# 23: CVOLT 335071 C6BTHREE 230.00]]	◆-----◆	0.20000
1.2000	CHNL# 22: CVOLT 334364 C6GEOTOWN 230.00]]	◄-----►	0.20000
1.2000	CHNL# 21: CVOLT 334204 C6CHINA 230.00]]	▣-----▣	0.20000






CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL34)

FILE: C:\SPP PID-217\GW-kolbs-SBkol34_9.out

61.000	CHNL# 31: CFREQ 334431 CG1SABIN	20.000	→-----→	59.000
61.000	CHNL# 30: CFREQ 334441 CG5SABIN	24.000	X-----X	59.000
61.000	CHNL# 29: CFREQ 334440 CG4SABIN	24.000	+-----+	59.000
61.000	CHNL# 28: CFREQ 334036 CPID 217	13.800	◆-----◆	59.000
61.000	CHNL# 27: CFREQ 334035 CGULFWAYA	69.000	←-----←	59.000
61.000	CHNL# 26: CFREQ 334034 CGULFWAY	230.00	▣-----▣	59.000




THU, JUL 31 2008 14:43
PG 4: FREQUENCY



CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL34)

FILE: C:\SPP PID-217\GW-kolbs-SBkol34_9.out

61.000	CHNL# 37: CFREQ 334414 C4LINDE	138.0000]x60+60	59.000
61.000	CHNL# 36: CFREQ 334413 C4PNEC BK	138.0000]x60+60	59.000
61.000	CHNL# 35: CFREQ 334399 C4NECHESO	138.0000]x60+60	59.000
61.000	CHNL# 34: CFREQ 334398 C4HAMPTON	138.0000]x60+60	59.000
61.000	CHNL# 33: CFREQ 334433 C63SABIN	22.0000]x60+60	59.000
61.000	CHNL# 32: CFREQ 334432 C62SABIN	20.0000]x60+60	59.000




THU, JUL 31 2008 14:43
PG 5: FREQUENCY



CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL34)

FILE: C:\SPP PID-217\GW-kolbs-SBkol34_9.out

61.000	CHNL# 42: CFREQ 334453 C4COW 13	138.0000*60+60	X-----X	59.000
61.000	CHNL# 41: CFREQ 334450 C4ORANGE	138.0000*60+60	+-----+	59.000
61.000	CHNL# 40: CFREQ 335071 C6BTHREE	230.0000*60+60	◆-----◆	59.000
61.000	CHNL# 39: CFREQ 334364 C6GEOTOWN	230.0000*60+60	◀-----▶	59.000
61.000	CHNL# 38: CFREQ 334204 C6CHINA	230.0000*60+60	□-----□	59.000




THU, JUL 31 2008 14:43
PG 6: FREQUENCY



CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL34)

FILE: C:\SPP PID-217\GW-kolbs-SBkol34_9.out

250.00	CHNL# 12: CANGL 334431 CG1SABIN	20.0000	→-----→	0.0
250.00	CHNL# 10: CANGL 334441 CG5SABIN	24.0000	x-----x	0.0
250.00	CHNL# 8: CANGL 334440 CG4SABIN	24.0000	+-----+	0.0
250.00	CHNL# 6: CANGL 334036 CPID 217	13.8000	◆-----◆	0.0
250.00	CHNL# 4: CANGL 334035 CGULFWAYA	69.0000	←-----←	0.0
250.00	CHNL# 2: CANGL 334034 CGULFWAY	230.0000	□-----□	0.0




THU, JUL 31 2008 14:43
PG 7: ANGLE



CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL34)

FILE: C:\SPP PID-217\GW-kolbs-SBkol34_9.out

250.00	CHNL# 46: C ANGL BUS 334033 MACH '1 ']	→-----→	0.0
250.00	CHNL# 45: C ANGL BUS 334032 MACH '1 ']	x-----x	0.0
250.00	CHNL# 44: C ANGL BUS 334031 MACH '1 ']	+-----+	0.0
250.00	CHNL# 43: C ANGL BUS 334030 MACH '1 ']	◆-----◆	0.0
250.00	CHNL# 16: C ANGL 334433 [G3SABIN 22.000]]	←-----←	0.0
250.00	CHNL# 14: C ANGL 334432 [G2SABIN 20.000]]	□-----□	0.0




THU, JUL 31 2008 14:43
PG 8: ANGLE



CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL34)

FILE: C:\SPP PID-217\GW-kolbs-SBkol34_9.out

250.00	CHNL# 52: C ANGL BUS 334335 MACH '1 ']	0.0
250.00	CHNL# 51: C ANGL BUS 334299 MACH '1 ']	0.0
250.00	CHNL# 50: C ANGL BUS 334298 MACH '1 ']	0.0
250.00	CHNL# 49: C ANGL BUS 334282 MACH '1 ']	0.0
250.00	CHNL# 48: C ANGL BUS 334071 MACH '1 ']	0.0
250.00	CHNL# 47: C ANGL BUS 334070 MACH '1 ']	0.0




THU, JUL 31 2008 14:43
PG 9: ANGLE



CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL34)

FILE: C:\SPP PID-217\GW-kolbs-SBkol34_9.out

250.00	CHNL# 58: C ANGL BUS 334393 MACH '1 'J	→-----→	0.0
250.00	CHNL# 57: C ANGL BUS 334392 MACH '1 'J	x-----x	0.0
250.00	CHNL# 56: C ANGL BUS 334377 MACH '1 'J	+-----+	0.0
250.00	CHNL# 55: C ANGL BUS 334376 MACH '1 'J	◊-----◊	0.0
250.00	CHNL# 54: C ANGL BUS 334375 MACH '1 'J	←-----←	0.0
250.00	CHNL# 53: C ANGL BUS 334374 MACH '1 'J	□-----□	0.0




THU, JUL 31 2008 14:43
PG 10: ANGLE



CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL34)

FILE: C:\SPP PID-217\GW-kolbs-SBkol34_9.out

250.00	CHNL# 64: CANGI BUS 334738 MACH '1 'J	→-----→	0.0
250.00	CHNL# 63: CANGI BUS 334467 MACH '1 'J	x-----x	0.0
250.00	CHNL# 62: CANGI BUS 334458 MACH '1 'J	+-----+	0.0
250.00	CHNL# 61: CANGI BUS 334457 MACH '1 'J	◆-----◆	0.0
250.00	CHNL# 60: CANGI BUS 334456 MACH '1 'J	←-----←	0.0
250.00	CHNL# 59: CANGI BUS 334394 MACH '1 'J	□-----□	0.0




THU, JUL 31 2008 14:43
PG 11: ANGLE



CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL34)

FILE: C:\SPP PID-217\GW-kolbs-SBkol34_9.out

250.00	CHNL# 70: C ANGL BUS 335177 MACH '4 'J	→-----→	0.0
250.00	CHNL# 69: C ANGL BUS 335137 MACH '2 'J	X-----X	0.0
250.00	CHNL# 68: C ANGL BUS 335076 MACH '1 'J	+-----+	0.0
250.00	CHNL# 67: C ANGL BUS 335075 MACH '1 'J	◆-----◆	0.0
250.00	CHNL# 66: C ANGL BUS 334740 MACH '1 'J	←-----←	0.0
250.00	CHNL# 65: C ANGL BUS 334739 MACH '1 'J	□-----□	0.0




THU, JUL 31 2008 14:43
PG 12: ANGLE



CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL34)

FILE: C:\SPP PID-217\GW-kolbs-SBkol34_9.out

250.00	CHNL# 76: C ANGL BUS 335204 MACH '1 'J	0.0
250.00	CHNL# 75: C ANGL BUS 335203 MACH '1 'J	0.0
250.00	CHNL# 74: C ANGL BUS 335202 MACH '1 'J	0.0
250.00	CHNL# 73: C ANGL BUS 335201 MACH '1 'J	0.0
250.00	CHNL# 72: C ANGL BUS 335179 MACH '6 'J	0.0
250.00	CHNL# 71: C ANGL BUS 335178 MACH '5 'J	0.0




THU, JUL 31 2008 14:43
PG 13: ANGLE



CLEAR LOCAL AND REMOVE IN 10 CYC
GW-KOLBS, STUCK BRKR CONDS (KOL34)
FILE: C:\SPP PID-217\GW-kolbs-SBkol34_9.out

THU, JUL 31 2008 14:43
PG 14: ANGLE




FAULT REFERENCE NO. 5
FAULT-GENR1-STUCK BKR –KOL12- LOCATION GULFWAY GENR1



GW
GW-GENR1, STUCK BRAK COND
CLEAR LOCAL AND REMOVE IN 10CYC
GW-GENR1, STUCK BRAK COND (KOL12)

FILE: C:\SPP PID-217\GW-genr1-KOL12_9.out

1.2000	CHNL# 11: CVOLT 334431 CG1SABIN	20.0000	→-----→	0.20000
1.2000	CHNL# 9: CVOLT 334441 CG5SABIN	24.0000	X-----X	0.20000
1.2000	CHNL# 7: CVOLT 334440 CG4SABIN	24.0000	+-----+	0.20000
1.2000	CHNL# 5: CVOLT 334036 CPID 217	13.8000	◆-----◆	0.20000
1.2000	CHNL# 3: CVOLT 334035 CGULFWAYA	69.0000	←-----←	0.20000
1.2000	CHNL# 1: CVOLT 334034 CGULFWAY	230.0000	□-----□	0.20000




THU, JUL 31 2008 15:23
PG 1: VOLTAGE



GW
GW-GENR1, STUCK BRAK COND
CLEAR LOCAL AND REMOVE IN 10CYC
GW-GENR1, STUCK BRAK COND (KOL12)

FILE: C:\SPP PID-217\GW-genr1-KOL12_9.out

1.2000	CHNL# 20: CVOLT 334414 C4LINDE	138.0000	→-----→	0.20000
1.2000	CHNL# 19: CVOLT 334413 C4PNEC BK	138.0000	x-----x	0.20000
1.2000	CHNL# 18: CVOLT 334399 C4NECHESO	138.0000	+-----+	0.20000
1.2000	CHNL# 17: CVOLT 334398 C4HAMPTDN	138.0000	◆-----◆	0.20000
1.2000	CHNL# 15: CVOLT 334433 CG3SABIN	22.0000	←-----←	0.20000
1.2000	CHNL# 13: CVOLT 334432 CG2SABIN	20.0000	□-----□	0.20000




THU, JUL 31 2008 15:24
PG 2: VOLTAGE



GW
GW-GENR1, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10CYC
GW-GENR1, STUCK BRKR CONDS (KOL12)
FILE: C:\SPP PID-217\GW-genr1-KOL12_9.out

THU, JUL 31 2008 15:24
PG 3: VOLTAGE

1.2000	CHNL# 25: CVOLT 334453 C4COW 13 138.0000	x-----x	0.20000
1.2000	CHNL# 24: CVOLT 334450 C4ORANGE 138.0000	+-----+	0.20000
1.2000	CHNL# 23: CVOLT 335071 C6BTHREE 230.0000	◆-----◆	0.20000
1.2000	CHNL# 22: CVOLT 334364 C6GEOTOWN 230.0000	←-----←	0.20000
1.2000	CHNL# 21: CVOLT 334204 C6CHINA 230.0000	□-----□	0.20000






GW
GW-GENR1, STUCK BRAK COND
CLEAR LOCAL AND REMOVE IN 10CYC
GW-GENR1, STUCK BRAK COND (KOL12)

FILE: C:\SPP PID-217\GW-genr1-KOL12_9.out

61.000	CHNL# 31: CFREQ 334431 CG1SABIN	20.000	→	59.000
61.000	CHNL# 30: CFREQ 334441 CG5SABIN	24.000	x	59.000
61.000	CHNL# 29: CFREQ 334440 CG4SABIN	24.000	+	59.000
61.000	CHNL# 28: CFREQ 334036 CPID 217	13.800	◆	59.000
61.000	CHNL# 27: CFREQ 334035 CGULFWAYA	69.000	←	59.000
61.000	CHNL# 26: CFREQ 334034 CGULFWAY	230.000	□	59.000




THU, JUL 31 2008 15:24
PG 4: FREQUENCY



GW
 GW-GENR1, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10CYC
 GW-GENR1, STUCK BRKR CONDS (KOL12)

FILE: C:\SPP PID-217\GW-genr1-KOL12_9.out

61.000	CHNL# 37: CFREQ 334414 C4LINDE	138.0000*60+60	→-----→	59.000
61.000	CHNL# 36: CFREQ 334413 C4PNEC BK	138.0000*60+60	x-----x	59.000
61.000	CHNL# 35: CFREQ 334399 C4NECHES0	138.0000*60+60	+-----+	59.000
61.000	CHNL# 34: CFREQ 334398 C4HAMPTDN	138.0000*60+60	◆-----◆	59.000
61.000	CHNL# 33: CFREQ 334433 C63SABIN	22.0000*60+60	←-----←	59.000
61.000	CHNL# 32: CFREQ 334432 C62SABIN	20.0000*60+60	□-----□	59.000



THU, JUL 31 2008 15:24
 PG 5: FREQUENCY




GW
 GW-GENR1, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10CYC
 GW-GENR1, STUCK BRKR CONDS (KOL12)

FILE: C:\SPP PID-217\GW-genr1-KOL12_9.out

THU, JUL 31 2008 15:24
 PG 6: FREQUENCY

61.000	CHNL# 42: CFREQ 334453 C4COW 13	138.0000	*-----*	59.000
61.000	CHNL# 41: CFREQ 334450 C4ORANGE	138.0000	+-----+	59.000
61.000	CHNL# 40: CFREQ 335071 C6BTHREE	230.0000	◆-----◆	59.000
61.000	CHNL# 39: CFREQ 334364 C6GEOTOWN	230.0000	◀-----▶	59.000
61.000	CHNL# 38: CFREQ 334204 C6CHINA	230.0000	□-----□	59.000






GW
 GW-GENR1, STUCK BRAK COND
 CLEAR LOCAL AND REMOVE IN 10CYC
 GW-GENR1, STUCK BRAK COND (KOL12)

FILE: C:\SPP PID-217\GW-genr1-KOL12_9.out

250.00	CHNL# 12: CANGL 334431 CG1SABIN	20.000]]	→-----→	0.0
250.00	CHNL# 10: CANGL 334441 CG5SABIN	24.000]]	x-----x	0.0
250.00	CHNL# 8: CANGL 334440 CG4SABIN	24.000]]	+-----+	0.0
250.00	CHNL# 6: CANGL 334036 CPID 217	13.800]]	◆-----◆	0.0
250.00	CHNL# 4: CANGL 334035 CGULFWAYA	69.000]]	←-----←	0.0
250.00	CHNL# 2: CANGL 334034 CGULFWAY	230.00]]	□-----□	0.0




THU, JUL 31 2008 15:24
 PG 7: ANGLE



GW
 GW-GENR1, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10CYC
 GW-GENR1, STUCK BRKR CONDS (KOL12)

FILE: C:\SPP PID-217\GW-genr1-KOL12_9.out

250.00	CHNL# 46: CANGL BUS 334033 MACH '1 ']	→-----→	0.0
250.00	CHNL# 45: CANGL BUS 334032 MACH '1 ']	x-----x	0.0
250.00	CHNL# 44: CANGL BUS 334031 MACH '1 ']	+-----+	0.0
250.00	CHNL# 43: CANGL BUS 334030 MACH '1 ']	◆-----◆	0.0
250.00	CHNL# 16: CANGL 334433 [G3SABIN 22.000]]	←-----←	0.0
250.00	CHNL# 14: CANGL 334432 [G2SABIN 20.000]]	□-----□	0.0




THU, JUL 31 2008 15:24
 PG 8: ANGLE



GW
GW-GENR1, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10CYC
GW-GENR1, STUCK BRKR CONDS (KOL12)

FILE: C:\SPP PID-217\GW-genr1-KOL12_9.out

250.00	CHNL# 52: CANGL BUS 334335 MACH '1 'J	→	0.0
250.00	CHNL# 51: CANGL BUS 334299 MACH '1 'J	x	0.0
250.00	CHNL# 50: CANGL BUS 334298 MACH '1 'J	+	0.0
250.00	CHNL# 49: CANGL BUS 334282 MACH '1 'J	◊	0.0
250.00	CHNL# 48: CANGL BUS 334071 MACH '1 'J	←	0.0
250.00	CHNL# 47: CANGL BUS 334070 MACH '1 'J	□	0.0




THU, JUL 31 2008 15:24
PG 9: ANGLE



GW
GW-GENR1, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10CYC
GW-GENR1, STUCK BRKR CONDS (KOL12)

FILE: C:\SPP PID-217\GW-genr1-KOL12_9.out

250.00	CHNL# 58: CANGL BUS 334393 MACH '1 'J	→-----→	0.0
250.00	CHNL# 57: CANGL BUS 334392 MACH '1 'J	x-----x	0.0
250.00	CHNL# 56: CANGL BUS 334377 MACH '1 'J	+-----+	0.0
250.00	CHNL# 55: CANGL BUS 334376 MACH '1 'J	◆-----◆	0.0
250.00	CHNL# 54: CANGL BUS 334375 MACH '1 'J	←-----←	0.0
250.00	CHNL# 53: CANGL BUS 334374 MACH '1 'J	□-----□	0.0




THU, JUL 31 2008 15:24
PG 10: ANGLE



GW
GW-GENR1, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10CYC
GW-GENR1, STUCK BRKR CONDS (KOL12)

FILE: C:\SPP PID-217\GW-genr1-KOL12_9.out

250.00	CHNL# 64: CANGL BUS 33473B MACH '1 ']	→	0.0
250.00	CHNL# 63: CANGL BUS 334467 MACH '1 ']	x	0.0
250.00	CHNL# 62: CANGL BUS 334458 MACH '1 ']	+	0.0
250.00	CHNL# 61: CANGL BUS 334457 MACH '1 ']	◆	0.0
250.00	CHNL# 60: CANGL BUS 334456 MACH '1 ']	←	0.0
250.00	CHNL# 59: CANGL BUS 334394 MACH '1 ']	□	0.0




THU, JUL 31 2008 15:24
PG 11: ANGLE



GW
 GW-GENR1, STUCK BRAK COND
 CLEAR LOCAL AND REMOVE IN 10CYC
 GW-GENR1, STUCK BRAK COND (KOL12)

FILE: C:\SPP PID-217\GW-genr1-KOL12_9.out

250.00	CHNL# 70: [ANGL BUS 335177 MACH '4 ']	0.0
250.00	CHNL# 69: [ANGL BUS 335137 MACH '2 ']	0.0
250.00	CHNL# 68: [ANGL BUS 335076 MACH '1 ']	0.0
250.00	CHNL# 67: [ANGL BUS 335075 MACH '1 ']	0.0
250.00	CHNL# 66: [ANGL BUS 334740 MACH '1 ']	0.0
250.00	CHNL# 65: [ANGL BUS 334739 MACH '1 ']	0.0




THU, JUL 31 2008 15:24
 PG 12: ANGLE



GW
GW-GENR1, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10CYC
GW-GENR1, STUCK BRKR CONDS (KOL12)

FILE: C:\SPP PID-217\GW-genr1-KOL12_9.out

250.00	CHNL# 76: C ANGL BUS 335204 MACH '1 ']	0.0
250.00	CHNL# 75: C ANGL BUS 335203 MACH '1 ']	0.0
250.00	CHNL# 74: C ANGL BUS 335202 MACH '1 ']	0.0
250.00	CHNL# 73: C ANGL BUS 335201 MACH '1 ']	0.0
250.00	CHNL# 72: C ANGL BUS 335179 MACH '6 ']	0.0
250.00	CHNL# 71: C ANGL BUS 335178 MACH '5 ']	0.0




THU, JUL 31 2008 15:24
PG 13: ANGLE



GW
GW-GENR1, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10CYC
GW-GENR1, STUCK BRKR CONDS (KOL12)
FILE: C:\SPP PID-217\GW-genr1-KOL12_9.out

THU, JUL 31 2008 15:24
PG 14: ANGLE




FAULT REFERECNE NO. 6
FAULT-GENR1-STUCK BKR2 -GEVF12- LOCATION GULFWAY GENR1



GW
GW-GENR1, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR1, STUCK BRKR CONDS (GEVF12)

FILE: C:\SPP PID-217\GW-GENR1-SB2_9.out

1.2000	CHNL# 11: CVOLT 334431 CG1SABIN	20.0000	→-----→	0.20000
1.2000	CHNL# 9: CVOLT 334441 CG5SABIN	24.0000	X-----X	0.20000
1.2000	CHNL# 7: CVOLT 334440 CG4SABIN	24.0000	+-----+	0.20000
1.2000	CHNL# 5: CVOLT 334036 CPID 217	13.8000	◆-----◆	0.20000
1.2000	CHNL# 3: CVOLT 334035 CGULFWAYA	69.0000	←-----←	0.20000
1.2000	CHNL# 1: CVOLT 334034 CGULFWAY	230.0000	□-----□	0.20000




THU, JUL 31 2008 14:43
PG 1: VOLTAGE



GW
GW-GENR1, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR1, STUCK BRKR CONDS (GEVF12)

FILE: C:\SPP PID-217\GW-GENR1-SB2_9.out

1.2000	CHNL# 20: CVDLT 334414 C4LINDE	138.0000	→-----→	0.20000
1.2000	CHNL# 19: CVDLT 334413 C4PNEC BK	138.0000	x-----x	0.20000
1.2000	CHNL# 18: CVDLT 334399 C4NECHESO	138.0000	+-----+	0.20000
1.2000	CHNL# 17: CVDLT 334398 C4HAMPTON	138.0000	◆-----◆	0.20000
1.2000	CHNL# 15: CVDLT 334433 C63SABIN	22.0000	←-----←	0.20000
1.2000	CHNL# 13: CVDLT 334432 C62SABIN	20.0000	□-----□	0.20000




THU, JUL 31 2008 14:43
PG 2: VOLTAGE



GW
 GW-GENR1, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-GENR1, STUCK BRKR CONDS (GEVF12)
 FILE: C:\SPP PID-217\GW-GENR1-SB2_9.out

THU, JUL 31 2008 14:43
 PG 3: VOLTAGE

1.2000	CHNL# 25: CVDLT 334453 C4COW 13	138.0000	X-----X	0.20000
1.2000	CHNL# 24: CVDLT 334450 C4ORANGE	138.0000	+-----+	0.20000
1.2000	CHNL# 23: CVDLT 335071 C6BTHREE	230.0000	◆-----◆	0.20000
1.2000	CHNL# 22: CVDLT 334364 C6GEOTOWN	230.0000	←-----←	0.20000
1.2000	CHNL# 21: CVDLT 334204 C6CHINA	230.0000	□-----□	0.20000






GW
GW-GENR1, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR1, STUCK BRKR CONDS (GEVF12)

FILE: C:\SPP PID-217\GW-GENR1-SB2_9.out
CHNL# 31: CFREQ 334431 CG1SABIN 20.0000]x60+60

61.000				----->	59.000
	CHNL# 30: CFREQ 334441 CG5SABIN	24.0000]]x60+60		x-----x	
61.000					
	CHNL# 29: CFREQ 334440 CG4SABIN	24.0000]]x60+60		+-----+	
61.000					
	CHNL# 28: CFREQ 334036 CPID 217	13.8000]]x60+60		◆-----◆	
61.000					
	CHNL# 27: CFREQ 334035 CGULFWAYA	69.0000]]x60+60		←-----→	
61.000					
	CHNL# 26: CFREQ 334034 CGULFWAY	230.0000]]x60+60		□-----□	
61.000					




THU, JUL 31 2008 14:43
PG 4: FREQUENCY



GW
GW-GENR1, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR1, STUCK BRKR CONDS (GEVF12)

FILE: C:\SPP PID-217\GW-GENR1-SB2_9.out

61.000	CHNL# 37: CFREQ 334414 C4LINDE	138.000]]*60+60	→-----→	59.000
61.000	CHNL# 36: CFREQ 334413 C4PNEC BK	138.000]]*60+60	x-----x	59.000
61.000	CHNL# 35: CFREQ 334399 C4NECHESO	138.000]]*60+60	+-----+	59.000
61.000	CHNL# 34: CFREQ 334398 C4HAMPTDN	138.000]]*60+60	◆-----◆	59.000
61.000	CHNL# 33: CFREQ 334433 CG3SABIN	22.000]]*60+60	←-----←	59.000
61.000	CHNL# 32: CFREQ 334432 CG2SABIN	20.000]]*60+60	□-----□	59.000




THU, JUL 31 2008 14:43
PG 5: FREQUENCY



GW
GW-GENR1, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR1, STUCK BRKR CONDS (GEVF12)
FILE: C:\SPP PID-217\GW-GENR1-SB2_9.out

THU, JUL 31 2008 14:43
PG 6: FREQUENCY

61.000	CHNL# 42: CFREQ 334453 C4COW 13	138.0000x60+60	x-----x	59.000
61.000	CHNL# 41: CFREQ 334450 C4ORANGE	138.0000x60+60	+-----+	59.000
61.000	CHNL# 40: CFREQ 335071 C6BTHREE	230.0000x60+60	o-----o	59.000
61.000	CHNL# 39: CFREQ 334364 C6GEOTOWN	230.0000x60+60	o-----o	59.000
61.000	CHNL# 38: CFREQ 334204 C6CHINA	230.0000x60+60	o-----o	59.000






GW
 GW-GENR1, STUCK BRKA CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-GENR1, STUCK BRKA CONDS (GEVF12)

FILE: C:\SPP PID-217\GW-GENR1-SB2_9.out

250.00	CHNL# 12: CANGL 334431 CG1SABIN	20.0000	→-----→	0.0
250.00	CHNL# 10: CANGL 334441 CG5SABIN	24.0000	x-----x	0.0
250.00	CHNL# 8: CANGL 334440 CG4SABIN	24.0000	+-----+	0.0
250.00	CHNL# 6: CANGL 334036 CPID 217	13.8000	◆-----◆	0.0
250.00	CHNL# 4: CANGL 334035 CGULFWAYA	69.0000	←-----←	0.0
250.00	CHNL# 2: CANGL 334034 CGULFWAY	230.0000	□-----□	0.0




THU, JUL 31 2008 14:43
 PG 7: ANGLE



GW
 GW-GENR1, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-GENR1, STUCK BRKR CONDS (GEVF12)

FILE: C:\SPP PID-217\GW-GENR1-SB2_9.out

250.00	CHNL# 46: [ANGL BUS 334033 MACH '1 ']	0.0
250.00	CHNL# 45: [ANGL BUS 334032 MACH '1 ']	0.0
250.00	CHNL# 44: [ANGL BUS 334031 MACH '1 ']	0.0
250.00	CHNL# 43: [ANGL BUS 334030 MACH '1 ']	0.0
250.00	CHNL# 16: [ANGL 334433 [G3SABIN 22.000]]	0.0
250.00	CHNL# 14: [ANGL 334432 [G25ABIN 20.000]]	0.0




THU, JUL 31 2008 14:43
 PG 8: ANGLE



GW
GW-GENR1, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR1, STUCK BRKR CONDS (GEVF12)

FILE: C:\SPP PID-217\GW-GENR1-SB2_9.out

250.00	CHNL# 52: CANG BUS 334335 MACH '1 ']	→-----→	0.0
250.00	CHNL# 51: CANG BUS 334299 MACH '1 ']	x-----x	0.0
250.00	CHNL# 50: CANG BUS 334298 MACH '1 ']	+-----+	0.0
250.00	CHNL# 49: CANG BUS 334282 MACH '1 ']	◆-----◆	0.0
250.00	CHNL# 48: CANG BUS 334071 MACH '1 ']	←-----←	0.0
250.00	CHNL# 47: CANG BUS 334070 MACH '1 ']	□-----□	0.0




THU, JUL 31 2008 14:43
PG 9: ANGLE



GW
GW-GENR1, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR1, STUCK BRKR CONDS (GEVF12)

FILE: C:\SPP PID-217\GW-GENR1-SB2_9.out

250.00	CHNL# 58: CANGL BUS 334393 MACH '1 'J	→	0.0
250.00	CHNL# 57: CANGL BUS 334392 MACH '1 'J	x	0.0
250.00	CHNL# 56: CANGL BUS 334377 MACH '1 'J	+	0.0
250.00	CHNL# 55: CANGL BUS 334376 MACH '1 'J	◆	0.0
250.00	CHNL# 54: CANGL BUS 334375 MACH '1 'J	←	0.0
250.00	CHNL# 53: CANGL BUS 334374 MACH '1 'J	□	0.0




THU, JUL 31 2008 14:43
PG 10: ANGLE



GW
GW-GENR1, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR1, STUCK BRKR CONDS (GEVF12)

FILE: C:\SPP PID-217\GW-GENR1-SB2_9.out

250.00	CHNL# 64: CANG BUS 334738 MACH '1 'J	→-----→	0.0
250.00	CHNL# 63: CANG BUS 334467 MACH '1 'J	x-----x	0.0
250.00	CHNL# 62: CANG BUS 334458 MACH '1 'J	+-----+	0.0
250.00	CHNL# 61: CANG BUS 334457 MACH '1 'J	◆-----◆	0.0
250.00	CHNL# 60: CANG BUS 334456 MACH '1 'J	←-----←	0.0
250.00	CHNL# 59: CANG BUS 334394 MACH '1 'J	□-----□	0.0




THU, JUL 31 2008 14:43
PG 11: ANGLE



GW
GW-GENR1, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR1, STUCK BRKR CONDS (GEVF12)

FILE: C:\SPP PID-217\GW-GENR1-SB2_9.out

250.00	CHNL# 70: CANGL BUS 335177 MACH '4 ']	0.0
250.00	CHNL# 69: CANGL BUS 335137 MACH '2 ']	0.0
250.00	CHNL# 68: CANGL BUS 335076 MACH '1 ']	0.0
250.00	CHNL# 67: CANGL BUS 335075 MACH '1 ']	0.0
250.00	CHNL# 66: CANGL BUS 334740 MACH '1 ']	0.0
250.00	CHNL# 65: CANGL BUS 334739 MACH '1 ']	0.0



THU, JUL 31 2008 14:43
PG 12: ANGLE



GW
GW-GENR1, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR1, STUCK BRKR CONDS (GEVF12)

FILE: C:\SPP PID-217\GW-GENR1-SB2_9.out

250.00	CHNL# 76: CANGL BUS 335204 MACH '1 'J	→-----→	0.0
250.00	CHNL# 75: CANGL BUS 335203 MACH '1 'J	X-----X	0.0
250.00	CHNL# 74: CANGL BUS 335202 MACH '1 'J	+-----+	0.0
250.00	CHNL# 73: CANGL BUS 335201 MACH '1 'J	◊-----◊	0.0
250.00	CHNL# 72: CANGL BUS 335179 MACH '6 'J	←-----←	0.0
250.00	CHNL# 71: CANGL BUS 335178 MACH '5 'J	□-----□	0.0




THU, JUL 31 2008 14:43
PG 13: ANGLE



GW
GW-GENR1, STUCK BRAK COND
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR1, STUCK BRAK COND (GEVF12)
FILE: C:\SPP PID-217\GW-GENR1-SB2_9.out

THU, JUL 31 2008 14:43
PG 14: ANGLE




FAULT REFERENCE NO. 7
FAULT-GENR2-STUCK BKR2 -VFW34- LOCATION GULFWAY Genr2



GW
GW-GENR2, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR2, STUCK BRKR CONDS (VFW34)

FILE: C:\SPP PID-217\GW-GENR2-SB_9.out

1.2000	CHNL# 11: CVOLT 334431 CG1SABIN	20.0000	→-----→	0.20000
1.2000	CHNL# 9: CVOLT 334441 CG5SABIN	24.0000	x-----x	0.20000
1.2000	CHNL# 7: CVOLT 334440 CG4SABIN	24.0000	+-----+	0.20000
1.2000	CHNL# 5: CVOLT 334036 CPID 217	13.8000	◆-----◆	0.20000
1.2000	CHNL# 3: CVOLT 334035 CGULFWAYA	69.0000	←-----←	0.20000
1.2000	CHNL# 1: CVOLT 334034 CGULFWAY	230.0000	□-----□	0.20000




THU, JUL 31 2008 14:43
PG 1: VOLTAGE



GW
 GW-GENR2, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-GENR2, STUCK BRKR CONDS (VFW34)

FILE: C:\SPP PID-217\GW-GENR2-SB_9.out

1.2000	CHNL# 20: CVDLT 334414 C4LINDE	138.0000	→-----→	0.20000
1.2000	CHNL# 19: CVDLT 334413 C4PNEC BK	138.0000	x-----x	0.20000
1.2000	CHNL# 18: CVDLT 334399 C4NECHESO	138.0000	+-----+	0.20000
1.2000	CHNL# 17: CVDLT 334398 C4HAMPTON	138.0000	◆-----◆	0.20000
1.2000	CHNL# 15: CVDLT 334433 CG3SABIN	22.0000	←-----←	0.20000
1.2000	CHNL# 13: CVDLT 334432 CG2SABIN	20.0000	□-----□	0.20000



THU, JUL 31 2008 14:43
 PG 2: VOLTAGE




GW
 GW-GENR2, STUCK BRAK CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-GENR2, STUCK BRAK CONDS (VFW34)

FILE: C:\SPP PID-217\GW-GENR2-SB_9.out

THU, JUL 31 2008 14:43
 PG 3: VOLTAGE

1.2000	CHNL# 25: CVOLT 334453 C4COW 13 138.00]]	X-----X	0.20000
1.2000	CHNL# 24: CVOLT 334450 C4ORANGE 138.00]]	+-----+	0.20000
1.2000	CHNL# 23: CVOLT 335071 C6BTHREE 230.00]]	◆-----◆	0.20000
1.2000	CHNL# 22: CVOLT 334364 C6GEOTOWN 230.00]]	←-----←	0.20000
1.2000	CHNL# 21: CVOLT 334204 C6CHINA 230.00]]	□-----□	0.20000






GW
GW-GENR2, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR2, STUCK BRKR CONDS (VFW34)

FILE: C:\SPP PID-217\GW-GENR2-SB_9.out

61.000	CHNL# 31: CFREQ 334431 CG1SABIN	20.000]]*60+60	→-----→	59.000
61.000	CHNL# 30: CFREQ 334441 CG5SABIN	24.000]]*60+60	X-----X	59.000
61.000	CHNL# 29: CFREQ 334440 CG4SABIN	24.000]]*60+60	+-----+	59.000
61.000	CHNL# 28: CFREQ 334036 CPID 217	13.800]]*60+60	◆-----◆	59.000
61.000	CHNL# 27: CFREQ 334035 CGULFWAYA	69.000]]*60+60	←-----←	59.000
61.000	CHNL# 26: CFREQ 334034 CGULFWAY	230.00]]*60+60	□-----□	59.000




THU, JUL 31 2008 14:43
PG 4: FREQUENCY



GW
 GW-GENR2, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-GENR2, STUCK BRKR CONDS (VFW34)

FILE: C:\SPP PID-217\GW-GENR2-SB_9.out

61.000	CHNL# 37: CFREQ 334414 C4LINDE	138.0000*60+60	→-----→	59.000
61.000	CHNL# 36: CFREQ 334413 C4PNEC BK	138.0000*60+60	X-----X	59.000
61.000	CHNL# 35: CFREQ 334399 C4NECHESO	138.0000*60+60	+-----+	59.000
61.000	CHNL# 34: CFREQ 334398 C4HAMPTDN	138.0000*60+60	◆-----◆	59.000
61.000	CHNL# 33: CFREQ 334433 CG3SABIN	22.0000*60+60	←-----←	59.000
61.000	CHNL# 32: CFREQ 334432 CG2SABIN	20.0000*60+60	□-----□	59.000




THU, JUL 31 2008 14:43
 PG 5: FREQUENCY



GW
GW-GENR2, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR2, STUCK BRKR CONDS (VFW34)
FILE: C:\SPP PID-217\GW-GENR2-SB_9.out

THU, JUL 31 2008 14:43
PG 6: FREQUENCY

61.000	CHNL# 42: CFREQ 334453 C4COW 13	138.000]x60+60	x-----x	59.000
61.000	CHNL# 41: CFREQ 334450 C4ORANGE	138.000]x60+60	+-----+	59.000
61.000	CHNL# 40: CFREQ 335071 C6BTHREE	230.000]x60+60	◆-----◆	59.000
61.000	CHNL# 39: CFREQ 334364 C6GEOTOWN	230.000]x60+60	◀-----▶	59.000
61.000	CHNL# 38: CFREQ 334204 C6CHINA	230.000]x60+60	□-----□	59.000






GW
 GW-GENR2, STUCK BRKR CONDS
 CLEAR LOCAL AND REMOVE IN 10 CYC
 GW-GENR2, STUCK BRKR CONDS (VFW34)

FILE: C:\SPP PID-217\GW-GENR2-SB_9.out

250.00	CHNL# 12: CANGL 334431 CG1SABIN	20.0000	→-----→	0.0
250.00	CHNL# 10: CANGL 334441 CG5SABIN	24.0000	x-----x	0.0
250.00	CHNL# 8: CANGL 334440 CG4SABIN	24.0000	+-----+	0.0
250.00	CHNL# 6: CANGL 334036 CPID 217	13.8000	◊-----◊	0.0
250.00	CHNL# 4: CANGL 334035 CGULFWAYA	69.0000	←-----←	0.0
250.00	CHNL# 2: CANGL 334034 CGULFWAY	230.0000	□-----□	0.0




THU, JUL 31 2008 14:43
 PG 7: ANGLE



GW
GW-GENR2, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR2, STUCK BRKR CONDS (VFW34)

FILE: C:\SPP PID-217\GW-GENR2-SB_9.out

250.00	CHNL# 46: CANGL BUS 334033 MACH '1 'J	0.0
250.00	CHNL# 45: CANGL BUS 334032 MACH '1 'J	0.0
250.00	CHNL# 44: CANGL BUS 334031 MACH '1 'J	0.0
250.00	CHNL# 43: CANGL BUS 334030 MACH '1 'J	0.0
250.00	CHNL# 16: CANGL 334433 CG3SABIN 22.000J	0.0
250.00	CHNL# 14: CANGL 334432 CG25ABIN 20.000J	0.0




THU, JUL 31 2008 14:43
PG 8: ANGLE



GW
GW-GENR2, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR2, STUCK BRKR CONDS (VFW34)

FILE: C:\SPP PID-217\GW-GENR2-SB_9.out

250.00	CHNL# 52: CANGL BUS 334335 MACH '1 ']	→-----→	0.0
250.00	CHNL# 51: CANGL BUS 334299 MACH '1 ']	x-----x	0.0
250.00	CHNL# 50: CANGL BUS 334298 MACH '1 ']	+-----+	0.0
250.00	CHNL# 49: CANGL BUS 334282 MACH '1 ']	◆-----◆	0.0
250.00	CHNL# 48: CANGL BUS 334071 MACH '1 ']	←-----←	0.0
250.00	CHNL# 47: CANGL BUS 334070 MACH '1 ']	□-----□	0.0




THU, JUL 31 2008 14:43
PG 9: ANGLE



GW
GW-GENR2, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR2, STUCK BRKR CONDS (VFW34)

FILE: C:\SPP PID-217\GW-GENR2-SB_9.out

250.00	CHNL# 58: CANGI BUS 334393 MACH '1 'J	0.0
250.00	CHNL# 57: CANGI BUS 334392 MACH '1 'J	0.0
250.00	CHNL# 56: CANGI BUS 334377 MACH '1 'J	0.0
250.00	CHNL# 55: CANGI BUS 334376 MACH '1 'J	0.0
250.00	CHNL# 54: CANGI BUS 334375 MACH '1 'J	0.0
250.00	CHNL# 53: CANGI BUS 334374 MACH '1 'J	0.0




THU, JUL 31 2008 14:43
PG 10: ANGLE



GW
GW-GENR2, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR2, STUCK BRKR CONDS (VFW34)

FILE: C:\SPP PID-217\GW-GENR2-SB_9.out

250.00	CHNL# 64: CANG BUS 33473B MACH '1 'J	0.0
250.00	CHNL# 63: CANG BUS 334467 MACH '1 'J	0.0
250.00	CHNL# 62: CANG BUS 334458 MACH '1 'J	0.0
250.00	CHNL# 61: CANG BUS 334457 MACH '1 'J	0.0
250.00	CHNL# 60: CANG BUS 334456 MACH '1 'J	0.0
250.00	CHNL# 59: CANG BUS 334394 MACH '1 'J	0.0




THU, JUL 31 2008 14:43
PG 11: ANGLE



GW
GW-GENR2, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR2, STUCK BRKR CONDS (VFW34)

FILE: C:\SPP PID-217\GW-GENR2-SB_9.out

250.00	CHNL# 70: CANGL BUS 335177 MACH '4 ']	→-----→	0.0
250.00	CHNL# 69: CANGL BUS 335137 MACH '2 ']	x-----x	0.0
250.00	CHNL# 68: CANGL BUS 335076 MACH '1 ']	+-----+	0.0
250.00	CHNL# 67: CANGL BUS 335075 MACH '1 ']	◆-----◆	0.0
250.00	CHNL# 66: CANGL BUS 334740 MACH '1 ']	←-----←	0.0
250.00	CHNL# 65: CANGL BUS 334739 MACH '1 ']	□-----□	0.0




THU, JUL 31 2008 14:43
PG 12: ANGLE



GW
GW-GENR2, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR2, STUCK BRKR CONDS (VFW34)

FILE: C:\SPP PID-217\GW-GENR2-SB_9.out

250.00	CHNL# 76: C ANGL BUS 335204 MACH '1 'J	0.0
250.00	CHNL# 75: C ANGL BUS 335203 MACH '1 'J	0.0
250.00	CHNL# 74: C ANGL BUS 335202 MACH '1 'J	0.0
250.00	CHNL# 73: C ANGL BUS 335201 MACH '1 'J	0.0
250.00	CHNL# 72: C ANGL BUS 335179 MACH '6 'J	0.0
250.00	CHNL# 71: C ANGL BUS 335178 MACH '5 'J	0.0



THU, JUL 31 2008 14:43
PG 13: ANGLE



GW
GW-GENR2, STUCK BRKR CONDS
CLEAR LOCAL AND REMOVE IN 10 CYC
GW-GENR2, STUCK BRKR CONDS (VFW34)
FILE: C:\SPP PID-217\GW-GENR2-SB_9.out

THU, JUL 31 2008 14:43
PG 14: ANGLE

