



Manual Wind Curtailment Constraints

Reporting period:

Year: 2012

Month: August

Constraint Name	Curtailment Hours (Last Month)	Curtailment Hours (YTD)
Honey Creek – South Prairie 69 kV (NIPS)		1455
Bush – Cumberland 138 kV (CIN)		921
Monticello – E Winamac 138 kV (NIPS)		481
Marshalltown - Blainstown 115 kV (ALTW)		325
Dundee – Aurora 69 kV (ALTW)		266
Paxton-Watseka 138 kV (AMIL)		251
Dickinson County - Lakefield 161 kV (ALTW)		120
FG 5228 IaScLkNaSjHa (SPP)		107
Boone Jct. TR92 161/69 kV (ALTW)		104
Ellendale - Steele Center 69 kV (ALTW)		104
Red Stone - Tittabawassee 138 kV (CONS)		94
Madelia - Madelia Village 69 kV (ALTW/NSP)		91
Square Butte-Arrowhead Bi Pole Outage (MP)		81
Langdon Area Voltage (OTP)		72
Triboji-WPT2 69 kV (ALTW)		69
Heron Lake – Fulda Jct. 69 kV (ALTW)		68
Goodland 138/69 kV (NIPS)		67
Fernald TR1 161/69 kV(ALTW)		63
Lime Creek TR1 161/69 kV (ALTW)		49
Lime Creek – Emery 161 kV (ALTW)		46

*Report shows the top 20 constraints year to date.

'Curtailment Hours' represents the total number of hours one or more wind nodes were curtailed for the given constraint.

No curtailments among the top 20 for August, 2012.