

Report R164-08

***MHEB Group TSR System Impact Study
Stability Analysis; MH to US Requests***

Prepared for
Midwest ISO

Submitted by:
Douglas R. Brown
Lengcheng Huang
Hari Singh

April 28, 2009

Siemens PTI Project P/21-113318

DRAFT

Siemens Energy, Inc.
Siemens Power Technologies International
400 State Street • P.O. Box 1058
Schenectady, New York 12301-1058 US
Tel: 518-395-5000 • Fax: 518-346-2777
www.usa.siemens.com/PTI

SIEMENS

DRAFT

This page intentionally left blank.

Contents

Legal Notice.....	iii
Executive Summary	v
Section 1 Transient Stability Analysis.....	1-1
1.1 Stability Study Package	1-1
1.2 Power Flow Cases	1-1
1.2.1 Pre-Benchmark Case "Mb0-so15aa".....	1-2
1.2.2 Benchmark Case "MHB-so15aa".....	1-6
1.2.3 TSR Study Cases	1-7
1.3 Contingency Criteria	1-9
1.4 Performance Criteria	1-11
1.5 Simulation Results	1-12
1.5.1 Pre-Benchmark and Benchmark Cases.....	1-12
1.5.2 TSR Study Cases	1-12
Appendix A Stability Power Flow Model Development.....	A-1
A.1 Pre-Benchmark Case	A-1
A.2 Benchmark Case	A-4
A.3 TSR Study Case	A-4
Appendix B Power Flow Summaries.....	B-1
B.1 Pre-Benchmark Case without CapX, MH TSRs or Transmission Upgrade Options.....	B-2
B.2 Benchmark Case without MH TSRs or Transmission Upgrade Options.....	B-4
B.3 Study Case with MH TSRs and Transmission Upgrade Option 1	B-6
B.4 Study Case with MH TSRs and Transmission Upgrade Option 3	B-8
Appendix C Transient Stability Summary Tables	C-1

DRAFT

This page intentionally left blank.

Legal Notice

This document was prepared by Siemens Energy, Inc., Siemens Power Technologies International (Siemens PTI), solely for the benefit of Midwest ISO. Neither Siemens PTI, nor parent corporation or its or their affiliates, nor Midwest ISO, nor any person acting in their behalf (a) makes any warranty, expressed or implied, with respect to the use of any information or methods disclosed in this document; or (b) assumes any liability with respect to the use of any information or methods disclosed in this document.

Any recipient of this document, by their acceptance or use of this document, releases Siemens PTI, its parent corporation and its and their affiliates, and Midwest ISO from any liability for direct, indirect, consequential or special loss or damage whether arising in contract, warranty, express or implied, tort or otherwise, and irrespective of fault, negligence, and strict liability.

DRAFT

DRAFT

This page intentionally left blank.

Executive Summary

At the MH TSR Group Study meeting held on March 27, 2009, the study group provided comments on the power flow cases being developed for stability analysis and requested analysis of benchmark cases without and with CapX 2020 Group 1 projects. This report describes development and analysis of both benchmark cases and the TSR study cases.

Significant model changes since the previous set of models were released include the following:

- Load in North Dakota has been reduced to approximately 80% of summer peak; generation west of NDEX was reduced by a corresponding amount; generator reductions include coal-field generators dispatched above Pmax and wind generation in eastern North Dakota; wind generation in eastern North Dakota was selected based on discussions with the study group that dispatching wind generation in central and western North Dakota tends to stress the system more than dispatching generation further east
- Center-Harvey-Prairie 345 kV line, Center 345-230 kV xfmr #2 and Harvey 345-230 kV xfmr have been purged
- Amount of new transmission service modeled in the study cases has been reduced to 1130 MW; A340 has been granted 7 MW of service and A339 and A406 have been withdrawn

Transient stability analyses have been performed using a model representing off-peak system conditions after Manitoba Hydro's third HVDC bipole goes into service. The analyses were performed using a UIP study package that was updated by the NMORWG in January 2009.

A pre-benchmark case without CapX projects, study TSRs or associated transmission upgrades was developed from the 2015 summer off-peak case in the UIP package. Loading of the MHEX, MWEX and NDEX interfaces was reset in the pre-benchmark case (MHEX = 2175 MW, MWEX = 1525 MW, NDEX=2450 MW). All of the simulated disturbances result in acceptable system performance.

A benchmark case without study TSRs or associated transmission upgrades was developed by adding the CapX 2020 Group 1 projects to the pre-benchmark case. Interface loading was not reset after adding the CapX projects. All of the simulated disturbances result in acceptable system performance.

Two TSR study cases were created by modeling the requested transmission service in the benchmark case along with one of the two transmission upgrade options. Both cases were analyzed assuming that outage of a new 500 kV facility will be accompanied by an HVDC automatic power order reduction at Dorsey.

With upgrade option 1, all of the simulated disturbances result in acceptable system performance. With upgrade option 3, all of the simulated disturbances result in acceptable system performance except for a steady-state voltage violation at the series capacitor on the new Dorsey-King 500 kV line. The new 500 kV line is modeled without shunt reactors and

with the series capacitor at the line midpoint. The pre-contingency voltage at the series capacitor is 1.19 per unit and the steady-state post-contingency voltage is as high as 1.26 per unit. Mitigation for the Option 3 voltage violation might include series compensating the line in two locations instead of at the midpoint, connecting shunt reactors at the line terminals or adding a substation and connection to the 230 kV system near the line's midpoint.

DRAFT

**Section
1**

Transient Stability Analysis

Stability analyses have been performed to evaluate transient stability performance with the Manitoba Hydro TSRs and corresponding transmission upgrade options. Analyses were also performed on two cases without the TSRs or associated transmission upgrades to benchmark the 2015 summer off-peak case from the UIP study package.

1.1 Stability Study Package

Midwest ISO provided a UIP study package that was updated by the NMORWG in January 2009. Manitoba Hydro provided updates required to incorporate the Riel Station Reliability Project and Bipole 3.

1.2 Power Flow Cases

The power flow cases utilized in the stability analysis are listed in Table 1. The cases were developed from the 2015 summer off-peak case ("urg-so15aa.sav") in the UIP package. Case development is summarized in the following sections; additional details are provided in Appendix A.

Loading of the MHEX, MWEX and NDEX interfaces was reset in the pre-benchmark case and allowed to float in the benchmark and study cases.

Table 1: Power Flow Cases

Case ID	Case Description	CapX Projects	Study TSRs and Associated Transmission Upgrades
MB0-so15aa	Pre-Benchmark Case	-	-
MHB-so15aa	Benchmark Case	Group 1 Projects	-
MH1-so15aa	TSR Study Case with Option 1	Group 1 Projects	1130 MW with Upgrade Option 1
MH3-so15aa	TSR Study Case with Option 3	Group 1 Projects	1130 MW with Upgrade Option 3

1.2.1 Pre-Benchmark Case "Mb0-so15aa"

A pre-benchmark case without CapX projects, study TSRs or associated transmission upgrades was developed from the 2015 summer off-peak case in the UIP package as follows:

- 1) Apply response file provided by ATC to update model
- 2) Add Big Stone II (generator and 230 kV outlet)
- 3) Add MTEP projects excluding CapX projects
- 4) Apply miscellaneous updates and corrections
- 5) Add NR generating facilities
- 6) Reduce load in North Dakota to approximately 80% of summer peak and reduce generation west of NDEX by a corresponding amount
- 7) Turn on generation in the GRE and XEL control areas that will be used to sink A388 and A416
- 8) Manitoba Hydro system updates including the addition of Bipole 3. HVDC loading adjusted to maintain export level and prepare to source TSRs at Dorsey in the TSR study cases.
- 9) Apply setexports.ipl to adjust NDEX, MHEX and MWEX to their simultaneous maximum capability. MHEX = 2175 MW, MWEX = 1525 MW, NDEX=2450 MW

The power flow summary for the pre-benchmark case is in Appendix B.1.

1.2.1.1 Big Stone II

Big Stone II is dispatched at 600 MW (net) and is modeled in the pre-benchmark case with the 230 kV outlet facilities:

- Big Stone-Johnson Jct–Morris 230 kV line
- Big Stone-Canby-Granite Falls 230 kV line
- Johnson Jct 230-115 kV transformer
- Canby 230-115 kV transformer

1.2.1.2 Midwest ISO Transmission Expansion Plan 2008 (MTEP08) Projects

Table 2 shows the MTEP08 projects that were added to the pre-benchmark case using response files provided by Midwest ISO.

Table 2: MTEP Projects Added to the Stability Case

PrjID	TO	Project Name
56	XEL	La Crosse Area Capacitor banks
177	ATC LLC	Gardner Park-Highway 22 345 kV line projects
552	XEL/GRE	Mankato 115 kV loop
675	XEL	Eau Claire - Hydro Lane 161 kV Conversion
971	XEL	Convert/Relocate the 69 kV Rush River substation to existing 161 kV line from Pine Lake - Crystal Cave
1021	MP/GRE	Embarass to Tower 115 kV Line
1022	MP/GRE	Embarass to Tower 115 kV Line
1025	SMP	Lake City load serving upgrades
1033	XEL	Osceola - Sand Lake 69 Reconductor
1287	ITCM	Replace Salem 345/161 kV transformer with 448 MVA unit
1288	ATC LLC	Gardner Park-Highway 22 345 kV line projects
1289	OTP/MPC	Winger 230/115 kV Transformer Upgrade
1340	XEL	Rebuild Westgate to Scott County 69 kV to 115 kV
1341	GRE/OTP	Silver Lake 230/41.6 kV transformer
1342	ITCM	Replace Salem 345/161 kV transformer with 448 MVA unit
1345	GRE	Crooked Lake - Enterprise Park 115 kV line
1361	MP/GRE	Badoura-Long Lake 115 kV line
1367	XEL/GRE	Scott County - West Waconia 115
1368	XEL	Three Lakes 115/69 kV substation
1369	XEL	Osceola - Sand Lake 69 Reconductor
1370	XEL	Convert/Relocate the 69 kV Rush River substation to existing 161 kV line from Pine Lake - Crystal Cave
1371	XEL	G238, 37642-02, Increase of generating capacity at Riverside Generating Plant
1373	XEL	Ft. Ridgeley - Searles Jct 115 new line and Searles Jct - New Ulm 69 Reconductor
1380	ITCM	Hrn Lk-Lkfld 161kV Ckt 1 Rbld
1455	XEL	G287, 37642-03. Upgrades for G287
1457	XEL	G287, 37642-03. Upgrades for G287
1473	ITCM	Replace Hazleton 345/161 kV transformer #1 with 335 MVA unit

PrjID	TO	Project Name
1482	XEL	Three Lakes 115/69 kV substation
1487	ITCM	Mason City Armor - Emery North 69 kV line
1489	XEL	Woodbury - Tanners Lake upgrade
1522	ITCM	Marshalltown - Toledo - Belle Plaine - Stoney Point 115 kV line rebuild
1545	XEL/GRE	Mankato 115 kV loop
1548	XEL	La Crosse Area Capacitor banks
1549	XEL	Eau Claire - Hydro Lane 161 kV Conversion
1618	ITCM	Marshalltown - Toledo - Belle Plaine - Stoney Point 115 kV line rebuild
1619	GRE	Badoura - Birch Lake 115 lines
1641	ITCM	Hazleton - Lore - Salem 345 kV line with a Lore 345/161 kV 335 MVA transformer
1645	ATC LLC	Cranberry-Conover 115 kV and Conover-Plains conversion to 138 kV
1739	ITCM	Replace two Hazleton 161/69 kV transformers
1753	ITCM	Lewis Fields 161 kV substation which taps the SwampFX - Coggon 115 kV line
1755	ATC LLC	Morgan - Werner West 345 kV line (includes Clintonville-Werner West 138)
1756	ITCM	Lewis Fields 161 kV substation which taps the SwampFX - Coggon 115 kV line
1758	XEL	Chisago - Apple River
1761	ITCM	Readlyn-Tripoli 69kV Rebuild
1772	XEL	Ironwood 92/34.5 kV transformer #2
1953	MP	Pepin Lake 115/34.5 - Transformer 115/34.5 kV 39 MVA
1954	XEL	Somerset - Stanton 69 kV line 84 MVA
1958	ITCM	Hrn Lk-Lkfld 161kV Ckt 1 Rbld
1959	XEL	Yankee Doodle interconnection
1960	XEL	Woodbury - Tanners Lake upgrade
1961	ITCM	6th Street - Beverly
2091	XEL	Black Dog - Wilson 115 kV #2 Reconductor
2092	XEL	Ft. Ridgeley - Searles Jct 115 new line and Searles Jct - New Ulm 69 Reconductor

1.2.1.3 Miscellaneous Updates and Corrections

Table 3 shows miscellaneous model updates and corrections.

Table 3: Miscellaneous Updates and Corrections

Area	Description
ATC	ATC footprint updates
GRE	MISO-PROJECT-KRMRLK(53801)
GRE	MISO-PROJECT-LWRNCTP(20138)
MP	MISO-Dunka-Load
MP	MISO-PROJECT-LL-BAD-PINE-PEQ
MP	Add MN Steel load and transmission
MP	GNET Unit 3 at Cloquet (bus 61668)
OTP	Put Buffalo-CSLTNET 115 kV line in service
OTP	Put Running 230/69 kV xfmr 1 in service
OTP	Put Moranville 230/115 kV xfmr 1 in service
OTP	Purge Center-Harvey-Prairie 345 kV line, Center 345-230 kV xfmr #2 and Harvey 345-230 kV xfmr
XEL	GNET Unit 1 at Chandler (bus 62710)

1.2.1.4 Midwest ISO Network Resource Generation

The NR generating facilities listed in Table 4 were added to the pre-benchmark case.

Table 4: Midwest ISO NR Generation Added to the Stability Case

MISO Project Number	MISO Queue Number	MISO Queue Date	Control Area	County	Point of Interconnection	Max Output (MW)	Dispatch (MW)
G519	38491-01	19-May-05	MP	Itasca, MN	Blackberry 230/115kV Substation	600	600
G618	38818-02	4/11/2006	OTP	Yellow Medicine, MN	Burr Jct to Toronto 115 kV line located 5 miles from Camby	138	27.6
G904	39388-01	11/2/2007	Xcel	Rolette, ND	Rugby-Glenboro 230kV	150	30
G930	39426-03	10-Dec-07	XEL	Sherburne, MN	Sherco Substation	120	120

1.2.1.5 North Dakota Load

Load in North Dakota was reduced by 540 MW to approximately 80% of summer peak. Generation west of NDEX was reduced by a corresponding amount:

- North Dakota coal field generation dispatched above Pmax was reduced to Pmax (90 MW reduction)
- Big Stone Unit 1 reduced to Pmax (20 MW reduction)
- Wind generation in eastern North Dakota turned off at Ashtabula, Edgley and Langdon (430 MW reduction)

1.2.1.6 Manitoba Hydro (MH) System Updates

The following transmission and generating facilities were added to the pre-benchmark case to update the MH system representation and to ensure adequate generation reserves are available for sourcing the study TSRs:

- Bipole 3 and associated facilities at Riel
- Dorsey-Riel 500 kV circuit #2
- Dorsey-Portage 230 kV 2nd line
- Laverendrye-St Vital 230 kV line
- Letellier-St Vital 230 kV line
- Keeyask generating plant (7 x 90 MW)
- Conawapa generating plant (10 x 130 MW)

1.2.2 Benchmark Case "MHB-so15aa"

A benchmark case without study TSRs or associated transmission upgrades was developed from the pre-benchmark case described in Section 1 as follows:

- 1) Add Big Stone 345 kV outlet facilities
- 2) Add CapX 2020 Group 1 projects

Interface loading was not reset in the benchmark case. The power flow summary for the benchmark case is in Appendix B.2.

1.2.2.1 Big Stone 345 kV Outlet Facilities

Big Stone II is modeled in the benchmark case with 345 kV outlet facilities:

- Big Stone - Johnson Jct-Morris 230 kV line
- Big Stone 345- 230 kV transformers
- Big Stone-Canby 345 line
- Canby 345-115 kV xfmr
- Canby-Hazel Run 345 line
- 2 Hazel Run 345/230 kV xfmr
- Hazel Run 230/115 kV xfmr
- Hazel Run-Granite Falls 230 kV line
- Hazel Run-Minn Valley 230 kV line
- Johnson Jct 230-115 kV transformer

1.2.2.2 CapX 2020 Group 1 Projects

Table 5 shows the CapX 2020 Group 1 projects that were added to the benchmark case using response files provided by Midwest ISO.

Table 5: CapX 2020 Group 1 Projects Added to the Benchmark Case

PrjID	TO	Project Name
279	MPC, XEL, OTP, MP	CapX Bemidji-Grand Rapids 230 kV Line
286	GRE, XEL, OTP, MP, MRES	CapX Fargo, ND - St Cloud/Monticello, MN area 345 kV project
1024	XEL, DPC, RPU, SMP, WPPI	CapX SE Twin Cities - Rochester, MN - LaCrosse, WI 345 kV project
1203	XEL, GRE	CapX Brookings, SD - SE Twin Cities 345 kV project

1.2.3 TSR Study Cases

Two TSR study cases were created by modeling the requested transmission service in the benchmark case along with one of the two transmission upgrade options.

- 1) Increase loading on MH bipoles 1 and 2 and make corresponding changes to MH generation schedule at Conawapa and Keeyask
- 2) Adjust US generation to sink study TSRs
- 3) Add transmission upgrade option

Power flow summaries and diagrams for each study case are in Appendix B.

1.2.3.1 Source and Sinks for Study TSRs

The TSR source is the Dorsey inverter station and the 1130 MW aggregate study TSRs were sourced by increasing the injection from bipoles 1 and 2 from approximately 1700 MW in the benchmark case to 3245 MW in the study case and reducing the injection from bipole 3 from 1540 MW to 1130 MW. The study TSRs were sunk using the generators shown in Table 6.

Table 6: MH to US TSR Sinks

Generator Bus	MW
<i>Removed</i>	

Generator Bus	MW
Removed	

1.2.3.2 Transmission Upgrade Options

The transmission upgrade options proposed by the ad hoc study group are summarized in Table 7.

Table 7: Transmission Upgrade Options

Project	1	2	3
Dorsey – Maple River 50% series compensated 500 kV line terminated via 500/345 kV transformer at Maple River. HVDC reduction for loss of the line or transformer.	X	X	
North LaCrosse – West Middleton 345 kV Line	X	X	X
Maple River – Helena 50% series compensated 500 kV line terminated via 500/345 kV transformer at Helena. HVDC reduction for loss of the line or transformer.	X		
Arrowhead – Chisago – King 345 kV line		X	
Maple River – Arrowhead 50% series compensated 500 kV line terminated via 500/345 kV transformer at Arrowhead. HVDC reduction for loss of the line or transformer.		X	
Dorsey – King 50% series compensated 500 kV line terminated via 500/345 kV transformer at King. HVDC reduction for loss of the line or transformer.			X

1.3 Contingency Criteria

The stability simulations performed as part of this study considered the contingencies listed in Table 8. Disturbances defined in the MAPP standard library were simulated using the switching sequence from the library; disturbances affected by the Riel substation were updated based on input provided by Manitoba Hydro. New switching sequence files were developed for disturbances not defined in the library (ID beginning with an "h"); admittances used to simulate single-line-to-ground faults in new switching sequences were estimated assuming that the impedance in the positive, negative and zero sequences at the fault point are equal.

Table 8: Proposed Stability Disturbances

Pre-Benchmark MB0	Benchmark MHB	TSR Study Option 1 MH1	TSR Study Option 3 MH3	Description
ag1	ag1	ag1	ag1	SLG fault with breaker failure at Leland Olds on the Ft Thompson 345 kV line
ag3	ag3	ag3	ag3	3PH fault at Leland Olds on the Ft Thompson 345 kV line
		cts ¹	cts ¹	SLGBF fault at CHISAGO 345 TR10, Trips CHISAGO-FORBES, and CHISAGO TR; Cross-trip Forbes-Riel
ei2	ei2	ei2	ei2	CU DC permanent bipole fault with tripping of both Coal Creek units
		em3	em3	5.0 cy 3 ph flt @ letellier 230 on drayton line, clr letellier-drayton 230 kv line; dc reduction
eq1	eq1	eq1	eq1	SLG fault with breaker failure at Coal Creek on CU DC pole 1 with cross-trip of Coal Creek unit #2
fds	fds	fds	fds	3PH fault at Square Butte on the Stanton 230 kV line
		mc3	mc3	5.0 cy 3 ph flt @ richer 230 on R50M, clr richer-roseau 230 kv line; dc reduction
		md3	md3	5.0 cy 3 ph flt @ glenboro 230 on G82R, clr glenboro-rugby 230 kv line; dc reduction
		mis	mis	Bipole 2 block in the Manitoba Hydro System, Cross trip Manitoba Ontario Ties @ t=0.35s
		mjs	mjs	SLGBF fault at CHISAGO, Trip CHISAGO-KOHLMAN LAKE, and CHISAGO TR
		mkd	mkd	4 cycle 3 phase fault at Chisago kv, clear the king-Chisago kv line
		mks	mks	SLGBF fault at CHISAGO, Trips CHISAGO-KING, and CHISAGO TR
nad ¹	nad ¹	nad ¹	nad ¹	3PH fault at Forbes on the M602F 500 kV line; dc reduction
nmz ¹	nmz ¹	nmz ¹	nmz ¹	3PH fault at Chisago on the Forbes D601C 500 kV line, xtrip M602F, 100% reduction, leave SVC on MP system
pas ¹	pas ¹	pas ¹	pas ¹	SLG fault with breaker failure at Forbes with 602L stuck, trip Riel-Forbes 500 kV line (M602F); dc reduction

Pre-Benchmark MB0	Benchmark MHB	TSR Study Option 1 MH1	TSR Study Option 3 MH3	Description
		pc0	pc0	SLG fault at King-Eau Claire line with a breaker failure at King, Trips King-ECL and ASK-CHI line
pcs	pcs	pcs	pcs	SLG fault with breaker failure at King with 8P6 stuck
pct	pct	pct	pct	Trip of King-Eau Claire-Arpin without a fault
pys	pzs ²	pzs ²	pzs ²	SLG fault with breaker failure at Prairie Island with 8H9 stuck; Trips Prairie Island-N Rochester line
pyt	pzt ²	pzt ²	pzt ²	Trip of Prairie Island-N Rochester without a fault
		ya3	ya3	4 cycle 3 phase fault at Arrowhead 230 kV, clear the Arrowhead-Gardner park 345 kV line
		yas	yas	4 CY SLG fault at Arrowhead 345 on AHD-GDP ckt #1, AHD brkr stk, clear at 17 cycles by tripping AHD-GDP bus section
		yb3	yb3	4 cycle 3 phase fault at Arrowhead 345 kV, clear the Arrowhead - Stone Lake 345 kv line
		h13	h13	5 cycle 3PH fault at Dorsey, trip Dorsey-Riel 500 kV line #1
		h23	h23	5 cycle 3PH fault at Dorsey, trip Dorsey 500/230 kV transformer #1; dc reduction
		h73		5 cycle 3PH fault at Dorsey 500 kV, trip the Dorsey-Maple River 500 kV line; dc reduction
		hc3		5 cycle 3PH fault at Dorsey 500 kV, trip Dorsey-King 500 kV line; dc reduction
		hes		5 cycle SLG fault at Dorsey 500 kV on Dorsey-Maple River line, Dorsey breaker fails, clear at 16 cycles by tripping Dorsey 500-230 kV xfmr, dc reduction
		hfs		5 cycle SLG fault at Dorsey 500 kV on Dorsey-King line, Dorsey breaker fails, clear at 16 cycles by tripping Dorsey 500-230 kV xfmr, dc reduction
		h33	h33	5 cycle 3PH fault at Riel, trip Riel-Forbes 500 kV line; dc reduction
		h43	h43	5 cycle 3PH fault at Riel, trip Riel 500/230 kV transformer
		h53		5 cycle 3PH fault at Helena 500 kV, trip the Helena-Maple River 500 kV line, cross trip the Dorsey-Maple River 500 kV line; dc reduction
		h63		5 cycle 3PH fault at Helena 345 kV, trip the Helena-Blue Lake 345 kV line
		he3		5 cycle 3PH fault at Helena 345 kV, trip the Helena-Lake Marion 345 kV line
		hgs		5 cycle SLG fault at Helena 345 kV on 500-345 kV xfmr, 345 kV breaker fails, clear at 16 cycles by tripping Helena-Blue Lake, cross trip the Dorsey-Maple River 500 kV line, dc reduction
		hjs		5 cycle SLG fault at Helena 345 kV on Helena-Blue Lake line, Helena breaker fails, clear at 16 cycles by tripping Helena-Wilmarth
		h83		5 cycle 3PH fault at Maple River 500 kV, trip the Maple River 500/345 kV transformer

Pre-Benchmark MB0	Benchmark MHB	TSR Study Option 1 MH1	TSR Study Option 3 MH3	Description
		h93		5 cycle 3PH fault at Maple River 345 kV, trip Maple River-Alexandria SS 345 kV line
		hhs		5 cycle SLG fault at Maple River 345 kV on 500-345 kV xfmr, 345 kV breaker fails, clear at 16 cycles by tripping Maple River-Alexandria SS
		hks		5 cycle SLG fault at Maple River 345 on Alexandria SS line, Maple River breaker fails, clear at 16 cycles by tripping Maple River 345-230 kV xfmr
		hd3		5 cycle 3PH fault at King 500 kV, trip Dorsey-King line, 100% reduction
		his		5 cycle SLG fault at King 345 on 500-345 kV transformer, 345 kV breaker fails, clear at 16 cycles by tripping King-Eau Claire line

Note 1: Switching sequence updated to account for Riel

Note 2: Switching sequence updated to account for N Rochester

Existing 500 kV and 230 kV HVDC reduction Special Protection Schemes (SPS) were simulated in the stability analysis. HVDC reduction assumed for network upgrade options is summarized in Table 9.

Table 9: HVDC Reduction Assumed for Network Upgrade Options

Option	Initiating Event	Flow Measurement	% Reduction at Dorsey Based on Measured Flow
1	Dorsey-Maple River 500 kV line trip	Dorsey-Maple River	100%
1	Maple River 500/230 kV transformer trip	Dorsey-Maple River	None
1	Maple River-Helena 500 kV line trip	Dorsey-Maple River	100%
1	Helena 500/230 kV transformer trip	Dorsey-Maple River	100%
3	Dorsey-King 500 kV line trip	Dorsey-King	100%
3	King 500/230 kV transformer trip	Dorsey-King	100%

1.4 Performance Criteria

Simulation results were evaluated using the criteria in the MAPP Members Reliability Criteria and Study Procedures Manual. Transient voltages must be within the MAPP default limits of 0.70-1.20 per unit with the exception of a few specific buses, areas or companies that have different requirements. All machine rotor angle oscillations must be positively damped with a minimum damping factor of 5% for disturbances with a fault or 10% for line trips without a fault.

1.5 Simulation Results

1.5.1 Pre-Benchmark and Benchmark Cases

Transient stability simulation results for the pre-benchmark and benchmark cases are summarized in Appendix C. All of the simulated disturbances result in acceptable system performance.

1.5.2 TSR Study Cases

Transient stability simulation results for the TSR study cases are summarized in Appendix C.

With upgrade option 1, all of the simulated disturbances result in acceptable system performance.

With upgrade option 3, all of the simulated disturbances result in acceptable system performance except for steady-state voltage violations at the series capacitor on the new Dorsey-King 500 kV line. The line is modeled without shunt reactors and with the series capacitor at the line midpoint. The pre-contingency voltage at the series capacitor is 1.19 per unit and the steady-state post-contingency voltage is as high as 1.26 per unit. Mitigation for the Option 3 voltage violation might include series compensating the line in two locations instead of at the midpoint, connecting shunt reactors at the line terminals or adding a substation and connection to the 230 kV system near the line's midpoint.

DRAFT

Appendix
A

Stability Power Flow Model Development

A.1 Pre-Benchmark Case

1.1 Apply Response file provided by ATC to update model

2015SUOP_ATC_20090304_v29.idv

1.2 Add Big Stone II (generator and 230 kV outlet)

```
i-addBGSGrntF11s230.idv (added here but removed by later response file)
i-addBGSMrrs230.idv
purge_Ortonville230.idv
BSPII_BSP_JHNSJCT_MORRIS_1272.idv
BSPII_BSP_CANBY_GF1S_1272BNDL.idv
i-addBGSII.idv
```

1.3 Add MTEP near-term projects

```
ALTW_1289_Marshalltown-Toledo_115V.idv
ALTW_1618_Heron_Lake-Lakefield_161kV.idv
altw_1753_Winnebago_Jct_161-69_kV_75_MVA_TRFs1&2.idv
altw_1761_Tripoli-Readlyn_69_kV_Rebuild.idv
ALTW_Arnold-Washburn_1739-161kV_Upgrade.idv
ITCM_Grand_Mound-1619_161kV-CONVERTED_v2.idv
altw_hiawatha-Lws_Flds-1342_161-115kV.idv
altw_salem-1287_345-161kV_448_MVA.idv
ATC_(339)_Jefferson-Stonybrook_138_kV_and_Uprates.idv
ATC_(1553)_Hiawatha_Cap_1x16_3.idv
GRE-PROJECT-TOWER(1021)(for mp).idv
xel-1368-1369-1370-NEWRICHMOND.idv
xel-1373-NEWULM-TS.idv
xel-1457-BRIGO_.idv
xel-1489-WOODBURY-TANNERSLAKE.idv
xel-1545-MANKATO_115KV_LOOP_v2.idv
xel-1548-LACROSSE.idv
xel-1548-mONROECO_CAPBANK.idv
xel-1549-EAUCLAIRE_v2.idv
XEL-1959-YANKEEODOODLE-PILOTKNOB_v2.idv
```

1.4 Add MTEP out-year projects excluding CapX

ALTW_1758_Beaver_Channel-2nd_AVE_69_kV_Rebuild-CONVERTED.idv
ALTW_Hazelton-1288_345-161kV_335_MVA-CONVERTED.idv
ALTW_Hills-Washington-1755_69kV_Rbld-CONVERTED.idv
ALTW_Leon-1645_69kV_7MVAR-CONVERTED.idv
ALTW_N_Cntrville_69kV-1772_7MVAR-CONVERTED.idv
ALTW_Qquad-RkCrk-Salem-1345_Terminals-CONVERTED.idv
ALTW_Salem-Lore-Hazelton-1340_345kV-CONVERTED.idv
ALTW_Toledo-Belle-1289_Plaine_StoneyPt-CONVERTED.idv
GRE-1021-EMBARRASS-TOWER115-CONVERTED.idv
GRE-1022-BADOURA-LONGLAKE115-CONVERTED.idv
GRE-1361-BADOURA-BIRCHLAKE115_BL115_69-CONVERTED.idv
GRE-PROJECT-599-ENTPPK_CRKDLK(20152)-CONVERTED.idv
ITCM_1341_Hazleton_161-69_kv_75_MVA_bothTRFs-CONVERTED.idv
ITCM_1473_Mason_City_Emery-Armour_69kV-CONVERTED_v2.idv
ITCM_1522_6th-Beverly_161kV-CONVERTED.idv
ITCM_1618_Heron_Lake-Lakefield_161kv-CONVERTED.idv
ITCM_1641_Ottumwa_161kv_50MVAR-CONVERTED.idv
ITCM_1739_Arnold-Washburn_161kV_Upgrade-CONVERTED.idv
ITCM_1753_Winnebago_Jct_161-69_kv_75_MVA_TRF-CONVERTED.idv
ITCM_1756_Dyersville-Seippel_Rd_69kv2-CONVERTED.idv
MP-MISO-PROJECT-1482-Pepin-Lk-r2-CONVERTED.idv
OTP-1033-SLVRLK-CONVERTED.idv
OTP-971-WINGERXFMR-20080613 [08-09-16 09_34]-CONVERTED.idv
OTP-MTEPA-2091-CASSLKFMR-CONVERTED.idv
OTP-MTEPA-2092-SOCASCADE-CONVERTED.idv
SMP-MISO-LAKECITY-1367-AREA [08-10-18 16_21]-CONVERTED.idv
xel-1371-BLACKDOG-WILSON2-UPGRADE_v30-CONVERTED.idv
xel-1455-MERP-RIVERSIDE_v30-CONVERTED.idv
XEL-1487-SOMMERSET-CONVERTED.idv
XEL-1953-SAUKRIVER-STCLOUD-CONVERTED.idv
XEL-1954-WSIOUXFALLS-PATHFINDER-CONVERTED.idv
XEL-1960-TRAVERSE-STPETER-CONVERTED.idv
XEL-1961_LAKEEMILY_CAP-CONVERTED.idv
XEL-552-IRONWOOD_2ND_TR-CONVERTED.idv
XEL-56-CHISAGO-STCROIXFLS [08-10-31 18_27]-CONVERTED_v2.idv
XEL-675-SCOTTCO-WESTGATE-CONVERTED.idv
XEL-PROJECT-1380-WWACONIA-SCOTTCO-115KV-CONVERTED.idv
XEL-PROJECT-1958-StoneLake-Couderay-CONVERTED.idv

1.5 Apply miscellaneous updates and corrections

GRE-MISO-PROJECT-KRMRLK(53801)-CONVERTED.idv
GRE-MISO-PROJECT-LWRNCTP(20138)-CONVERTED.idv
MP-MISO-Dunka-Load-CONVERTED.idv
MP-MISO-PROJECT-LL-BAD-PINE-PEQ-CONVERTED.idv
add-essar-mn-detail-r1.idv

The following facilities were placed in service:

- CSLTNET-Buffalo 115 kV line
- Running 230-69 kV xfmr
- Moranville 230/115 kV xfmr

The following facilities were purged

- Center-Harvey-Prairie 345 kV line
- Center 345/230 kV xfmr #2
- Harvey 345/230 kV xfmr

Activity GNET used to replace generators with negative MVA load at the following buses:

- Cloquet 115 kV (61668)
- Chandler 69 kV (bus 62710)

1.6 Add NR generating facilities

G519_Mesaba.idv

G618_5d.idv

G904_5d.idv

G930_A422_A423_5d.idv

1.7 Reduce generation in North Dakota by 540 MW so that North Dakota load is approximately 80% of summer peak. Generating units in the Dakotas dispatched above Pmax (given in power flow case) were reduced to Pmax and wind generation in eastern ND was turned off at Ashtabula, Edgley and Langdon.

1.8 Turn on generation in the GRE and XEL control areas that will be used to sink A388 and A416; scale load in the TVA control area by corresponding amount.

1.9 Manitoba Hydro system updates including the addition of Bipole 3. HVDC loading adjusted to maintain export level and prepare to source TSRs at Dorsey in the study cases. Bipole 1 = 797 MW, Bipole 2 = 903 MW, Bipole 3 = 1540 MW.

1-add transcona stuff-2004series.idv

2-Riel 230-500 buses 2004-series.idv

3-riel-sum-08s-2004series.idv

4-BP3_and_Conawapa.idv

5-Gull.idv

Bipole 3 changes.idv

Dorsey--Riel-Ckt2-500kV.idv

1.10 Apply setexports.ipl to adjust NDEX, MHEX and MWEX to their simultaneous maximum capability. NDEX=2450 MW, MHEX = 2175 MW, MWEX - 1525 MW

1.11 Scale load in the TVA control area to make up for load and generation changes

A.2 Benchmark Case

2.1 Add CapX 2020 Group 1 Projects

i-1-SWMINN_TC_345additionB_dpk'.idv
i-2-MapleRiver-AlexSS-WaitePark-Monticello_add.idv
i-3-alex-cloud-V29.idv
i-4-Bos230Wil_GIMod.idv
i-5-almx-no-bvd.idv

2.2 Add Big Stone 345 kV outlet facilities

XEL-1457-HAZEL.idv
MODIFY_BIGSTONII.idv

A.3 TSR Study Case

- 3.1 Increase loading on MH bipole 1 and 2 from 1700 MW to 2830 MW and make corresponding change to MH generation schedule at Conawapa and Keeyask
- 3.2 Adjust generation to sink study TSR
- 3.3 Add transmission upgrades

3.3.1 Option 1

MHEB_Case\upgrades\Dorsey--MapleRiver-midcomp-500kV.idv
MHEB_Case\upgrades\MapleRiver--Helena-midcomp-500kV.idv
MHEB_Case\upgrades\N-LaCrosse--W-Middleton-345kV.idv

3.3.2 Option 3

MHEB_Case\upgrades\ Dorsey--King-500kV.idv
MHEB_Case\upgrades\N-LaCrosse--W-Middleton-345kV.idv

**Appendix
B**

Power Flow Summaries

DRAFT

B.1 Pre-Benchmark Case without CapX, MH TSRs or Transmission Upgrade Options

POWER FLOW SUMMARY


NDEX:	2449 MW	ECL-ARP:	626 MW		
MHEX:	2177 MW	PRI-BYN:	746 MW		
MWEX:	1528 MW	AHD-SLK:	638 MW		
KING-ECL:	888 MW	SLK-GPK:	444 MW		
COOPER S:	1016 MW	WNE-WKS:	524 MW		
FTCAL S:	562 MW	GGS:	1615 MW		
GRIS-LNC:	679 MW	QC WEST:	184 MW		
ALEX-WTPK:	0 MW	NROC-NLAX:	0 MW		
DOR-MAP R:	0 MW	DOR-ASK:	0 MW		
LOAD LEVELS AS PERCENT OF 2015 SUMMER PEAK:					
NORTH DAKOTA (ZONE 90,990)	2890.0 MW, 77.9% OF	3710.2 MW			
NSP (AREA 600)	8463.5 MW, 71.2% OF	11889.2 MW			
MAN HYDRO (AREA 667)	2348.2 MW, 76.3% OF	3076.0 MW			
Load/Losses	MW / MW	Generation	Export		
Manitoba	2348 / 243	MH total gross	4960 ATC West Import 1293		
Ont. total	22150 / 478	Wpg River	568 ATC SW Import 620		
NW	915 / 37	7 Sisters	170 ATC SE Import -1599		
Sask.	2150 / 82	OH total gross	21884 East Bias 220		
MP	2342 / 164	northwest	717 SPC>WAPA (B10T) 164		
NSP	8463 / 472	SPC total gross	2406 MH>SPC (3-230) 60		
N. Dakota	2890 / 295	MP total gross	2861 MH>SPC (FALLS) 0		
Manitoba	481 MVARS	ND Cfd AC gross	3149 OH>MH @Kenora -195		
Ont. total	13082 MVARS	net	2978 OH>MP @Ft Fran 152		
NW	489 MVARS	NSP East gross	2552 OH E>W @Wawa 192		
Sask.	502 MVARS	net	2420 OH>East USA 0		
MP	669 MVARS	West gross	3057 F601C @Forbes 1606		
NSP	1786 MVARS	net	2895 D602F @Riel 1804		
N. Dakota	753 MVARS	Total net	6191 L20D @Letell 271		
ATC	10757 / 303	WAPA SD Hydro	1497 R50M @Richer 137		
ATC	3143 MVARS	Pleasant Valley	110 G82R @Glenboro N/A		
		LGS/Trimont	109		
		SW MN Wind	193		
		N DAK WIND	252		
		Swing Bus	1010		
Tfmrs	MVA/ Load	Ph Shifters	Deg/ MW	DC Lines	MW
Wshell #1	7-7 105/ 73%	Stinson	29/ 29	CU (1,2)	1103
Wshell #2	7-7 105/ 73%	Boundary Dam	4/ 165	SQ BU (3,4)	455
Drayton#1	4-7 47/ 34%	Whiteshell	97/ 199	MH Bipole 1	797
Drayton#2	4-7 60/ 32%	Int Falls	120/ 151	MH Bipole 2	903
Dorsey #1	2-4 469/ 39%	St. Lawrence	16/ 0	MH (BP1+BP2)	1700
Dorsey #2	2-4 550/ 45%	Arrowhead	0/ 639	Miles City E>W	-150
Forbes	2-4 50/ 7%			RCDC (15)	0
Stone Lk	3-5 182/ 54%			Stegall (10)	0
Dorsey SC's	I/S	MVAR	Qmax/ Qmin	SVC's	MVAR
MIL 7-9G	17.0	2	-115	Forbes	500
SCE 1-3G	18.2	3	-94	Fargo	13.2
SCA 4-6G	18.2	3	-94	Watertown	20.0
Total Margin		-304	1560/ -810	Series Caps	Num In Serv
		1864		Roseau	500 2 of 2
				Chisago	500 1 of 1

Caps/Reactors	MVAR	Caps/Reactors	MVAR	Caps/Reactors	MVAR
Balta (FS) 230	0	Arrowhead 230	160	Chisago T 9	34.5 60
Drayton 115	20	Blackberry 230	47	Chisago T 10	34.5 60
Drayton 13.8	0	Minntac 115	45	Forbes 230	70
Eau Claire (FS) 161	356	Riverton 230	47	Forbes 500	600
Kohlman Lake 115	240	Roseau Co. (FS) 230	0		0
Parkers Lk (FS) 115	0	Running (FS) 230	30	Fargo 115	27
Prairie (FS) 115	40	Running react 230	0	Watertown 20	20
Ramsey (FS) 230	0	Shannon 230	72	Watertown 230	76
Red Rock 115	240		0		0
Rugby 13.8	-25	Glenboro 230	0	Arrowhead 345	75
Split Rock (FS) 115	80	Laverendrye 110	98	Stone Lake 345	75
Sheyenne (FS) 115	40	Richer react 230	0	Stone Lk Reac 345	0
Wilton/Bemidji 115	20	St Vital 110	98	Stone Lake 161	0
	0		0	Grdn Pk Reac 345	0
	0		0	Grdn Pk Caps 115	0
	0		0	Arpin Caps 138	52
	0		0	Council Creek 138	16

Bus Voltages	V,pu	Bus Voltages	V,pu	Bus Voltages	V,kV
Adams 345	1.008	Arrowhead 230	1.011	Whiteshell 110	118.9
Alexandria 115	1.022	Badoura 115	1.026	Kenora 220	246.5
Audubon 115	1.040	Blackberry 230	1.035	Dryden 220	250.7
Bemidji 115	1.015	Boise Cascade 13.8	1.051	Fort Frances 220	244.3
Byron 345	1.016	Boise Cascade 115	1.019	Mackenzie 220	253.6
Chisago Co. 345	1.022	ETCO 115	1.008	Lakehead 220	246.2
Chisago Co. 500	1.018	Forbes 230	1.022	Marathon 220	253.0
Drayton 230	1.028	Forbes 500	1.018	Wawa 220	254.7
Eau Claire 345	1.028	Hubbard 115	1.021	Mississagi 220	250.7
WEST FARIBAULT 115	1.020	Intl Falls 115	1.020	Fort Frances 118	118.7
LaPorte 115	1.013	Minntac 115	1.015	Lakehead 118	122.8
Maple River 230	1.031	Moranville 230	1.027	Birch 118	120.2
Marshall Tap 115	1.024	Riverton 230	1.019	Marathon 118	123.3
Owatonna 161	1.001	Running 230	1.028		0.000
Prairie 115	1.033	Shannon 230	1.029	Arrowhead 345	1.027
Prairie 230	1.027	Stinson MN 115	1.024	Stone Lake 345	1.037
Ramsey 230	1.005	Jamestown 345	0.983	Stone Lake 161	1.037
Roseau County 230	1.026	Groton 345	1.009	Gardner Park 345	1.035
Roseau County 500	1.065	Watertown 230	1.030	Weston 115	1.035
Sheyenne 230	1.032	Watertown 345	1.023	Arpin 345	1.023
Thief R Falls 115	1.028		0.000	Eau Claire 161	1.039
Tioga 230	1.034	Dorsey 230	1.045	Council Creek 161	0.975
Wahpeton 230	1.019	Dorsey 500	1.046	Hydro Lane 161	1.014
Winger 115	1.043		0.000	Wien 115	1.033
	0.000		0.000		0.000
	0.000		0.000		0.000
	0.000		0.000		0.000

Steady State Relay Margins (measured from inner blinder)

Relay Location	Manuf/Type	PSS Model	South	North	Em	North
1) B10T-Tioga (South)	GE OST	SLLP	342%	N/A	N/A	
2) -Tioga (North)	GE OST	SLLP	702%	N/A	N/A	
3) -Tioga (Em North)	GE OST	SLLP		N/A	N/A	
4) D602F-Dorsey	ATP ???	SLINOS	999999%	N/A	N/A	
5) -Forbes (Normal)	ATP ???	SLINOS	240%	N/A	N/A	
6) -Forbes (Em Nrth)	APT S-PRO	SLINOS		N/A	N/A	
8) F3M-Intl Falls	APT S-PRO	SLINOS	315%	N/A	N/A	
9) G82R-Rugby	APT	SLINOS	999999%	N/A	N/A	
10) L20D-Drayton (Normal)	APT, ASEA	SLINOS	743%	N/A	N/A	
11) -Drayton (Em Nrth)	ASEA RXZF2	SLINOS		N/A	N/A	
12) R50M-Moranville (Norm)	APT, West	SLINOS	987%	N/A	N/A	
13) -Moranville (Em N)	ASEA RXZF2	SLINOS		N/A	N/A	



Pre-Benchmark Case

B.2 Benchmark Case without MH TSRs or Transmission Upgrade Options


POWER FLOW SUMMARY						
NDEX:	2316 MW	ECL-ARP:	639 MW			
MHEX:	2175 MW	PRI-BYN:	102 MW			
MWEX:	1483 MW	AHD-SLK:	643 MW			
KING-ECL:	838 MW	SLK-GPK:	450 MW			
COOPER S:	1011 MW	WNE-WKS:	520 MW			
FTCAL S:	556 MW	GGS:	1605 MW			
GRIS-LNC:	653 MW	QC WEST:	195 MW			
MAP R-ALEX:	289 MW	WIL-BOWS:	-116 MW			
ALEX-WTPK:	206 MW	NROC-NLAX:	238 MW			
GOR-MAP R:	0 MW	GOR-ASK:	0 MW			
LOAD LEVELS AS PERCENT OF 2015 SUMMER PEAK:						
NORTH DAKOTA (ZONE 90, 990) 2890.0 MW, 77.9% OF 3710.2 MW						
NSP (AREA 600) 8463.5 MW, 71.2% OF 11889.2 MW						
MAN HYDRO (AREA 667) 2348.2 MW, 76.3% OF 3076.0 MW						
Load/Losses	MW / MW	Generation	MW	Export	MW	
Manitoba	2348 / 245	MH total gross	4960	ATC West Import	1349	
Ont. total	22150 / 478	Wpg River	568	ATC SW Import	603	
NW	915 / 36	7 Sisters	170	ATC SE Import	-1628	
Sask.	2150 / 82	OH total gross	21884	East Bias	119	
MP	2342 / 142	northwest	717	SPC>WAPA (B10T)	164	
NSP	8463 / 429	SPC total gross	2406	MH>SPC (3-230)	60	
N. Dakota	2890 / 286	MP total gross	2861	MH>SPC (FALLS)	0	
Manitoba	481 MVARS	ND Cfd AC gross	3149	OH>MH @Kenora	-196	
Ont. total	13082 MVARS	net	2978	OH>MP @Ft Fran	151	
NW	489 MVARS	NSP East gross	2552	OH E>W @Wawa	190	
Sask.	502 MVARS	net	2420	OH>East USA	0	
MP	669 MVARS	West gross	3057	F601C @Forbes	1476	
NSP	1786 MVARS	net	2895	D602F @Riel	1750	
N. Dakota	753 MVARS	Total net	6191	L20D @Letell	301	
ATC	10757 / 310	WAPA SD Hydro	1497	R50M @Richer	138	
ATC	3143 MVARS	Pleasant Valley	110	G82R @Glenboro	N/A	
		LGS/Trimont	109			
		SW MN Wind	193			
		N DAK WIND	252			
		Swing Bus	933			
Tfmrs	MVA/ Load	Ph Shifters	Deg/	MW	DC Lines	MW
Wshell #1 7-7	105/ 73%	Stinson	26/	26	CU (1,2)	1104
Wshell #2 7-7	105/ 73%	Boundary Dam	1/	165	SQ BU (3,4)	455
Drayton#1 4-7	51/ 36%	Whiteshell	94/	200	MH Bipole 1	797
Drayton#2 4-7	65/ 34%	Int Falls	117/	150	MH Bipole 2	903
Dorsey #1 2-4	457/ 38%	St. Lawrence	16/	0	MH (BP1+BP2)	1700
Dorsey #2 2-4	542/ 45%	Arrowhead	0/	644	Miles City E>W	-149
Forbes	2-4 87/ 13%				RCDC (15)	0
Stone Lk	3-5 181/ 53%				Stegall (10)	0
Dorsey SC's	I/S	MVAR	Qmax/ Qmin	SVC's	MVAR	Qmax/ Qmin
MIL 7-9G	17.0	2	-137	Forbes	500	12
SCE 1-3G	18.2	3	-112	Fargo	13.2	-3
SCA 4-6G	18.2	3	-112	Watertown	20.0	31
Total Margin			1560/ -810	Series Caps		Num In Serv
			1921	Roseau	500	2 of 2
				Chisago	500	1 of 1

Caps/Reactors	MVAR	Caps/Reactors	MVAR	Caps/Reactors	MVAR
Balta (FS)	230	0	Arrowhead	230	160
Drayton	115	20	Blackberry	230	47
Drayton	13.8	0	Minntac	115	45
Eau Claire (FS)	161	356	Riverton	230	47
Kohlman Lake	115	240	Roseau Co. (FS)	230	0
Parkers Lk(FS)	115	0	Running (FS)	230	30
Prairie (FS)	115	40	Running react	230	0
Ramsey (FS)	230	0	Shannon	230	72
Red Rock	115	240	St Vital	110	98
Rugby	13.8	-25	Glenboro	230	0
Split Rock(FS)	115	80	Laverendrye	110	98
Sheyenne (FS)	115	40	Richer react	230	0
Wilton/Bemidji	115	20	Stone Lake	345	75
	0		Stone Lk Reac	345	0
	0		Stone Lake	161	0
	0		Grdn Pk Reac	345	0
	0		Grdn Pk Caps	115	0
	0		Arpin Caps	138	52
	0		Council Creek	138	16

Bus Voltages	V,pu	Bus Voltages	V,pu	Bus Voltages	V,kV
Adams	345 1.010	Arrowhead	230 1.005	Whiteshell	110 118.9
Alexandria	115 1.031	Badoura	115 1.041	Kenora	220 246.7
Audubon	115 1.053	Blackberry	230 1.035	Dryden	220 250.9
Bemidji	115 1.037	Boise Cascade	13.8 1.053	Fort Frances	220 244.8
Byron	345 1.020	Boise Cascade	115 1.021	Mackenzie	220 253.8
Chisago Co.	345 1.023	ETCO	115 1.009	Lakehead	220 246.3
Chisago Co.	500 1.020	Forbes	230 1.025	Marathon	220 253.1
Drayton	230 1.027	Forbes	500 1.022	Wawa	220 254.8
Eau Claire	345 1.030	Hubbard	115 1.037	Mississagi	220 250.7
WEST FARIBAULT	115 1.030	Intl Falls	115 1.022	Fort Frances	118 119.0
LaPorte	115 1.032	Minntac	115 1.017	Lakehead	118 122.8
Maple River	230 1.044	Moranville	230 1.027	Birch	118 120.2
Marshall Tap	115 1.030	Riverton	230 1.031	Marathon	118 123.3
Owatonna	161 1.005	Running	230 1.029	0.000	
Prairie	115 1.038	Shannon	230 1.031	Arrowhead	345 1.009
Prairie	230 1.031	Stinson MN	115 1.017	Stone Lake	345 1.007
Ramsey	230 1.007	Jamestown	345 0.986	Stone Lake	161 1.015
Roseau County	230 1.027	Groton	345 1.015	Gardner Park	345 1.035
Roseau County	500 1.059	Watertown	230 1.030	Weston	115 1.035
Sheyenne	230 1.042	Watertown	345 1.028	Arpin	345 1.023
Thief R Falls	115 1.036		0.000	Eau Claire	161 1.038
Tioga	230 1.034	Dorsey	230 1.045	Council Creek	161 0.978
Wahpeton	230 1.030	Dorsey	500 1.043	Hydro Lane	161 1.012
Winger	115 1.056		0.000	Wien	115 1.031
	0.000		0.000		0.000
	0.000		0.000		0.000
	0.000		0.000		0.000

Steady State Relay Margins (measured from inner blinder)

Relay Location	Manuf/Type	PSS Model	South	North	Em	North
1) B10T-Tioga (South)	GE OST	SLLP	342%	N/A	N/A	
2) -Tioga (North)	GE OST	SLLP	702%	N/A	N/A	
3) -Tioga (Em North)	GE OST	SLLP		N/A	N/A	
4) D602F-Dorsey	ATP ???	SLINOS	999999%	N/A	N/A	
5) -Forbes (Normal)	ATP ???	SLINOS	254%	N/A	N/A	
6) -Forbes (Em Nth)	APT S-PRO	SLINOS		N/A	N/A	
8) F3M-Intl Falls	APT S-PRO	SLINOS	321%	N/A	N/A	
9) G82R-Rugby	APT	SLINOS	999999%	N/A	N/A	
10) I20D-Drayton (Normal)	APT, ASEA	SLINOS	646%	N/A	N/A	
11) -Drayton (Em Nth)	ASEA RXZF2	SLINOS		N/A	N/A	
12) R50M-Moranville (Norm)	APT, West	SLINOS	979%	N/A	N/A	
13) -Moranville (Em N)	ASEA RXZF2	SLINOS		N/A	N/A	



B.3 Study Case with MH TSRs and Transmission Upgrade Option 1

POWER FLOW SUMMARY


NDEX:	2400 MW	ECL-ARP:	692 MW			
MHEX:	1887 MW	PRI-BYN:	110 MW			
MWEX:	1586 MW	AHD-SLK:	644 MW			
KING-ECL:	940 MW	SLK-GPK:	470 MW			
COOPER S:	1013 MW	WNE-WKS:	520 MW			
FTCAL S:	569 MW	GGS:	1605 MW			
GRIS-LNC:	655 MW	QC WEST:	209 MW			
MAP R-ALEX:	323 MW	WIL-BOS:	-73 MW			
ALEX-WTPK:	229 MW	NROC-NLAX:	567 MW			
DOOR-MAP R:	1429 MW	GOR-ASK:	0 MW			
LOAD LEVELS AS PERCENT OF 2015 SUMMER PEAK:						
NORTH DAKOTA (ZONE 90,990) 2890.0 MW, 77.9% OF 3710.2 MW						
NSP (AREA 600) 8463.5 MW, 71.2% OF 11889.2 MW						
MAN HYDRO (AREA 667) 2348.2 MW, 76.3% OF 3076.0 MW						
Load/Losses	MW / MW	Generation	MW			
Manitoba	2348 / 331	MH total gross	6179			
Ont. total	22150 / 478	Wpg River	568			
NW	915 / 36	7 Sisters	170			
Sask.	2150 / 82	OH total gross	21884			
MP	2342 / 134	northwest	717			
NSP	8463 / 459	SPC total gross	2406			
N. Dakota	2890 / 277	MP total gross	2611			
Manitoba	481 MVARS	ND Cfd AC gross	3149			
Ont. total	13082 MVARS	net	2978			
NW	489 MVARS	NSP East gross	2552			
Sask.	502 MVARS	net	2420			
MP	669 MVARS	West gross	3027			
NSP	1786 MVARS	net	2865			
N. Dakota	753 MVARS	Total net	6111			
ATC	10757 / 312	WAPA SD Hydro	1497			
ATC	3143 MVARS	Pleasant Valley	0			
		LGS/Trimont	19			
		SW MN Wind	193			
		N DAK WIND	252			
		Swing Bus	1020			
Tfmrs	MVA/ Load	Ph Shifters	Deg/	MW	DC Lines	MW
Wshell #1	7-7 105/ 73%	Stinson	24/	33	CU (1,2)	1104
Wshell #2	7-7 105/ 73%	Boundary Dam	7/	165	SQ BU (3,4)	454
Drayton#1	4-7 44/ 32%	Whiteshell	87/	199	MH Bipole 1	1522
Drayton#2	4-7 57/ 30%	Int Falls	110/	150	MH Bipole 2	1723
Dorsey #1	2-4 990/ 82%	St. Lawrence	16/	0	MH (BP1+BP2)	3245
Dorsey #2	2-4 1141/ 95%	Arrowhead	1/	646	Miles City E>W	-150
Forbes	2-4 120/ 17%				RCDC (15)	0
Stone Lk	3-5 162/ 48%				Stegall (10)	0
Dorsey SC's	I/S	MVAR	Qmax/	Qmin	SVC's	MVAR
MIL 7-9G	17.0	2	312	-330	Forbes	500
SCE 1-3G	18.2	3	254	-240	Fargo	13.2
SCA 4-6G	18.2	3	254	-240	Watertown	20.0
Total Margin		821	1560/	-810	Series Caps	Num In Serv
		739			Roseau	500 2 of 2
					Chisago	500 1 of 1

Caps/Reactors	MVAR	Caps/Reactors	MVAR	Caps/Reactors	MVAR
Balta (FS)	230	0	Arrowhead	230	160
Drayton	115	20	Blackberry	230	47
Drayton	13.8	0	Minntac	115	45
Eau Claire (FS)	161	356	Riverton	230	47
Kohlman Lake	115	240	Roseau Co. (FS)	230	0
Parkers Lk (FS)	115	0	Running (FS)	230	30
Prairie (FS)	115	40	Running react	230	0
Ramsey (FS)	230	0	Shannon	230	72
Red Rock	115	240			0
Rugby	13.8	-25	Glenboro	230	0
Split Rock (FS)	115	80	Laverendrye	110	98
Sheyenne (FS)	115	0	Richer react	230	0
Wilton/Bemidji	115	20	St Vital	110	98
	0			0	0
	0			0	0
	0			0	0
	0			0	0
				Arpin Caps	138
				Council Creek	138
					16

Bus Voltages	V,pu	Bus Voltages	V,pu	Bus Voltages	V,kV
Adams	345 1.002	Arrowhead	230 1.012	Whiteshell	110 118.9
Alexandria	115 1.035	Badoura	115 1.044	Kenora	220 247.0
Audubon	115 1.056	Blackberry	230 1.035	Dryden	220 251.1
Bemidji	115 1.039	Boise Cascade	13.8 1.055	Fort Frances	220 245.3
Byron	345 1.007	Boise Cascade	115 1.023	Mackenzie	220 254.1
Chisago Co.	345 1.034	ETCO	115 1.017	Lakehead	220 246.3
Chisago Co.	500 1.034	Forbes	230 1.038	Marathon	220 253.1
Drayton	230 1.038	Forbes	500 1.040	Wawa	220 254.8
Eau Claire	345 1.019	Hubbard	115 1.039	Mississagi	220 250.7
WEST FARIBAULT	115 1.026	Intl Falls	115 1.024	Fort Frances	118 119.3
LaPorte	115 1.034	Minntac	115 1.025	Lakehead	118 122.8
Maple River	230 1.053	Moranville	230 1.034	Birch	118 120.2
Marshall Tap	115 1.030	Riverton	230 1.034	Marathon	118 123.3
Owatonna	161 1.002	Running	230 1.037		0.000
Prairie	115 1.044	Shannon	230 1.035	Arrowhead	345 1.034
Prairie	230 1.038	Stinson MN	115 1.018	Stone Lake	345 1.021
Ramsey	230 1.010	Jamestown	345 0.997	Stone Lake	161 1.025
Roseau County	230 1.034	Groton	345 1.018	Gardner Park	345 1.035
Roseau County	500 1.053	Watertown	230 1.030	Weston	115 1.035
Sheyenne	230 1.046	Watertown	345 1.029	Arpin	345 1.018
Thief R Falls	115 1.041		0.000	Eau Claire	161 1.032
Tioga	230 1.034	Dorsey	230 1.045	Council Creek	161 0.982
Wahpeton	230 1.033	Dorsey	500 1.045	Hydro Lane	161 1.006
Winger	115 1.056		0.000	Wien	115 1.027
	0.000		0.000		0.000
	0.000		0.000		0.000
	0.000		0.000		0.000

Steady State Relay Margins (measured from inner blinder)

Relay Location	Manuf/Type	PSS Model	South	North	Em	North
1) B10T-Tioga (South)	GE OST	SLLP	342%	N/A	N/A	
2) -Tioga (North)	GE OST	SLLP	702%	N/A	N/A	
3) -Tioga (Em North)	GE OST	SLLP		N/A	N/A	
4) D602F-Dorsey	ATP ???	SLINOS	999999%	N/A	N/A	
5) -Forbes (Normal)	ATP ???	SLINOS	321%	N/A	N/A	
6) -Forbes (Em Nrth)	APT S-PRO	SLINOS		N/A	N/A	
8) F3M-Intl Falls	APT S-PRO	SLINOS	325%	N/A	N/A	
9) G82R-Rugby	APT	SLINOS	999999%	N/A	N/A	
10) I20D-Drayton (Normal)	APT, ASEA	SLINOS	864%	N/A	N/A	
11) -Drayton (Em Nrth)	ASEA RXZF2	SLINOS		N/A	N/A	
12) R50M-Moranville (Norm)	APT, West	SLINOS	1076%	N/A	N/A	
13) -Moranville (Em N)	ASEA RXZF2	SLINOS		N/A	N/A	



B.4 Study Case with MH TSRs and Transmission Upgrade Option 3

POWER FLOW SUMMARY


NDEX:	2329 MW	ECL-ARP:	726 MW		
MHEX:	2052 MW	PRI-BYN:	119 MW		
MWEX:	1669 MW	AHD-SLK:	647 MW		
KING-ECL:	1021 MW	SLK-GPK:	476 MW		
COOPER S:	994 MW	WNE-WKS:	517 MW		
FTCAL S:	547 MW	GGS:	1605 MW		
GRIS-LNC:	654 MW	QC WEST:	224 MW		
MAP R-ALEX:	270 MW	WIL-BOWS:	-98 MW		
ALEX-WTPK:	179 MW	NROC-NLAX:	550 MW		
DOR-MAP R:	0 MW	DOR-ASK:	1257 MW		
LOAD LEVELS AS PERCENT OF 2015 SUMMER PEAK:					
NORTH DAKOTA (ZONE 90,990) 2890.0 MW, 77.9% OF 3710.2 MW					
NSP (AREA 600) 8463.5 MW, 71.2% OF 11889.2 MW					
MAN HYDRO (AREA 667) 2348.2 MW, 76.3% OF 3076.0 MW					
Load/Losses	MW / MW	Generation	MW		
-----	-----	-----	-----		
Manitoba	2348 / 333	MH total gross	6179		
Ont. total	22150 / 478	Wpg River	568		
NW	915 / 36	7 Sisters	170		
Sask.	2150 / 82	OH total gross	21884		
MP	2342 / 136	northwest	717		
NSP	8463 / 531	SPC total gross	2406		
N. Dakota	2890 / 284	MP total gross	2611		
Manitoba	481 MVARS	ND Cfd AC gross	3149		
Ont. total	13082 MVARS	net	2978		
NW	489 MVARS	NSP East gross	2552		
Sask.	502 MVARS	net	2420		
MP	669 MVARS	West gross	3027		
NSP	1786 MVARS	net	2865		
N. Dakota	753 MVARS	Total net	6111		
ATC	10757 / 315	WAPA SD Hydro	1497		
ATC	3143 MVARS	Pleasant Valley	0		
		LGS/Trimont	19		
		SW MN Wind	193		
		N DAK WIND	252		
		Swing Bus	1036		
Tfmrs	MVA/ Load	Ph Shifters	Deg/ MW	DC Lines	MW
-----	-----	-----	-----	-----	-----
Wshell #1	7-7 105/ 73%	Stinson	26/ 30	CU (1,2)	1104
Wshell #2	7-7 105/ 73%	Boundary Dam	1/ 165	SQ BU (3,4)	455
Drayton#1	4-7 50/ 35%	Whiteshell	92/ 199	MH Bipole 1	1522
Drayton#2	4-7 63/ 34%	Int Falls	114/ 150	MH Bipole 2	1723
Dorsey #1	2-4 964/ 80%	St. Lawrence	16/ 0	MH (BP1+BP2)	3245
Dorsey #2	2-4 1119/ 93%	Arrowhead	2/ 648	Miles City E>W	-149
Forbes	2-4 157/ 23%			RCDC (15)	0
Stone Lk	3-5 158/ 47%			Stegall (10)	0
Dorsey SC's	I/S	MVAR	Qmax/ Qmin	SVC's	MVAR
-----	-----	-----	-----	-----	-----
MIL 7-9G	17.0	2	250	Forbes	500
SCE 1-3G	18.2	3	204	Fargo	13.2
SCA 4-6G	18.2	3	204	Watertown	20.0
Total Margin		660	1560/ -810	Series Caps	
		900		Num In Serv	
				Roseau	500
				Chisago	500
				2 of 2	
				1 of 1	

Caps/Reactors	MVAR	Caps/Reactors	MVAR	Caps/Reactors	MVAR
Balta (FS)	230	0	Arrowhead	230	160
Drayton	115	20	Blackberry	230	47
Drayton	13.8	0	Minntac	115	45
Eau Claire(FS)	161	356	Riverton	230	47
Kohlman Lake	115	240	Roseau Co.(FS)	230	0
Parkers Lk(FS)	115	0	Running (FS)	230	30
Prairie (FS)	115	40	Running react	230	0
Ramsey (FS)	230	0	Shannon	230	72
Red Rock	115	240	St Vital	110	98
Rugby	13.8	-25	Glenboro	230	0
Split Rock(FS)	115	80	Laverendrye	110	98
Sheyenne (FS)	115	40	Richer react	230	0
Wilton/Bemidji	115	20	St Vital	110	98
	0			0	0
	0			0	0
	0			0	0
	0			0	0
				Arpin Caps	138
				Council Creek	138
					16

Bus Voltages	V,pu	Bus Voltages	V,pu	Bus Voltages	V,kV
Adams	345 1.002	Arrowhead	230 1.011	Whiteshell	110 118.9
Alexandria	115 1.034	Badoura	115 1.044	Kenora	220 246.9
Audubon	115 1.056	Blackberry	230 1.035	Dryden	220 251.0
Bemidji	115 1.039	Boise Cascade	13.8 1.054	Fort Frances	220 245.1
Byron	345 1.006	Boise Cascade	115 1.023	Mackenzie	220 254.0
Chisago Co.	345 1.032	ETCO	115 1.014	Lakehead	220 246.3
Chisago Co.	500 1.031	Forbes	230 1.034	Marathon	220 253.1
Drayton	230 1.029	Forbes	500 1.035	Wawa	220 254.8
Eau Claire	345 1.009	Hubbard	115 1.040	Mississagi	220 250.7
WEST FARIBAULT	115 1.027	Intl Falls	115 1.023	Fort Frances	118 119.2
LaPorte	115 1.035	Minntac	115 1.021	Lakehead	118 122.8
Maple River	230 1.046	Moranville	230 1.028	Birch	118 120.2
Marshall Tap	115 1.029	Riverton	230 1.034	Marathon	118 123.3
Owatonna	161 1.000	Running	230 1.031		0.000
Prairie	115 1.039	Shannon	230 1.033	Arrowhead	345 1.032
Prairie	230 1.033	Stinson MN	115 1.017	Stone Lake	345 1.019
Ramsey	230 1.008	Jamestown	345 0.988	Stone Lake	161 1.021
Roseau County	230 1.028	Groton	345 1.015	Gardner Park	345 1.035
Roseau County	500 1.057	Watertown	230 1.030	Weston	115 1.035
Sheyenne	230 1.043	Watertown	345 1.028	Arpin	345 1.013
Thief R Falls	115 1.038		0.000	Eau Claire	161 1.030
Tioga	230 1.034	Dorsey	230 1.045	Council Creek	161 0.980
Wahpeton	230 1.031	Dorsey	500 1.046	Hydro Lane	161 1.005
Winger	115 1.058		0.000	Wien	115 1.043
	0.000		0.000		0.000
	0.000		0.000		0.000
	0.000		0.000		0.000

Steady State Relay Margins (measured from inner blinder)

Relay Location	Manuf/Type	PSS Model	South	North	Em	North
1) B10T-Tioga (South)	GE OST	SLLP	341%	N/A	N/A	
2) -Tioga (North)	GE OST	SLLP	701%	N/A	N/A	
3) -Tioga (Em North)	GE OST	SLLP		N/A	N/A	
4) D602F-Dorsey	ATP ???	SLINOS	999999%	N/A	N/A	
5) -Forbes (Normal)	ATP ???	SLINOS	295%	N/A	N/A	
6) -Forbes (Em Nrth)	APT S-PRO	SLINOS		N/A	N/A	
8) F3M-Intl Falls	APT S-PRO	SLINOS	324%	N/A	N/A	
9) G82R-Rugby	APT	SLINOS	999999%	N/A	N/A	
10) L20D-Drayton (Normal)	APT, ASEA	SLINOS	672%	N/A	N/A	
11) -Drayton (Em Nrth)	ASEA RXZF2	SLINOS		N/A	N/A	
12) R50M-Moranville (Norm)	APT, West	SLINOS	978%	N/A	N/A	
13) -Moranville (Em N)	ASEA RXZF2	SLINOS		N/A	N/A	



DRAFT

This page intentionally left blank.

**Appendix
C**

Transient Stability Summary Tables

Table C-1: Pre-Benchmark Case MB0

Table C-2: Benchmark Case MHB

Table C-3: TSR Study Case MH1 with Upgrade Option 1

Table C-4: TSR Study Case MH3 with Upgrade Option 3

DRAFT

Table C-1: Pre-Benchmark Case

Case No.	1	2	3	4	5
Case Name	Mb0-so15aa-ag1	Mb0-so15aa-ag3	Mb0-so15aa-ei2	Mb0-so15aa-eq1	Mb0-so15aa-fds
Disturbance	ag1	ag3	ei2	eq1	fds
Prior Outage	None	None	None	None	None
Date/Time	APR 15 2009 17:19	APR 15 2009 17:40	APR 15 2009 18:00	APR 15 2009 18:20	APR 15 2009 18:44
Comments					
Steady State Flows					
NDEX / EAST BIAS	2449 / 220	2449 / 220	2449 / 220	2449 / 220	2449 / 220
MHEX / L20D	2177 / 271	2177 / 271	2177 / 271	2177 / 271	2177 / 271
ECL-ARP / PRI-BYN	626 / 746	626 / 746	626 / 746	626 / 746	626 / 746
MWEX / AHD-SLK	1528 / 638	1528 / 638	1528 / 638	1528 / 638	1528 / 638
D602F / F601C	0 / 1606	0 / 1606	0 / 1606	0 / 1606	0 / 1606
B10T / MH>SPC	164 / 60	164 / 60	164 / 60	164 / 60	164 / 60
OH E-W / OH>MH	192 / -195	192 / -195	192 / -195	192 / -195	192 / -195
R50M / OH>MP	137 / 152	137 / 152	137 / 152	137 / 152	137 / 152
G82R	N/A	N/A	N/A	N/A	N/A
Dorsey bipole / CU bipole	1700 / 1104	1700 / 1104	1700 / 1104	1700 / 1104	1700 / 1104
Dorsey Reserve / Wtrtn SVC	1864 / 30	1864 / 30	1864 / 30	1864 / 30	1864 / 30
Forbes SVC / MSC	18 / 600	18 / 600	18 / 600	18 / 600	18 / 600
RCDC	0	0	0	0	0
Steady State Vltgs					
Dorsey 500/Dorsey 230	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045
Roseau 500/Forbes 500	1.032 / 1.018	1.032 / 1.018	1.032 / 1.018	1.032 / 1.018	1.032 / 1.018
Chisago 500/EauClaire 345	1.018 / 1.028	1.018 / 1.028	1.018 / 1.028	1.018 / 1.028	1.018 / 1.028
Int Falls 115/Badoura 115	1.020 / 1.026	1.020 / 1.026	1.020 / 1.026	1.020 / 1.026	1.020 / 1.026
Drayton 230/Groton 345	1.028 / 1.009	1.028 / 1.009	1.028 / 1.009	1.028 / 1.009	1.028 / 1.009
SS OS Relay Margins					
D602F at Forbes/Dorsey	240% / 999%	240% / 999%	240% / 999%	240% / 999%	240% / 999%
G82R at Rugby/L20D at Draytor	999% / 744%	999% / 744%	999% / 744%	999% / 744%	999% / 744%
R50M/F3M	988% / 315%	988% / 315%	988% / 315%	988% / 315%	988% / 315%
B10T	344%	344%	344%	344%	344%
Min/MaxTransientVltg					
Arrowhd 230	0.99 1.02	0.99 1.02	0.98 1.04	0.99 1.04	0.98 1.03
Boise 115	1.00 1.03	1.00 1.03	0.99 1.01	1.00 1.02	1.01 1.03
Dorsey 230	1.04 1.05	1.04 1.05	1.04 1.05	1.04 1.05	1.04 1.05
Forbes 230	1.01 1.03	1.01 1.03	0.99 1.03	1.00 1.03	1.01 1.03
Riverton 230	0.99 1.03	0.99 1.04	0.95 1.04	0.98 1.04	0.98 1.04
Coal Creek 230	0.97 1.11	0.97 1.11	1.02 1.11	1.00 1.16	0.97 1.13
Jamestown 345	0.91 1.03	0.89 1.04	0.86 1.04	0.89 1.05	0.82 1.06
Drayton 230	1.01 1.06	1.00 1.07	0.98 1.07	1.02 1.08	1.00 1.07
Groton 345	0.89 1.03	0.88 1.03	0.89 1.06	0.92 1.06	0.93 1.05
Minong 161	1.01 1.04	1.01 1.04	1.02 1.07	1.03 1.06	1.01 1.04
Wahpeton 115	0.99 1.07	0.97 1.07	0.93 1.08	0.98 1.08	0.96 1.08
Watertown 345	0.96 1.04	0.96 1.04	0.94 1.06	0.97 1.05	0.97 1.05
Dynamic Voltage Warnings					
	none	none	none	none	none
Worst Case Angle Damping	KING 3 / 77.88%	KING 3 / 77.39%	SHERC3 / 22.12%	KING 3 / 30.00%	MNTCE3 / 71.80%
Dorsey SUVP / UdHold					
Forbes DC Red (DCAR)	463%	464%	507%	507%	452%
K22W (max +dP @ t, d-ang)	9.9@(2.44999,2.0)	13.8@(2.40832,0.8)	57.6@(2.40832,-28.0)	40.5@(2.34166,-17.1)	13.3@(2.49166,-1.1)
K22W (max -dP @ t, d-ang)	19.2@(0.79166,5.0)	20.3@(0.74166,5.7)	3.1@(0.46666,0.1)	3.1@(0.30833,0.1)	12.8@(0.73333,2.2)
K22W (max d-ang @ t, dP)	7.3@(1.05833,-7.3)	8.0@(1.00000,-8.9)	-65.6@(20.00806,31.8)	-36.2@(20.00806,18.3)	4.5@(1.04166,-3.9)
OS Rel Trip / Marg					
MH - OH					
D602F at Forbes/Dorsey	198% / -0.01667 sec	195% / -0.01667 sec	158% / -0.01667 sec	188% / -0.01667 sec	207% / -0.01667 sec
G82R at Rugby/L20D at Draytor	-0.01667 sec / 621%	-0.01667 sec / 602%	-0.01667 sec / 536%	-0.01667 sec / 578%	-0.01667 sec / 601%
R50M / F3M	846% / 277%	837% / 274%	790% / 226%	859% / 255%	859% / 281%
B10T	199%	182%	106%	127%	172%
FSCAPS (SS/Unav/Final)					
Balta 230	(0 0 0)	(0 0 0)	(0 0 0)	(0 1 0)	(0 0 0)
Eau Cl 345 / Park Lk 115	(4 4 4) / (0 0 0)	(4 4 4) / (0 0 0)	(4 4 3) / (0 0 0)	(4 4 4) / (0 0 0)	(4 4 4) / (0 0 0)
Prairie 115 / Ramsey 230	(1 2 1) / (0 1 1)	(1 3 1) / (0 2 2)	(1 3 1) / (0 1 1)	(1 3 1) / (0 1 1)	(1 3 1) / (0 2 2)
Roseau 230 / Running 230	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)
Shey 115 / Split Rock 115	(1 2 2) / (1 1 1)	(1 3 2) / (1 2 2)	(1 4 2) / (1 1 1)	(1 4 2) / (1 1 1)	(1 4 1) / (1 1 1)

Case Disturbance	Mb0-so15aa-ag1 ag1	Mb0-so15aa-ag3 ag3	Mb0-so15aa-ei2 ei2	Mb0-so15aa-eq1 eq1	Mb0-so15aa-fds fds
System Response	OK	OK	OK	OK	OK
70% or 120% Violations	(4T)(6T)	(4T)(6T)	(4T)(6T)	(4T)(6T)	(4T)(6T)
ORWG Criteria Violations					
Line Tripping					

Table C-1: Pre-Benchmark Case

1	Case No.	11	12
2	Case Name	Mb0-so15aa-pys	Mb0-so15aa-ptt
3	Disturbance	pys	ptt
4	Prior Outage	None	None
5	Date/Time	APR 15 2009 21:26	APR 15 2009 21:46
6	Comments		
7			
8	Steady State Flows		
9	NDEX / EAST BIAS	2449 / 220	2449 / 220
10	MHEX / L20D	2177 / 271	2177 / 271
11	ECL-ARP / PRI-BYN	626 / 746	626 / 746
12	MWEX / AHD-SLK	1528 / 638	1528 / 638
13	D602F / F601C	0 / 1606	0 / 1606
14	B10T / MH>SPC	164 / 60	164 / 60
15	OH E-W / OH>MH	192 / -195	192 / -195
16	R50M / OH>MP	137 / 152	137 / 152
17	G82R	N/A	N/A
18	Dorsey bipole / CU bipole	1700 / 1104	1700 / 1104
19	Dorsey Reserve / Wtrtn SVC	1864 / 30	1864 / 30
20	Forbes SVC / MSC	18 / 600	18 / 600
21	RCDC	0	0
22	Steady State Vltgs		
23	Dorsey 500/Dorsey 230	1.046 / 1.045	1.046 / 1.045
24	Roseau 500/Forbes 500	1.032 / 1.018	1.032 / 1.018
25	Chisago 500/EauClaire 345	1.018 / 1.028	1.018 / 1.028
26	Int Falls 115/Badoura 115	1.020 / 1.026	1.020 / 1.026
27	Drayton 230/Groton 345	1.028 / 1.009	1.028 / 1.009
28	SS OS Relay Margins		
29	D602F at Forbes/Dorsey	240% / 999%	240% / 999%
30	G82R at Rugby/L20D at Draytor	999% / 744%	999% / 744%
31	R50M/F3M	988% / 315%	988% / 315%
32	B10T	344%	344%
33	Min/MaxTransientVltg		
34	Arrowhd 230	0.98 1.02	0.99 1.01
35	Boise 115	1.00 1.04	1.02 1.03
36	Dorsey 230	1.04 1.06	1.04 1.05
37	Forbes 230	1.02 1.06	1.02 1.03
38	Riverton 230	1.01 1.03	1.02 1.03
39	Coal Creek 230	0.98 1.08	1.02 1.04
40	Jamestown 345	0.94 1.00	0.98 0.99
41	Drayton 230	1.02 1.05	1.02 1.03
42	Groton 345	0.97 1.02	1.00 1.01
43	Minong 161	0.98 1.04	1.00 1.02
44	Wahpeton 115	1.01 1.05	1.03 1.04
45	Watertown 345	1.00 1.03	1.01 1.02
46	Dynamic Voltage Warnings		
47		none	none
48			
49			
50			
51			
52			
53			
54	Worst Case Angle Damping	KING 3 / 74.32%	SHERC3 / 65.46%
55	Dorsey SUVP / UdHold		
56	Forbes DC Red (DCAR)	276%	368%
57	K22W (max +dP @ t, d-ang)	11.2@(2.42499,1.7)	0.0@(0.10000,0.0)
58	K22W (max -dP @ t, d-ang)	29.9@(0.66666,10.9)	21.3@(1.79166,8.2)
59	K22W (max d-ang @ t, dP)	17.1@(1.02500,-21.0)	8.6@(2.12499,-19.0)
60	OS Rel Trip / Marg		
61	MH - OH		
62	D602F at Forbes/Dorsey	194% / -0.01667 sec	240% / -0.01667 sec
63	G82R at Rugby/L20D at Draytor	-0.01667 sec / 596%	-0.01667 sec / 685%
64	R50M / F3M	780% / 294%	957% / 315%
65	B10T	175%	283%
66	FSCAPS (SS/Unav/Final)		
67	Balta 230	(0 0 0)	(0 0 0)
68	Eau Cl 345 / Park Lk 115	(4 4 4) / (0 3 3)	(4 4 4) / (0 0 0)
69	Prairie 115 / Ramsey 230	(1 1 1) / (0 1 1)	(1 1 1) / (0 0 0)
70	Roseau 230 / Running 230	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)
71	Shey 115 / Split Rock 115	(1 1 1) / (1 2 2)	(1 1 1) / (1 1 1)

Case Disturbance	Mb0-so15aa-pys pys	Mb0-so15aa-ptt ptt
System Response	OK	OK
70% or 120% Violations		
ORWG Criteria Violations		
Line Tripping	(4T)(6T)	(4T)(6T)

Table C-2: Benchmark Case

1	2	3	4	5	
Case No.	1	2	3	4	
Case Name	Mhb-so15aa-ag1	Mhb-so15aa-ag3	Mhb-so15aa-ei2	Mhb-so15aa-eq1	
Disturbance	ag1	ag3	ei2	eq1	
Prior Outage	None	None	None	None	
Date/Time	APR 16 2009 8:47	APR 16 2009 9:05	APR 16 2009 9:23	APR 16 2009 9:41	
Comments					
Steady State Flows					
NDEX / EAST BIAS	2318 / 116	2318 / 116	2318 / 116	2318 / 116	
MHEX / L20D	2174 / 301	2174 / 301	2174 / 301	2174 / 301	
ECL-ARP / PRI-BYN	648 / 100	648 / 100	648 / 100	648 / 100	
MWEX / AHD-SLK	1450 / 599	1450 / 599	1450 / 599	1450 / 599	
D602F / F601C	0 / 1494	0 / 1494	0 / 1494	0 / 1494	
B10T / MH>SPC	165 / 61	165 / 61	165 / 61	165 / 61	
OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	
R50M / OH>MP	137 / 151	137 / 151	137 / 151	137 / 151	
G82R	N/A	N/A	N/A	N/A	
Dorsey bipole / CU bipole	1700 / 1104	1700 / 1104	1700 / 1104	1700 / 1104	
Dorsey Reserve / Wtrtn SVC	1922 / -47	1922 / -47	1922 / -47	1922 / -47	
Forbes SVC / MSC	11 / 600	11 / 600	11 / 600	11 / 600	
RCDC	0	0	0	0	
Steady State Vltgs					
Dorsey 500/Dorsey 230	1.043 / 1.045	1.043 / 1.045	1.043 / 1.045	1.043 / 1.045	
Roseau 500/Forbes 500	1.042 / 1.022	1.042 / 1.022	1.042 / 1.022	1.042 / 1.022	
Chisago 500/EauClaire 345	1.019 / 1.028	1.019 / 1.028	1.019 / 1.028	1.019 / 1.028	
Int Falls 115/Badoura 115	1.022 / 1.041	1.022 / 1.041	1.022 / 1.041	1.022 / 1.041	
Drayton 230/Groton 345	1.027 / 1.014	1.027 / 1.014	1.027 / 1.014	1.027 / 1.014	
SS OS Relay Margins					
D602F at Forbes/Dorsey	255% / 999%	255% / 999%	255% / 999%	255% / 999%	
G82R at Rugby/L20D at Draytor	999% / 645%	999% / 645%	999% / 645%	999% / 645%	
R50M/F3M	988% / 320%	988% / 320%	988% / 320%	988% / 320%	
B10T	342%	342%	342%	342%	
Min/MaxTransientVltg					
Arrowhd 230	0.99 1.02	0.99 1.02	0.99 1.04	0.99 1.04	
Boise 115	1.01 1.03	1.01 1.03	1.00 1.02	1.01 1.03	
Dorsey 230	1.04 1.05	1.04 1.05	1.04 1.05	1.04 1.05	
Forbes 230	1.01 1.03	1.01 1.03	1.00 1.04	1.01 1.03	
Riverton 230	1.01 1.04	1.00 1.04	0.98 1.05	1.00 1.05	
Coal Creek 230	0.97 1.11	0.97 1.11	1.02 1.11	1.00 1.16	
Jamestown 345	0.91 1.02	0.90 1.03	0.85 1.04	0.87 1.05	
Drayton 230	1.01 1.05	1.00 1.04	0.98 1.06	1.02 1.07	
Groton 345	0.91 1.04	0.91 1.04	0.92 1.07	0.94 1.07	
Minong 161	1.00 1.03	1.00 1.03	1.01 1.06	1.01 1.05	
Wahpeton 115	1.00 1.07	0.99 1.07	0.96 1.08	0.99 1.08	
Watertown 345	0.99 1.04	0.99 1.04	0.98 1.06	0.99 1.06	
Dynamic Voltage Warnings					
	none	none	none	none	
Worst Case Angle Damping	KING 3 / 73.75%	KING 3 / 76.69%	SHERC3 / 30.25%	KING 3 / 32.97%	MNTCE3 / 70.29%
Dorsey SUVP / UdHold					
Forbes DC Red (DCAR)	457%	451%	507%	507%	453%
K22W (max +dP @ t, d-ang)	9.4@(2.40832,1.8)	11.3@(2.38332,1.4)	57.6@(2.39166,-26.2)	39.7@(2.31666,-16.2)	10.5@(2.45832,-0.6)
K22W (max -dP @ t, d-ang)	16.8@(0.79166,4.5)	18.8@(0.74166,5.4)	2.2@(0.38333,0.1)	2.9@(0.29167,0.2)	11.9@(0.74166,2.3)
K22W (max d-ang @ t, dP)	6.4@(1.04166,-6.8)	7.6@(1.00000,-8.6)	-64.1@(20.00806,30.7)	-35.0@(20.00806,17.4)	4.2@(1.01666,-4.1)
OS Rel Trip / Marg					
MH - OH					
D602F at Forbes/Dorsey	214% / -0.01667 sec	211% / -0.01667 sec	186% / -0.01667 sec	212% / -0.01667 sec	225% / -0.01667 sec
G82R at Rugby/L20D at Draytor	-0.01667 sec / 558%	-0.01667 sec / 549%	-0.01667 sec / 489%	-0.01667 sec / 510%	-0.01667 sec / 558%
R50M / F3M	865% / 284%	852% / 282%	838% / 232%	893% / 256%	878% / 288%
B10T	206%	199%	108%	127%	102%
FSCAPS (SS/Unav/Final)					
Balta 230	(0 0 0)	(0 0 0)	(0 0 0)	(0 1 0)	(0 0 0)
Eau Cl 345 / Park Lk 115	(4 4 4) / (0 0 0)	(4 4 4) / (0 0 0)	(4 4 3) / (0 0 0)	(4 4 4) / (0 0 0)	(4 4 4) / (0 0 0)
Prairie 115 / Ramsey 230	(1 2 1) / (0 1 1)	(1 1 1) / (0 1 1)	(1 3 1) / (0 1 1)	(1 3 1) / (0 1 1)	(1 1 1) / (0 1 1)
Roseau 230 / Running 230	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)
Shey 115 / Split Rock 115	(1 1 1) / (1 1 1)	(1 2 1) / (1 1 1)	(1 4 1) / (1 1 1)	(1 3 1) / (1 1 1)	(1 2 0) / (1 1 1)

Case Disturbance	Mhb-so15aa-ag1 ag1	Mhb-so15aa-ag3 ag3	Mhb-so15aa-ei2 ei2	Mhb-so15aa-eq1 eq1	Mhb-so15aa-fds fuds
System Response	OK	OK	OK	OK	OK
70% or 120% Violations					
ORWG Criteria Violations					
Line Tripping	(4T)(6T)	(4T)(6T)	(4T)(6T)	(4T)(6T)	(4T)(6T)

Table C-2: Benchmark Case

1	Case No.	11	12
2	Case Name	Mhb-so15aa-pzs	Mhb-so15aa-pzt
3	Disturbance	pzs	pzt
4	Prior Outage	None	None
5	Date/Time	APR 16 2009 12:22	APR 16 2009 12:40
6	Comments		
7			
8	Steady State Flows		
9	NDEX / EAST BIAS	2318 / 116	2318 / 116
10	MHEX / L20D	2174 / 301	2174 / 301
11	ECL-ARP / PRI-BYN	648 / 100	648 / 100
12	MWEX / AHD-SLK	1450 / 599	1450 / 599
13	D602F / F601C	0 / 1494	0 / 1494
14	B10T / MH>SPC	165 / 61	165 / 61
15	OH E-W / OH>MH	190 / -196	190 / -196
16	R50M / OH>MP	137 / 151	137 / 151
17	G82R	N/A	N/A
18	Dorsey bipole / CU bipole	1700 / 1104	1700 / 1104
19	Dorsey Reserve / Wtrtn SVC	1922 / -47	1922 / -47
20	Forbes SVC / MSC	11 / 600	11 / 600
21	RCDC	0	0
22	Steady State Vltgs		
23	Dorsey 500/Dorsey 230	1.043 / 1.045	1.043 / 1.045
24	Roseau 500/Forbes 500	1.042 / 1.022	1.042 / 1.022
25	Chisago 500/EauClaire 345	1.019 / 1.028	1.019 / 1.028
26	Int Falls 115/Badoura 115	1.022 / 1.041	1.022 / 1.041
27	Drayton 230/Groton 345	1.027 / 1.014	1.027 / 1.014
28	SS OS Relay Margins		
29	D602F at Forbes/Dorsey	255% / 999%	255% / 999%
30	G82R at Rugby/L20D at Draytor	999% / 645%	999% / 645%
31	R50M/F3M	988% / 320%	988% / 320%
32	B10T	342%	342%
33	Min/MaxTransientVltg		
34	Arrowhd 230	1.00 1.03	1.01 1.01
35	Boise 115	1.00 1.04	1.02 1.02
36	Dorsey 230	1.04 1.06	1.04 1.05
37	Forbes 230	1.02 1.05	1.02 1.03
38	Riverton 230	1.02 1.04	1.03 1.03
39	Coal Creek 230	0.98 1.08	1.03 1.03
40	Jamestown 345	0.93 1.01	0.99 0.99
41	Drayton 230	1.02 1.04	1.03 1.03
42	Groton 345	0.98 1.03	1.01 1.01
43	Minong 161	1.01 1.05	1.01 1.02
44	Wahpeton 115	1.02 1.06	1.04 1.05
45	Watertown 345	1.01 1.04	1.03 1.03
46	Dynamic Voltage Warnings		
47		none	none
48			
49			
50			
51			
52			
53			
54	Worst Case Angle Damping	KING 3 / 72.51%	SHERC3 / 58.30%
55	Dorsey SUVP / UdHold		
56	Forbes DC Red (DCAR)	373%	475%
57	K22W (max +dP @ t, d-ang)	22.7@(2.36666,-4.3)	0.0@(0.10000,0.0)
58	K22W (max -dP @ t, d-ang)	22.6@(0.60833,7.8)	5.3@(1.70000,2.1)
59	K22W (max d-ang @ t, dP)	11.4@(0.91666,-12.8)	2.3@(20.00806,-3.4)
60	OS Rel Trip / Marg		
61	MH - OH		
62	D602F at Forbes/Dorsey	204% / -0.01667 sec	255% / -0.01667 sec
63	G82R at Rugby/L20D at Draytor	-0.01667 sec / 538%	-0.01667 sec / 637%
64	R50M / F3M	806% / 282%	976% / 320%
65	B10T	171%	327%
66	FSCAPS (SS/Unav/Final)		
67	Balta 230	(0 0 0)	(0 0 0)
68	Eau Cl 345 / Park Lk 115	(4 4 4) / (0 3 3)	(4 4 4) / (0 0 0)
69	Prairie 115 / Ramsey 230	(1 1 1) / (0 1 1)	(1 1 1) / (0 0 0)
70	Roseau 230 / Running 230	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)
71	Shey 115 / Split Rock 115	(1 1 1) / (1 2 2)	(1 1 1) / (1 1 1)

Case Disturbance	Mhb-so15aa-pzs pzs	Mhb-so15aa-pzt pzt
System Response 70% or 120% Violations ORWG Criteria Violations Line Tripping	OK (4T)(6T)	OK (4T)(6T)

Table C-3: TSR Study Case with Upgrade Option 1

1	Case No.	11	12	13	14	15
2	Case Name	mh1-so15aa-mjs	mh1-so15aa-mkd	mh1-so15aa-mks	mh1-so15aa-nad	mh1-so15aa-nmz
3	Disturbance	mjs	mkd	mks	nad	nmz
4	Prior Outage	None	None	None	None	None
5	Date/Time	APR 23 2009 18:45	APR 23 2009 18:48	APR 23 2009 18:51	APR 23 2009 18:54	APR 23 2009 18:57
6	Comments					
7						
8	Steady State Flows					
9	NDEX / EAST BIAS	2401 / 173	2401 / 173	2401 / 173	2401 / 173	2401 / 173
10	MHEX / L20D	1887 / 245	1887 / 245	1887 / 245	1887 / 245	1887 / 245
11	ECL-ARP / PRI-BYN	691 / 110	691 / 110	691 / 110	691 / 110	691 / 110
12	MWEX / AHD-SLK	1586 / 644	1586 / 644	1586 / 644	1586 / 644	1586 / 644
13	D602F / F601C	0 / 1241	0 / 1241	0 / 1241	0 / 1241	0 / 1241
14	B10T / MH>SPC	164 / 60	164 / 60	164 / 60	164 / 60	164 / 60
15	OH E-W / OH>MH	190 / -195	190 / -195	190 / -195	190 / -195	190 / -195
16	R50M / OH>MP	130 / 150	130 / 150	130 / 150	130 / 150	130 / 150
17	G82R	N/A	N/A	N/A	N/A	N/A
18	Dorsey bipole / CU bipole	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103
19	Dorsey Reserve / Wttrn SVC	739 / 17	739 / 17	739 / 17	739 / 17	739 / 17
20	Forbes SVC / MSC	-4 / 600	-4 / 600	-4 / 600	-4 / 600	-4 / 600
21	RCDC	0	0	0	0	0
22	Steady State Vltgs					
23	Dorsey 500/Dorsey 230	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045
24	Roseau 500/Forbes 500	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040
25	Chisago 500/EauClaire 345	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019
26	Int Falls 115/Badoura 115	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044
27	Drayton 230/Groton 345	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018
28	SS OS Relay Margins					
29	D602F at Forbes/Dorsey	321% / 536%	321% / 536%	321% / 536%	321% / 536%	321% / 536%
30	G82R at Rugby/L20D at Draytor	999% / 865%	999% / 865%	999% / 865%	999% / 865%	999% / 865%
31	R50M/F3M	999% / 326%	999% / 326%	999% / 326%	999% / 326%	999% / 326%
32	B10T	344%	344%	344%	344%	344%
33	Min/Max Transient Vltg					
34	Arrowhd 230	0.99 1.01	0.95 1.01	0.98 1.02	1.00 1.06	0.97 1.06
35	Boise 115	1.02 1.03	1.02 1.03	1.02 1.03	0.97 1.01	0.98 1.02
36	Dorsey 230	1.04 1.06	1.04 1.05	1.04 1.07	1.04 1.07	1.05 1.08
37	Forbes 230	1.03 1.05	1.03 1.05	1.03 1.05	1.02 1.04	1.02 1.04
38	Riverton 230	1.01 1.04	0.99 1.03	1.01 1.04	1.00 1.05	0.98 1.06
39	Coal Creek 230	0.98 1.07	0.98 1.07	0.97 1.08	1.00 1.06	0.97 1.06
40	Jamestown 345	0.94 1.01	0.93 1.01	0.93 1.01	0.95 1.01	0.90 1.03
41	Drayton 230	1.02 1.04	1.01 1.04	1.02 1.05	1.01 1.05	1.00 1.07
42	Groton 345	0.98 1.03	0.97 1.03	0.97 1.03	0.99 1.03	0.94 1.05
43	Minong 161	1.00 1.02	0.96 1.03	1.00 1.04	1.02 1.08	1.00 1.08
44	Wahpeton 115	1.02 1.05	1.01 1.05	1.01 1.06	1.01 1.06	0.99 1.08
45	Watertown 345	1.01 1.03	1.00 1.03	1.00 1.03	1.01 1.04	0.98 1.05
46	Dynamic Voltage Warnings					
47		none	none	none	none	none
48						
49						
50						
51						
52						
53						
54	Worst Case Angle Damping	SHERC3 / 84.78%	KING 3 / 76.24%	SHERC3 / 80.02%	KING 3 / 38.63%	KING 3 / 37.83%
55	Dorsey SUVP / UdHold	/ 0.133	/ 0.133	/ 0.133	/ 0.133	/ 0.133
56	Forbes DC Red (DCAR)	462%	327%	390%	507%	507%
57	K22W (max +dP @ t, d-ang)	2.9@(0.11667,0.3)	11.7@(0.10833,1.4)	8.6@(2.29166,0.5)	75.0@(2.03333,-36.0)	91.2@(2.11666,-40.6)
58	K22W (max -dP @ t, d-ang)	17.0@(0.35833,2.7)	26.6@(0.21667,3.3)	28.0@(0.37500,5.2)	59.3@(0.25000,6.6)	45.2@(0.22500,4.3)
59	K22W (max d-ang @ t, dP)	4.8@(0.80000,-5.2)	11.9@(0.78333,-10.2)	8.7@(0.72500,-7.7)	-61.2@(10.00821,35.0)	-65.0@(10.00821,49.5)
60	OS Rel Trip / Marg					
61	MH - OH					
62	D602F at Forbes/Dorsey	307% / 521%	321% / 536%	292% / 509%	0.16667 sec / 0.16667 sec	0.18333 sec / 0.18333 sec
63	G82R at Rugby/L20D at Draytor	999% / 793%	999% / 729%	999% / 764%	999% / 610%	999% / 756%
64	R50M / F3M	995% / 326%	955% / 326%	956% / 320%	578% / 179%	746% / 200%
65	B10T	245%	197%	209%	192%	154%
66	FSCAPS (SS/Unav/Final)					
67	Balta 230	(0 0 0 0)	(0 0 0 0)	(0 0 0 0)	(0 0 0 0)	(0 0 0 0)
68	Eau Cl 345 / Park Lk 115	(4 4 4 0)/(0 0 0 0)	(4 4 4 0)/(0 0 0 0)	(4 4 4 0)/(0 0 0 0)	(4 4 3 0)/(0 0 0 0)	(4 4 3 0)/(0 0 0 0)
69	Prairie 115 / Ramsey 230	(1 1 1 1)/(0 1 1 1)	(1 1 1 1)/(0 1 1 1)	(1 1 1 1)/(0 1 1 1)	(1 1 1 1)/(0 0 0 0)	(1 1 1 1)/(0 1 1 1)
70	Roseau 230 / Running 230	(0 0 0 0)/(1 1 1 1)	(0 0 0 0)/(1 1 1 1)	(0 0 0 0)/(1 1 1 1)	(0 0 0 0)/(1 1 2 2)	(0 0 0 0)/(1 1 1 1)
71	Shey 115 / Split Rock 115	(0 0 0 0)/(1 1 1 1)	(0 0 0 0)/(1 2 2 2)	(0 0 0 0)/(1 1 1 1)	(0 0 0 0)/(1 1 2 2)	(0 1 1 0)/(1 1 2 2)

Case Disturbance	mh1-so15aa-mjs mjs	mh1-so15aa-mkd mkd	mh1-so15aa-mks mks	mh1-so15aa-nad nad	mh1-so15aa-nmz nmz
System Response 70% or 120% Violations ORWG Criteria Violations Line Tripping	OK	OK	OK	OK	OK
				(5T)(6T)	(5T)(6T)

Table C-3: TSR Study Case with Upgrade Option 1

1	Case No.	16	17	18	19	20
2	Case Name	mh1-so15aa-pas	mh1-so15aa-pc0	mh1-so15aa-pcs	mh1-so15aa-pct	mh1-so15aa-pzs
3	Disturbance	pas	pc0	pcs	pct	pzs
4	Prior Outage	None	None	None	None	None
5	Date/Time	APR 23 2009 19:00	APR 23 2009 19:03	APR 23 2009 19:06	APR 23 2009 19:09	APR 23 2009 19:12
6	Comments					
7						
8	Steady State Flows					
9	NDEX / EAST BIAS	2401 / 173	2401 / 173	2401 / 173	2401 / 173	2401 / 173
10	MHEX / L20D	1887 / 245	1887 / 245	1887 / 245	1887 / 245	1887 / 245
11	ECL-ARP / PRI-BYN	691 / 110	691 / 110	691 / 110	691 / 110	691 / 110
12	MWEX / AHD-SLK	1586 / 644	1586 / 644	1586 / 644	1586 / 644	1586 / 644
13	D602F / F601C	0 / 1241	0 / 1241	0 / 1241	0 / 1241	0 / 1241
14	B10T / MH>SPC	164 / 60	164 / 60	164 / 60	164 / 60	164 / 60
15	OH E-W / OH>MH	190 / -195	190 / -195	190 / -195	190 / -195	190 / -195
16	R50M / OH>MP	130 / 150	130 / 150	130 / 150	130 / 150	130 / 150
17	G82R	N/A	N/A	N/A	N/A	N/A
18	Dorsey bipole / CU bipole	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103
19	Dorsey Reserve / Wttrn SVC	739 / 17	739 / 17	739 / 17	739 / 17	739 / 17
20	Forbes SVC / MSC	-4 / 600	-4 / 600	-4 / 600	-4 / 600	-4 / 600
21	RCDC	0	0	0	0	0
22	Steady State Vltgs					
23	Dorsey 500/Dorsey 230	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045
24	Roseau 500/Forbes 500	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040
25	Chisago 500/EauClaire 345	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019
26	Int Falls 115/Badoura 115	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044
27	Drayton 230/Groton 345	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018
28	SS OS Relay Margins					
29	D602F at Forbes/Dorsey	321% / 536%	321% / 536%	321% / 536%	321% / 536%	321% / 536%
30	G82R at Rugby/L20D at Drayton	999% / 865%	999% / 865%	999% / 865%	999% / 865%	999% / 865%
31	R50M/F3M	999% / 326%	999% / 326%	999% / 326%	999% / 326%	999% / 326%
32	B10T	344%	344%	344%	344%	344%
33	Min/Max Transient Vltg					
34	Arrowhd 230	0.99 1.06	0.89 0.99	0.89 0.98	0.95 0.97	0.99 1.03
35	Boise 115	0.98 1.01	1.01 1.04	1.01 1.04	1.02 1.03	1.01 1.04
36	Dorsey 230	1.05 1.07	1.03 1.08	1.03 1.08	1.04 1.05	1.03 1.07
37	Forbes 230	0.99 1.04	1.03 1.06	1.02 1.06	1.03 1.03	1.03 1.06
38	Riverton 230	1.00 1.05	1.01 1.04	1.01 1.04	1.03 1.04	1.02 1.05
39	Coal Creek 230	1.00 1.06	0.97 1.08	0.97 1.08	1.02 1.04	0.98 1.08
40	Jamestown 345	0.96 1.01	0.95 1.02	0.95 1.01	0.99 1.01	0.95 1.02
41	Drayton 230	1.02 1.06	1.03 1.05	1.03 1.05	1.03 1.04	1.03 1.05
42	Groton 345	0.99 1.03	0.98 1.03	0.98 1.03	1.01 1.02	0.99 1.03
43	Minong 161	1.02 1.07	0.87 1.01	0.87 0.99	0.94 0.98	0.99 1.05
44	Wahpeton 115	1.02 1.06	1.03 1.06	1.03 1.06	1.04 1.06	1.03 1.06
45	Watertown 345	1.01 1.04	1.00 1.04	1.01 1.04	1.02 1.03	1.01 1.04
46	Dynamic Voltage Warnings					
47		none	none	none	none	none
48						
49						
50						
51						
52						
53						
54	Worst Case Angle Damping	KING 3 / 42.23%	SHERC3 / 74.48%	SHERC3 / 73.51%	SHERC3 / 58.84%	KING 3 / 68.28%
55	Dorsey SUVP / UdHold	/ 0.150				
56	Forbes DC Red (DCAR)	394%	279%	264%	364%	362%
57	K22W (max +dP @ t, d-ang)	73.7@(2.0333,-33.7)	8.3@(3.28331,0.5)	2.6@(0.10833,0.4)	0.0@(0.10000,0.0)	20.1@(2.32499,-2.4)
58	K22W (max -dP @ t, d-ang)	41.0@(.25833,3.7)	38.6@(.39166,6.8)	38.7@(.39166,6.8)	29.6@(.194166,12.4)	29.0@(0.39166,4.7)
59	K22W (max d-ang @ t, dP)	-57.8@(.10.00821,39.6)	20.2@(.96666,-24.3)	20.7@(.99166,-26.4)	12.4@(.193333,-29.6)	12.6@(.086666,-11.4)
60	OS Rel Trip / Marg					
61	MH - OH					
62	D602F at Forbes/Dorsey	0.38333 sec / 0.18333 sec	281% / 466%	286% / 474%	321% / 535%	269% / 447%
63	G82R at Rugby/L20D at Drayton	999% / 670%	999% / 709%	999% / 718%	999% / 814%	999% / 748%
64	R50M / F3M	642% / 208%	852% / 316%	859% / 326%	985% / 326%	892% / 299%
65	B10T	221%	171%	181%	286%	182%
66	FSCAPS (SS/Unav/Final)					
67	Balta 230	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)
68	Eau Cl 345 / Park Lk 115	(4 4 3)/(0 0 0)	(4 4 4)/(0 3 3)	(4 4 3)/(0 3 3)	(4 4 3)/(0 0 0)	(4 4 4)/(0 3 3)
69	Prairie 115 / Ramsey 230	(1 1 1)/(0 0 0)	(1 1 1)/(0 1 1)	(1 1 1)/(0 1 1)	(1 1 1)/(0 0 0)	(1 1 1)/(0 1 1)
70	Roseau 230 / Running 230	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)
71	Shey 115 / Split Rock 115	(0 0 0)/(1 1 1)	(0 1 1)/(1 2 2)	(0 0 0)/(1 2 2)	(0 0 0)/(1 1 1)	(0 0 0)/(1 2 2)

Case Disturbance	mh1-so15aa-pas	mh1-so15aa-pc0	mh1-so15aa-pcs	mh1-so15aa-pct	mh1-so15aa-pzs
System Response 70% or 120% Violations ORWG Criteria Violations Line Tripping	OK	OK	OK	OK	OK

Table C-3: TSR Study Case with Upgrade Option 1

1	Case No.	21	22	23	24	25
2	Case Name	mh1-so15aa-pzt	mh1-so15aa-ya3	mh1-so15aa-yas	mh1-so15aa-yb3	mh1-so15aa-h13
3	Disturbance	pzt	ya3	yas	yb3	h13
4	Prior Outage	None	None	None	None	None
5	Date/Time	APR 23 2009 19:14	APR 23 2009 20:08	APR 23 2009 20:10	APR 23 2009 20:13	APR 23 2009 19:32
6	Comments					
7						
8	Steady State Flows					
9	NDEX / EAST BIAS	2401 / 173	2401 / 173	2401 / 173	2401 / 173	2401 / 173
10	MHEX / L20D	1887 / 245	1887 / 245	1887 / 245	1887 / 245	1887 / 245
11	ECL-ARP / PRI-BYN	691 / 110	691 / 110	691 / 110	691 / 110	691 / 110
12	MWEX / AHD-SLK	1586 / 644	1586 / 644	1586 / 644	1586 / 644	1586 / 644
13	D602F / F601C	0 / 1241	0 / 1241	0 / 1241	0 / 1241	0 / 1241
14	B10T / MH>SPC	164 / 60	164 / 60	164 / 60	164 / 60	164 / 60
15	OH E-W / OH>MH	190 / -195	190 / -195	190 / -195	190 / -195	190 / -195
16	R50M / OH>MP	130 / 150	130 / 150	130 / 150	130 / 150	130 / 150
17	G82R	N/A	N/A	N/A	N/A	N/A
18	Dorsey bipole / CU bipole	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103
19	Dorsey Reserve / Wtrtn SVC	739 / 17	739 / 17	739 / 17	739 / 17	739 / 17
20	Forbes SVC / MSC	-4 / 600	-4 / 600	-4 / 600	-4 / 600	-4 / 600
21	RCDC	0	0	0	0	0
22	Steady State Vltgs					
23	Dorsey 500/Dorsey 230	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045
24	Roseau 500/Forbes 500	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040
25	Chisago 500/EauClaire 345	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019
26	Int Falls 115/Badoura 115	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044
27	Drayton 230/Groton 345	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018
28	SS OS Relay Margins					
29	D602F at Forbes/Dorsey	321% / 536%	321% / 536%	321% / 536%	321% / 536%	321% / 536%
30	G82R at Rugby/L20D at Draytor	999% / 865%	999% / 865%	999% / 865%	999% / 865%	999% / 865%
31	R50M/F3M	999% / 326%	999% / 326%	999% / 326%	999% / 326%	999% / 326%
32	B10T	344%	344%	344%	344%	344%
33	Min/Max TransientVltg					
34	Arrowhd 230	1.00 1.01	1.01 1.02	0.96 0.99	1.03 1.05	1.00 1.03
35	Boise 115	1.02 1.03	1.03 1.04	1.03 1.04	1.03 1.04	1.01 1.03
36	Dorsey 230	1.04 1.05	1.04 1.05	1.04 1.07	1.04 1.05	1.01 1.05
37	Forbes 230	1.04 1.04	1.03 1.04	1.03 1.05	1.04 1.04	1.03 1.04
38	Riverton 230	1.03 1.04	1.02 1.03	1.02 1.03	1.03 1.03	1.03 1.04
39	Coal Creek 230	1.03 1.04	1.02 1.04	1.00 1.05	1.03 1.04	1.02 1.06
40	Jamestown 345	1.00 1.00	0.99 1.00	0.99 1.01	0.99 1.00	0.98 1.01
41	Drayton 230	1.04 1.04	1.03 1.05	1.03 1.05	1.03 1.04	1.02 1.05
42	Groton 345	1.01 1.02	1.01 1.02	1.01 1.02	1.01 1.02	1.01 1.04
43	Minong 161	1.01 1.02	0.97 0.99	0.97 1.04	0.98 1.00	1.01 1.04
44	Wahpeton 115	1.05 1.05	1.04 1.05	1.04 1.05	1.04 1.05	1.04 1.06
45	Watertown 345	1.03 1.03	1.02 1.03	1.02 1.03	1.02 1.03	1.02 1.04
46	Dynamic Voltage Warnings					
47		none	none		none	none
48						
49						
50						
51						
52						
53						
54	Worst Case Angle Damping	SHERC3 / 56.31%	SHERC3 / 53.94%	ANTEL3 / 71.81%	KING 3 / 56.12%	MNTCE3 / 70.97%
55	Dorsey SUVP / UdHold					/ 0.133
56	Forbes DC Red (DCAR)	467%	391%	439%	418%	473%
57	K22W (max +dP @ t, d-ang)	0.0@(0.10000,0.0)	5.2@(0.11667,0.7)	3.1@(0.11667,0.3)	3.5@(0.11667,0.5)	102.8@(0.15000,-2.1)
58	K22W (max -dP @ t, d-ang)	8.2@(.169166,3.3)	23.5@(.163333,11.2)	19.0@(.156666,8.6)	17.1@(.160000,8.0)	17.0@(.294165,3.5)
59	K22W (max d-ang @ t, dP)	3.4@(.205000,-7.8)	11.4@(.185000,-21.6)	9.3@(.100833,-11.8)	8.1@(.183333,-15.3)	-7.7@(.065833,0.3)
60	OS Rel Trip / Marg					
61	MH - OH					
62	D602F at Forbes/Dorsey	321% / 536%	321% / 536%	321% / 536%	321% / 536%	305% / 509%
63	G82R at Rugby/L20D at Draytor	999% / 850%	999% / 812%	999% / 820%	999% / 826%	999% / 787%
64	R50M / F3M	999% / 326%	999% / 326%	999% / 326%	999% / 326%	966% / 268%
65	B10T	324%	279%	286%	294%	194%
66	FSCAPS (SS/Unav/Final)					
67	Balta 230	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)
68	Eau Cl 345 / Park Lk 115	(4 4 4) / (0 0 0)	(4 4 4) / (0 0 0)	(4 4 4) / (0 0 0)	(4 4 4) / (0 0 0)	(4 4 4) / (0 0 0)
69	Prairie 115 / Ramsey 230	(1 1 1) / (0 0 0)	(1 1 1) / (0 0 0)	(1 1 1) / (0 0 0)	(1 1 1) / (0 0 0)	(1 1 1) / (0 0 0)
70	Roseau 230 / Running 230	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)
71	Shey 115 / Split Rock 115	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 2 2)

Case Disturbance	mh1-so15aa-pzt pzt	mh1-so15aa-ya3 ya3	mh1-so15aa-yas yas	mh1-so15aa-yb3 yb3	mh1-so15aa-h13 h13
System Response 70% or 120% Violations ORWG Criteria Violations Line Tripping	OK	OK	OK	OK	OK

Table C-3: TSR Study Case with Upgrade Option 1

1	Case No.	26	27	28	29	30
2	Case Name	mh1-so15aa-h23	mh1-so15aa-h33	mh1-so15aa-h43	mh1-so15aa-h53	mh1-so15aa-h63
3	Disturbance	h23	h33	h43	h53	h63
4	Prior Outage	None	None	None	None	None
5	Date/Time	APR 23 2009 19:35	APR 23 2009 19:38	APR 23 2009 19:41	APR 23 2009 19:44	APR 23 2009 19:47
6	Comments					
7						
8	Steady State Flows					
9	NDEX / EAST BIAS	2401 / 173	2401 / 173	2401 / 173	2401 / 173	2401 / 173
10	MHEX / L20D	1887 / 245	1887 / 245	1887 / 245	1887 / 245	1887 / 245
11	ECL-ARP / PRI-BYN	691 / 110	691 / 110	691 / 110	691 / 110	691 / 110
12	MWEX / AHD-SLK	1586 / 644	1586 / 644	1586 / 644	1586 / 644	1586 / 644
13	D602F / F601C	0 / 1241	0 / 1241	0 / 1241	0 / 1241	0 / 1241
14	B10T / MH>SPC	164 / 60	164 / 60	164 / 60	164 / 60	164 / 60
15	OH E-W / OH>MH	190 / -195	190 / -195	190 / -195	190 / -195	190 / -195
16	R50M / OH>MP	130 / 150	130 / 150	130 / 150	130 / 150	130 / 150
17	G82R	N/A	N/A	N/A	N/A	N/A
18	Dorsey bipole / CU bipole	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103
19	Dorsey Reserve / Wtrtn SVC	739 / 17	739 / 17	739 / 17	739 / 17	739 / 17
20	Forbes SVC / MSC	-4 / 600	-4 / 600	-4 / 600	-4 / 600	-4 / 600
21	RCDC	0	0	0	0	0
22	Steady State Vltgs					
23	Dorsey 500/Dorsey 230	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045
24	Roseau 500/Forbes 500	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040
25	Chisago 500/EauClaire 345	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019
26	Int Falls 115/Badoura 115	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044
27	Drayton 230/Groton 345	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018
28	SS OS Relay Margins					
29	D602F at Forbes/Dorsey	321% / 536%	321% / 536%	321% / 536%	321% / 536%	321% / 536%
30	G82R at Rugby/L20D at Drayton	999% / 865%	999% / 865%	999% / 865%	999% / 865%	999% / 865%
31	R50M/F3M	999% / 326%	999% / 326%	999% / 326%	999% / 326%	999% / 326%
32	B10T	344%	344%	344%	344%	344%
33	Min/Max Transient Vltg					
34	Arrowhd 230	1.02 1.05	1.02 1.07	1.00 1.03	0.98 1.05	0.97 1.03
35	Boise 115	1.01 1.03	0.97 1.00	1.00 1.02	1.00 1.02	1.01 1.03
36	Dorsey 230	1.03 1.06	1.04 1.07	1.00 1.04	1.04 1.07	1.03 1.05
37	Forbes 230	1.04 1.05	1.05 1.07	1.03 1.04	1.03 1.05	1.03 1.04
38	Riverton 230	1.04 1.05	1.03 1.05	1.03 1.04	1.01 1.04	1.02 1.04
39	Coal Creek 230	1.02 1.06	1.02 1.07	1.02 1.06	1.00 1.05	1.01 1.07
40	Jamestown 345	0.99 1.02	0.97 1.01	0.98 1.00	0.95 0.99	0.98 1.01
41	Drayton 230	1.04 1.06	1.02 1.05	1.02 1.04	1.02 1.05	1.02 1.04
42	Groton 345	1.01 1.05	1.00 1.03	1.01 1.03	0.99 1.03	1.00 1.03
43	Minong 161	1.02 1.07	1.03 1.08	1.01 1.04	0.99 1.07	0.98 1.06
44	Wahpeton 115	1.06 1.07	1.03 1.06	1.04 1.05	1.02 1.05	1.04 1.06
45	Watertown 345	1.03 1.05	1.02 1.04	1.02 1.04	1.01 1.04	1.01 1.04
46	Dynamic Voltage Warnings					
47		none	none	none	none	none
48						
49						
50						
51						
52						
53						
54	Worst Case Angle Damping	KING 3 / 26.66%	KING 3 / 34.84%	MNTCE3 / 70.83%	KING 3 / 45.08%	KING 3 / 77.16%
55	Dorsey SUVP / UdHold	/ 0.133	/ 0.133	/ 0.133	/ 0.133	/ 0.133
56	Forbes DC Red (DCAR)	454%	507%	478%	507%	380%
57	K22W (max +dP @ t, d-ang)	102.8@(0.15000,-.21)	96.6@(0.15000,-.18)	96.6@(0.15000,-.18)	80.7@(2.08333,-30.7)	21.6@(2.22499,-2.6)
58	K22W (max -dP @ t, d-ang)	0.0@(0.01667,0.0)	17.9@(0.25000,0.6)	30.1@(2.93332,7.1)	60.2@(0.26667,6.1)	38.4@(0.26667,5.3)
59	K22W (max d-ang @ t, dP)	-36.7@(10.00821,41.6)	-62.2@(10.00821,36.4)	7.7@(2.64165,-22.9)	-52.7@(10.00821,41.0)	14.2@(0.76666,-11.7)
60	OS Rel Trip / Marg					
61	MH - OH					
62	D602F at Forbes/Dorsey	321% / 536%	0.18333 sec / 0.18333 sec	312% / 517%	232% / 392%	248% / 414%
63	S82R at Rugby/L20D at Drayton	999% / 865%	999% / 765%	999% / 674%	999% / 616%	999% / 751%
64	R50M / F3M	999% / 259%	610% / 173%	792% / 266%	829% / 232%	843% / 285%
65	B10T	286%	235%	264%	167%	194%
66	FSCAPS (SS/Unav/Final)					
67	Balta 230	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)
68	Eau Cl 345 / Park Lk 115	(4 4 3)/(0 0 0)	(4 4 3)/(0 0 0)	(4 4 4)/(0 0 0)	(4 4 3)/(0 0 0)	(4 4 4)/(0 0 0)
69	Prairie 115 / Ramsey 230	(1 1 1)/(0 0 0)	(1 1 1)/(0 0 0)	(1 1 1)/(0 0 0)	(1 1 1)/(0 0 0)	(1 1 1)/(0 0 0)
70	Roseau 230 / Running 230	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)
71	Shey 115 / Split Rock 115	(0 0 0)/(1 2 2)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 2 2)	(0 0 0)/(1 2 2)

Case Disturbance	mh1-so15aa-h23 h23	mh1-so15aa-h33 h33	mh1-so15aa-h43 h43	mh1-so15aa-h53 h53	mh1-so15aa-h63 h63
System Response 70% or 120% Violations ORWG Criteria Violations Line Tripping	OK	OK	OK	OK	OK
		(5T)(6T)			

Table C-3: TSR Study Case with Upgrade Option 1

1	Case No.	31	32	33	34	35
2	Case Name	mh1-so15aa-h73	mh1-so15aa-h83	mh1-so15aa-h93	mh1-so15aa-hes	mh1-so15aa-hgs
3	Disturbance	h73	h83	h93	hes	hgs
4	Prior Outage	None	None	None	None	None
5	Date/Time	APR 23 2009 19:50	APR 23 2009 19:53	APR 23 2009 19:56	APR 23 2009 19:58	APR 23 2009 20:01
6	Comments					
7						
8	Steady State Flows					
9	NDEX / EAST BIAS	2401 / 173	2401 / 173	2401 / 173	2401 / 173	2401 / 173
10	MHEX / L20D	1887 / 245	1887 / 245	1887 / 245	1887 / 245	1887 / 245
11	ECL-ARP / PRI-BYN	691 / 110	691 / 110	691 / 110	691 / 110	691 / 110
12	MWEX / AHD-SLK	1586 / 644	1586 / 644	1586 / 644	1586 / 644	1586 / 644
13	D602F / F601C	0 / 1241	0 / 1241	0 / 1241	0 / 1241	0 / 1241
14	B10T / MH>SPC	164 / 60	164 / 60	164 / 60	164 / 60	164 / 60
15	OH E-W / OH>MH	190 / -195	190 / -195	190 / -195	190 / -195	190 / -195
16	R50M / OH>MP	130 / 150	130 / 150	130 / 150	130 / 150	130 / 150
17	G82R	N/A	N/A	N/A	N/A	N/A
18	Dorsey bipole / CU bipole	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103
19	Dorsey Reserve / Wttrn SVC	739 / 17	739 / 17	739 / 17	739 / 17	739 / 17
20	Forbes SVC / MSC	-4 / 600	-4 / 600	-4 / 600	-4 / 600	-4 / 600
21	RCDC	0	0	0	0	0
22	Steady State Vltgs					
23	Dorsey 500/Dorsey 230	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045
24	Roseau 500/Forbes 500	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040
25	Chisago 500/EauClaire 345	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019
26	Int Falls 115/Badoura 115	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044
27	Drayton 230/Groton 345	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018
28	SS OS Relay Margins					
29	D602F at Forbes/Dorsey	321% / 536%	321% / 536%	321% / 536%	321% / 536%	321% / 536%
30	G82R at Rugby/L20D at Draytor	999% / 865%	999% / 865%	999% / 865%	999% / 865%	999% / 865%
31	R50M/F3M	999% / 326%	999% / 326%	999% / 326%	999% / 326%	999% / 326%
32	B10T	344%	344%	344%	344%	344%
33	Min/Max Transient Vltg					
34	Arrowhd 230	1.01 1.04	0.99 1.02	0.99 1.01	1.02 1.07	0.97 1.06
35	Boise 115	1.00 1.02	1.02 1.03	1.02 1.03	0.99 1.06	0.99 1.03
36	Dorsey 230	1.04 1.07	1.03 1.05	1.03 1.05	1.05 1.19	1.05 1.07
37	Forbes 230	1.02 1.05	1.03 1.05	1.03 1.04	1.04 1.08	1.02 1.05
38	Riverton 230	1.02 1.04	1.02 1.04	1.01 1.03	1.03 1.05	1.00 1.05
39	Coal Creek 230	1.02 1.06	1.00 1.07	0.99 1.07	1.02 1.06	0.99 1.06
40	Jamestown 345	0.94 0.99	0.96 1.00	0.96 1.01	0.96 1.00	0.95 1.01
41	Drayton 230	1.02 1.05	1.02 1.04	1.03 1.05	1.05 1.15	1.02 1.06
42	Groton 345	0.99 1.03	1.00 1.03	0.99 1.03	0.99 1.04	0.97 1.04
43	Minong 161	1.03 1.06	0.99 1.03	0.99 1.02	1.03 1.08	0.98 1.08
44	Wahpeton 115	1.02 1.05	1.03 1.06	1.03 1.05	1.03 1.06	1.01 1.07
45	Watertown 345	1.02 1.04	1.02 1.04	1.02 1.03	1.02 1.04	1.00 1.04
46	Dynamic Voltage Warnings					
47		none	none	none		none
48						
49						
50						
51						
52						
53						
54	Worst Case Angle Damping	KING 3 / 35.33%	KING 3 / 70.25%	KING 3 / 72.88%	KING 3 / 35.46%	KING 3 / 52.90%
55	Dorsey SUVP / UdHold	/ 0.133	/ 0.133	/ 0.133	/ 0.133	/ 0.158
56	Forbes DC Red (DCAR)	507%	452%	471%	378%	507%
57	K22W (max +dP @ t, d-ang)	102.8@(0.15000,-2.1)	28.9@(0.11667,0.6)	20.3@(0.11667,0.6)	154.4@(1.51666,-45.6)	91.7@(2.19999,-33.6)
58	K22W (max -dP @ t, d-ang)	12.1@(0.25000,0.9)	37.4@(0.28333,5.1)	31.8@(0.26667,4.0)	58.5@(0.39166,6.6)	48.5@(0.27500,5.0)
59	K22W (max d-ang @ t, dP)	-53.8@(10.00821,40.6)	7.2@(0.54166,-3.0)	7.0@(0.62500,-4.4)	-84.1@(10.00821,87.7)	-52.1@(10.00821,39.1)
60	OS Rel Trip / Marg					
61	MH - OH					
62	D602F at Forbes/Dorsey	259% / 437%	261% / 437%	268% / 448%	61% / 85%	200% / 335%
63	G82R at Rugby/L20D at Draytor	999% / 749%	999% / 693%	999% / 803%	999% / 387%	999% / 628%
64	R50M / F3M	999% / 234%	868% / 309%	916% / 307%	524% / 195%	821% / 217%
65	B10T	214%	231%	241%	201%	109%
66	FSCAPS (SS/Unav/Final)					
67	Balta 230	(0 0 0)	(0 0 0)	(0 0 0)	(0 1 1)	(0 0 0)
68	Eau Cl 345 / Park Lk 115	(4 4 3)/(0 0 0)	(4 4 4)/(0 0 0)	(4 4 4)/(0 0 0)	(4 4 3)/(0 0 0)	(4 4 3)/(0 0 0)
69	Prairie 115 / Ramsey 230	(1 1 1)/(0 0 0)	(1 1 1)/(0 0 0)	(1 1 1)/(0 0 0)	(1 5 1)/(0 1 0)	(1 1 1)/(0 0 0)
70	Roseau 230 / Running 230	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 1 0)/(1 2 0)	(0 0 0)/(1 1 1)
71	Shey 115 / Split Rock 115	(0 0 0)/(1 2 2)	(0 0 0)/(1 2 2)	(0 0 0)/(1 2 2)	(0 1 1)/(1 1 1)	(0 2 2)/(1 2 2)

Case Disturbance	mh1-so15aa-h73 h73	mh1-so15aa-h83 h83	mh1-so15aa-h93 h93	mh1-so15aa-hes hes	mh1-so15aa-hgs hgs
System Response 70% or 120% Violations ORWG Criteria Violations Line Tripping	OK	OK	OK	OK	OK

Table C-3: TSR Study Case with Upgrade Option 1

1	Case No.	36	37	38	39
2	Case Name	mh1-so15aa-hhs	mh1-so15aa-hjs	mh1-so15aa-hks	m1a-so15aa-he3
3	Disturbance	hhs	hjs	hks	he3
4	Prior Outage	None	None	None	None
5	Date/Time	APR 23 2009 20:04	APR 23 2009 20:15	APR 23 2009 20:18	APR 23 2009 20:21
6	Comments				
7					
8	Steady State Flows				
9	NDEX / EAST BIAS	2401 / 173	2401 / 173	2401 / 173	2401 / 173
10	MHEX / L20D	1887 / 245	1887 / 245	1887 / 245	1887 / 245
11	ECL-ARP / PRI-BYN	691 / 110	691 / 110	691 / 110	691 / 110
12	MWEX / AHD-SLK	1586 / 644	1586 / 644	1586 / 644	1586 / 644
13	D602F / F601C	0 / 1241	0 / 1241	0 / 1241	0 / 1241
14	B10T / MH>SPC	164 / 60	164 / 60	164 / 60	164 / 60
15	OH E-W / OH>MH	190 / -195	190 / -195	190 / -195	190 / -195
16	R50M / OH>MP	130 / 150	130 / 150	130 / 150	130 / 150
17	G82R	N/A	N/A	N/A	N/A
18	Dorsey bipole / CU bipole	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103
19	Dorsey Reserve / Wtrtn SVC	739 / 17	739 / 17	739 / 17	739 / 17
20	Forbes SVC / MSC	-4 / 600	-4 / 600	-4 / 600	-4 / 600
21	RCDC	0	0	0	0
22	Steady State Vltgs				
23	Dorsey 500/Dorsey 230	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045	1.045 / 1.045
24	Roseau 500/Forbes 500	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040	1.046 / 1.040
25	Chisago 500/EauClaire 345	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019	1.034 / 1.019
26	Int Falls 115/Badoura 115	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044	1.024 / 1.044
27	Drayton 230/Groton 345	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018	1.038 / 1.018
28	SS OS Relay Margins				
29	D602F at Forbes/Dorsey	321% / 536%	321% / 536%	321% / 536%	321% / 536%
30	G82R at Rugby/L20D at Draytor	999% / 865%	999% / 865%	999% / 865%	999% / 865%
31	R50M/F3M	999% / 326%	999% / 326%	999% / 326%	999% / 326%
32	B10T	344%	344%	344%	344%
33	Min/Max Transient Vltg				
34	Arrowhd 230	0.99 1.04	0.98 1.03	0.99 1.04	0.97 1.03
35	Boise 115	1.00 1.02	1.01 1.04	1.00 1.05	1.01 1.03
36	Dorsey 230	1.05 1.07	1.03 1.09	1.04 1.17	1.03 1.05
37	Forbes 230	1.03 1.04	1.03 1.07	1.02 1.06	1.03 1.04
38	Riverton 230	1.01 1.04	1.03 1.04	1.02 1.04	1.02 1.04
39	Coal Creek 230	0.97 1.07	1.01 1.06	0.99 1.06	1.01 1.06
40	Jamestown 345	0.94 1.00	0.99 1.02	0.96 1.00	0.98 1.01
41	Drayton 230	1.05 1.09	1.03 1.09	1.04 1.14	1.02 1.04
42	Groton 345	0.96 1.03	1.00 1.03	0.98 1.03	1.00 1.03
43	Minong 161	1.00 1.06	0.99 1.05	1.00 1.06	0.98 1.05
44	Wahpeton 115	1.02 1.05	1.05 1.07	1.03 1.05	1.04 1.06
45	Watertown 345	1.00 1.04	1.01 1.04	1.01 1.03	1.01 1.04
46	Dynamic Voltage Warnings				
47		none	none		none
48					
49					
50					
51					
52					
53					
54	Worst Case Angle Damping	KING 3 / 41.38%	KING 3 / 73.44%	KING 3 / 41.48%	KING 3 / 76.99%
55	Dorsey SUVP / UdHold	/ 0.133	/ 0.158	/ 0.133	/ 0.133
56	Forbes DC Red (DCAR)	507%	379%	507%	379%
57	K22W (max +dP @ t, d-ang)	73.2@ (2.11666,-30.5)	18.5@ (2.29999,-1.6)	77.0@ (2.19166,-30.1)	19.3@ (2.23333,-1.9)
58	K22W (max -dP @ t, d-ang)	42.4@ (0.26667,3.8)	43.2@ (0.39166,6.9)	53.7@ (0.40833,6.3)	38.9@ (0.26667,5.4)
59	K22W (max d-ang @ t, dP)	-52.2@ (10.00821,38.5)	14.0@ (0.83333,-12.5)	-51.8@ (10.00821,38.5)	14.6@ (0.77500,-12.3)
60	OS Rel Trip / Marg				
61	MH - OH				
62	D602F at Forbes/Dorsey	228% / 391%	247% / 413%	214% / 363%	249% / 415%
63	G82R at Rugby/L20D at Draytor	999% / 416%	999% / 747%	999% / 654%	999% / 752%
64	R50M / F3M	839% / 237%	843% / 291%	791% / 231%	843% / 289%
65	B10T	155%	186%	173%	194%
66	FSCAPS (SS/Unav/Final)				
67	Balta 230	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)
68	Eau Cl 345 / Park Lk 115	(4 4 3)/(0 0 0)	(4 4 4)/(0 0 0)	(4 4 3)/(0 0 0)	(4 4 4)/(0 0 0)
69	Prairie 115 / Ramsey 230	(1 5 1)/(0 1 1)	(1 2 1)/(0 1 1)	(1 5 1)/(0 1 1)	(1 1 1)/(0 0 0)
70	Roseau 230 / Running 230	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)
71	Shey 115 / Split Rock 115	(0 2 2)/(1 1 1)	(0 2 1)/(1 2 2)	(0 2 2)/(1 1 1)	(0 0 0)/(1 2 2)

Case Disturbance	mh1-so15aa-hhs hhs	mh1-so15aa-hjs hjs	mh1-so15aa-hks hks	m1a-so15aa-he3 he3
System Response 70% or 120% Violations ORWG Criteria Violations Line Tripping	OK	OK	OK	OK

Table C-4: TSR Study Case with Upgrade Option 3

1	2	3	4	5	
Case No.	mh3-so15aa-ag1	mh3-so15aa-ag3	mh3-so15aa-cts	mh3-so15aa-ei2	
Case Name				mh3-so15aa-em3	
Disturbance	ag1	ag3	cts	ei2	
Prior Outage	None	None	None	None	
Date/Time	APR 23 2009 20:24	APR 23 2009 20:27	APR 23 2009 20:29	APR 23 2009 20:33	
Comments					
Steady State Flows					
NDEX / EAST BIAS	2329 / 130	2329 / 130	2329 / 130	2329 / 130	
MHEX / L20D	2052 / 293	2052 / 293	2052 / 293	2052 / 293	
ECL-ARP / PRI-BYN	726 / 119	726 / 119	726 / 119	726 / 119	
MWEX / AHD-SLK	1669 / 647	1669 / 647	1669 / 647	1669 / 647	
D602F / F601C	0 / 1233	0 / 1233	0 / 1233	0 / 1233	
B10T / MH>SPC	165 / 60	165 / 60	165 / 60	165 / 60	
OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	
R50M / OH>MP	138 / 150	138 / 150	138 / 150	138 / 150	
G82R	N/A	N/A	N/A	N/A	
Dorsey bipole / CU bipole	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103	
Dorsey Reserve / Wtrtn SVC	900 / -48	900 / -48	900 / -48	900 / -48	
Forbes SVC / MSC	-7 / 600	-7 / 600	-7 / 600	-7 / 600	
RCDC	0	0	0	0	
Steady State Vltgs					
Dorsey 500/Dorsey 230	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045	
Roseau 500/Forbes 500	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035	
Chisago 500/EauClaire 345	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009	
Int Falls 115/Badoura 115	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044	
Drayton 230/Groton 345	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015	
SS OS Relay Margins					
D602F at Forbes/Dorsey	295% / 494%	295% / 494%	295% / 494%	295% / 494%	
G82R at Rugby/L20D at Draytor	999% / 673%	999% / 673%	999% / 673%	999% / 673%	
R50M/F3M	979% / 324%	979% / 324%	979% / 324%	979% / 324%	
B10T	343%	343%	343%	343%	
Min/Max Transient Vltg					
Arrowhd 230	0.99 1.02	0.99 1.02	0.93 1.08	0.99 1.04	1.01 1.02
Boise 115	1.01 1.03	1.01 1.03	0.98 1.03	1.00 1.02	1.01 1.02
Dorsey 230	1.03 1.05	1.03 1.05	1.05 1.14	1.04 1.05	1.03 1.05
Forbes 230	1.02 1.04	1.02 1.04	0.96 1.05	1.01 1.04	1.03 1.04
Riverton 230	1.01 1.04	1.01 1.04	0.93 1.08	0.99 1.05	1.04 1.04
Coal Creek 230	0.97 1.11	0.97 1.11	0.88 1.09	1.02 1.11	1.03 1.05
Jamestown 345	0.92 1.03	0.91 1.02	0.75 1.04	0.85 1.04	0.99 0.99
Drayton 230	1.01 1.06	1.00 1.04	0.96 1.09	0.99 1.06	1.03 1.04
Groton 345	0.91 1.04	0.91 1.04	0.84 1.09	0.93 1.07	1.02 1.03
Minong 161	0.99 1.03	0.99 1.03	0.98 1.10	1.01 1.06	1.02 1.03
Wahpeton 115	1.00 1.07	1.00 1.07	0.90 1.10	0.97 1.08	1.05 1.05
Watertown 345	0.99 1.04	0.99 1.04	0.92 1.08	0.98 1.06	1.03 1.03
Dynamic Voltage Warnings					
	none	none	63061 [MIDCOMP] 1.24	63061 [MIDCOMP] 1.22	63061 [MIDCOMP] 1.21
OS Rel Trip / Marg					
MH - OH					
D602F at Forbes/Dorsey	252% / 421%	248% / 414%	0.36667 sec / 0.36667 sec	234% / 392%	257% / 432%
G82R at Rugby/L20D at Draytor	999% / 587%	999% / 578%	999% / 494%	999% / 529%	999% / 0.18333 sec
R50M / F3M	865% / 286%	853% / 284%	622% / 190%	873% / 232%	838% / 291%
B10T	210%	203%	62%	121%	252%
FSCAPS (SS/Unav/Final)					
Balta 230	(0 0 0)	(0 0 0)	(0 2 0)	(0 0 0)	(0 0 0)
Eau Cl 345 / Park Lk 115	(4 4 4)/(0 0 0)	(4 4 4)/(0 0 0)	(4 4 2)/(0 0 0)	(4 4 3)/(0 0 0)	(4 4 4)/(0 0 0)
Prairie 115 / Ramsey 230	(1 2 1)/(0 1 1)	(1 1 1)/(0 1 1)	(1 6 1)/(0 2 1)	(1 3 1)/(0 1 1)	(1 1 1)/(0 0 0)
Roseau 230 / Running 230	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)
Shey 115 / Split Rock 115	(1 1 1)/(1 1 1)	(1 1 1)/(1 2 2)	(1 5 0)/(1 2 2)	(1 3 1)/(1 1 1)	(1 1 1)/(1 1 1)

Case Disturbance	mh3-so15aa-ag1 ag1	mh3-so15aa-ag3 ag3	mh3-so15aa-cts cts	mh3-so15aa-ei2 ei2	mh3-so15aa-em3 em3
System Response	OK	OK	OK	OK	OK
70% or 120% Violations			M	M	M
ORWG Criteria Violations			(5T)(6T)		(3T)
Line Tripping					

Table C-4: TSR Study Case with Upgrade Option 3

1	Case No.	6	7	8	9	10
2	Case Name	mh3-so15aa-eq1	mh3-so15aa-fds	mh3-so15aa-mc3	mh3-so15aa-md3	mh3-so15aa-mis
3	Disturbance	eq1	fds	mc3	md3	mis
4	Prior Outage	None	None	None	None	None
5	Date/Time	APR 23 2009 20:38	APR 23 2009 20:41	APR 23 2009 20:44	APR 23 2009 20:47	APR 23 2009 20:49
6	Comments					
7						
8	Steady State Flows					
9	NDEX / EAST BIAS	2329 / 130	2329 / 130	2329 / 130	2329 / 130	2329 / 130
10	MHEX / L20D	2052 / 293	2052 / 293	2052 / 293	2052 / 293	2052 / 293
11	ECL-ARP / PRI-BYN	726 / 119	726 / 119	726 / 119	726 / 119	726 / 119
12	MWEX / AHD-SLK	1669 / 647	1669 / 647	1669 / 647	1669 / 647	1669 / 647
13	D602F / F601C	0 / 1233	0 / 1233	0 / 1233	0 / 1233	0 / 1233
14	B10T / MH>SPC	165 / 60	165 / 60	165 / 60	165 / 60	165 / 60
15	OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	190 / -196
16	R50M / OH>MP	138 / 150	138 / 150	138 / 150	138 / 150	138 / 150
17	G82R	N/A	N/A	N/A	N/A	N/A
18	Dorsey bipole / CU bipole	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103
19	Dorsey Reserve / Wltn SVC	900 / -48	900 / -48	900 / -48	900 / -48	900 / -48
20	Forbes SVC / MSC	-7 / 600	-7 / 600	-7 / 600	-7 / 600	-7 / 600
21	RCDC	0	0	0	0	0
22	Steady State Vltgs					
23	Dorsey 500/Dorsey 230	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045
24	Roseau 500/Forbes 500	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035
25	Chisago 500/EauClaire 345	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009
26	Int Falls 115/Badoura 115	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044
27	Drayton 230/Groton 345	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015
28	SS OS Relay Margins					
29	D602F at Forbes/Dorsey	295% / 494%	295% / 494%	295% / 494%	295% / 494%	295% / 494%
30	G82R at Rugby/L20D at Draytor	999% / 673%	999% / 673%	999% / 673%	999% / 673%	999% / 673%
31	R50M/F3M	979% / 324%	979% / 324%	979% / 324%	979% / 324%	979% / 324%
32	B10T	343%	343%	343%	343%	343%
33	Min/Max Transient Vltg					
34	Arrowhd 230	0.99 1.04	0.97 1.02	1.01 1.02	1.01 1.01	1.01 1.02
35	Boise 115	1.00 1.02	1.01 1.03	1.01 1.02	1.02 1.03	1.05 1.06
36	Dorsey 230	1.04 1.05	1.03 1.06	1.03 1.05	1.03 1.05	1.04 1.05
37	Forbes 230	1.02 1.04	1.02 1.04	1.03 1.04	1.03 1.04	1.03 1.04
38	Riverton 230	1.01 1.06	1.00 1.05	1.03 1.04	1.03 1.04	1.03 1.04
39	Coal Creek 230	1.00 1.16	0.97 1.12	1.03 1.04	1.03 1.04	1.03 1.04
40	Jamestown 345	0.87 1.05	0.83 1.05	0.99 0.99	0.99 0.99	0.99 0.99
41	Drayton 230	1.02 1.07	1.00 1.05	1.02 1.03	1.02 1.03	1.03 1.03
42	Groton 345	0.95 1.07	0.95 1.05	1.01 1.02	1.01 1.02	1.01 1.02
43	Minong 161	1.01 1.05	0.99 1.03	1.02 1.03	1.02 1.02	1.02 1.03
44	Wahpeton 115	0.99 1.09	0.98 1.08	1.05 1.05	1.04 1.05	1.05 1.05
45	Watertown 345	1.00 1.06	1.00 1.05	1.03 1.03	1.03 1.03	1.03 1.03
46	Dynamic Voltage Warnings					
47		63061 [MIDCOMP] 1.22		none	none	none
48						
49						
50						
51						
52						
53						
54	Worst Case Angle Damping	KING 3 / 30.07%	MNTCE3 / 69.70%	KING 3 / 25.28%	SHERC3 / 81.10%	KING 3 / 20.46%
55	Dorsey SUVP / UdHold			/ 0.133	/ 0.133	
56	Forbes DC Red (DCAR)	492%	453%	490%	498%	482%
57	K22W (max +dP @ t, d-ang)	42.0@(2.33332,-16.6)	10.8@(2.43332,-0.5)	28.9@(0.12500,0.4)	21.3@(0.12500,-0.4)	196.1@(0.35000,-11.9)
58	K22W (max -dP @ t, d-ang)	1.7@(0.29167,0.0)	11.3@(0.76666,2.6)	23.4@(0.99166,-4.5)	12.3@(0.24167,0.7)	0.0@(0.01667,0.0)
59	K22W (max d-ang @ t, dP)	-24.9@(10.00821,18.0)	4.2@(1.01666,-3.6)	-8.0@(10.00821,-14.4)	0.7@(0.25833,-11.7)	-43.0@(0.96666,196.1)
60	OS Rel Trip / Marg					
61	MH - OH					0.35000 sec
62	D602F at Forbes/Dorsey	257% / 431%	261% / 437%	274% / 460%	289% / 482%	283% / 474%
63	S82R at Rugby/L20D at Draytor	42% / 542%	999% / 583%	999% / 624%	999% / 661%	999% / 643%
64	R50M / F3M	911% / 258%	872% / 291%	979% / 209%	960% / 319%	612% / 324%
65	B10T	135%	191%	109%	103%	337%
66	FSCAPS (SS/Unav/Final)					
67	Balta 230	(0 1 0)	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)
68	Eau Cl 345 / Park Lk 115	(4 4 4)/(0 0 0)	(4 4 4)/(0 0 0)	(4 4 4)/(0 0 0)	(4 4 4)/(0 0 0)	(4 4 4)/(0 0 0)
69	Prairie 115 / Ramsey 230	(1 3 1)/(0 1 1)	(1 1 1)/(0 1 1)	(1 1 1)/(0 0 0)	(1 1 1)/(0 0 0)	(1 1 1)/(0 0 0)
70	Roseau 230 / Running 230	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)
71	Shey 115 / Split Rock 115	(1 3 1)/(1 1 1)	(1 2 0)/(1 1 1)	(1 1 1)/(1 1 1)	(1 1 1)/(1 1 1)	(1 1 1)/(1 1 1)

Case Disturbance	mh3-so15aa-eq1 eq1	mh3-so15aa-fds fds	mh3-so15aa-mc3 mc3	mh3-so15aa-md3 md3	mh3-so15aa-mis mis
System Response 70% or 120% Violations ORWG Criteria Violations Line Tripping	OK M	OK	OK	OK	OK (1T)

Table C-4: TSR Study Case with Upgrade Option 3

1	Case No.	11	12	13	14	15
2	Case Name	mh3-so15aa-mjs	mh3-so15aa-mkd	mh3-so15aa-mks	mh3-so15aa-nad	mh3-so15aa-nmz
3	Disturbance	mjs	mkd	mks	nad	nmz
4	Prior Outage	None	None	None	None	None
5	Date/Time	APR 23 2009 20:52	APR 23 2009 20:54	APR 23 2009 20:57	APR 23 2009 21:00	APR 23 2009 21:03
6	Comments					
7						
8	Steady State Flows					
9	NDEX / EAST BIAS	2329 / 130	2329 / 130	2329 / 130	2329 / 130	2329 / 130
10	MHEX / L20D	2052 / 293	2052 / 293	2052 / 293	2052 / 293	2052 / 293
11	ECL-ARP / PRI-BYN	726 / 119	726 / 119	726 / 119	726 / 119	726 / 119
12	MWEX / AHD-SLK	1669 / 647	1669 / 647	1669 / 647	1669 / 647	1669 / 647
13	D602F / F601C	0 / 1233	0 / 1233	0 / 1233	0 / 1233	0 / 1233
14	B10T / MH>SPC	165 / 60	165 / 60	165 / 60	165 / 60	165 / 60
15	OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	190 / -196
16	R50M / OH>MP	138 / 150	138 / 150	138 / 150	138 / 150	138 / 150
17	G82R	N/A	N/A	N/A	N/A	N/A
18	Dorsey bipole / CU bipole	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103
19	Dorsey Reserve / Wtrtn SVC	900 / -48	900 / -48	900 / -48	900 / -48	900 / -48
20	Forbes SVC / MSC	-7 / 600	-7 / 600	-7 / 600	-7 / 600	-7 / 600
21	RCDC	0	0	0	0	0
22	Steady State Vltgs					
23	Dorsey 500/Dorsey 230	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045
24	Roseau 500/Forbes 500	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035
25	Chisago 500/EauClaire 345	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009
26	Int Falls 115/Badoura 115	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044
27	Drayton 230/Groton 345	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015
28	SS OS Relay Margins					
29	D602F at Forbes/Dorsey	295% / 494%	295% / 494%	295% / 494%	295% / 494%	295% / 494%
30	G82R at Rugby/L20D at Draytor	999% / 673%	999% / 673%	999% / 673%	999% / 673%	999% / 673%
31	R50M/F3M	979% / 324%	979% / 324%	979% / 324%	979% / 324%	979% / 324%
32	B10T	343%	343%	343%	343%	343%
33	Min/Max Transient Vltg					
34	Arrowhd 230	0.98 1.01	0.94 1.01	0.97 1.02	1.01 1.06	0.97 1.06
35	Boise 115	1.02 1.03	1.02 1.03	1.02 1.03	0.97 1.02	0.98 1.02
36	Dorsey 230	1.03 1.06	1.03 1.05	1.03 1.07	1.04 1.08	1.04 1.08
37	Forbes 230	1.03 1.05	1.03 1.04	1.03 1.05	1.02 1.04	1.01 1.04
38	Riverton 230	1.01 1.04	0.99 1.03	1.00 1.04	1.01 1.05	0.98 1.06
39	Coal Creek 230	0.98 1.07	0.98 1.07	0.97 1.08	1.00 1.07	0.97 1.07
40	Jamestown 345	0.92 1.00	0.91 1.00	0.91 1.00	0.94 0.99	0.88 1.02
41	Drayton 230	1.01 1.04	1.00 1.03	1.01 1.04	0.99 1.05	0.99 1.07
42	Groton 345	0.97 1.02	0.97 1.02	0.96 1.03	0.99 1.03	0.95 1.06
43	Minong 161	0.99 1.01	0.95 1.03	0.98 1.04	1.02 1.08	1.00 1.08
44	Wahpeton 115	1.01 1.05	1.00 1.05	1.00 1.06	1.02 1.05	0.98 1.08
45	Watertown 345	1.00 1.03	1.00 1.03	1.00 1.03	1.01 1.04	0.99 1.06
46	Dynamic Voltage Warnings					
47		none	none	none	63061 [MIDCOMP] 1.23	63061 [MIDCOMP] 1.23
48						
49						
50						
51						
52						
53						
54	Worst Case Angle Damping	SHERC3 / 83.30%	KING 3 / 76.72%	KING 3 / 76.81%	KING 3 / 39.83%	KING 3 / 39.57%
55	Dorsey SUVP / UdHold		/ 0.133	/ 0.150	/ 0.133	/ 0.133
56	Forbes DC Red (DCAR)	455%	339%	398%	507%	507%
57	K22W (max +dP @ t, d-ang)	3.6@(0.11667,0.3)	12.6@(0.10833,1.6)	7.8@(2.29999,0.1)	85.2@(2.00000,-39.7)	104.1@(2.02500,-46.1)
58	K22W (max -dP @ t, d-ang)	20.7@(0.35000,3.1)	31.4@(0.22500,4.1)	30.5@(0.36667,5.5)	68.5@(0.25833,7.7)	53.1@(0.23333,5.2)
59	K22W (max d-ang @ t, dP)	5.3@(0.99166,-14.5)	11.9@(0.77500,-10.0)	8.6@(0.69166,-5.3)	-65.8@(10.00821,39.8)	-70.4@(10.00821,58.4)
60	OS Rel Trip / Marg					
61	MH - OH					
62	D602F at Forbes/Dorsey	275% / 476%	293% / 488%	255% / 452%	0.16667 sec / 0.16667 sec	0.18333 sec / 0.18333 sec
63	G82R at Rugby/L20D at Draytor	999% / 595%	999% / 548%	999% / 585%	999% / 417%	999% / 540%
64	R50M / F3M	883% / 324%	848% / 324%	850% / 315%	480% / 173%	687% / 196%
65	B10T	235%	189%	205%	184%	148%
66	FSCAPS (SS/Unav/Final)					
67	Balta 230	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)
68	Eau Cl 345 / Park Lk 115	(4 4 4)/(0 0 0)	(4 4 4)/(0 0 0)	(4 4 4)/(0 0 0)	(4 4 3)/(0 0 0)	(4 4 2)/(0 0 0)
69	Prairie 115 / Ramsey 230	(1 1 1)/(0 1 1)	(1 1 1)/(0 1 1)	(1 1 1)/(0 1 1)	(1 1 1)/(0 0 0)	(1 2 1)/(0 1 1)
70	Roseau 230 / Running 230	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 3 3)	(0 0 0)/(1 1 1)
71	Shey 115 / Split Rock 115	(1 1 1)/(1 1 1)	(1 1 1)/(1 2 2)	(1 1 1)/(1 1 1)	(1 1 1)/(1 1 1)	(1 3 1)/(1 2 2)

Case Disturbance	mh3-so15aa-mjs mjs	mh3-so15aa-mkd mkd	mh3-so15aa-mks mks	mh3-so15aa-nad nad	mh3-so15aa-nmz nmz
System Response 70% or 120% Violations ORWG Criteria Violations Line Tripping	OK	OK	OK	OK M (5T)(6T)	OK M (5T)(6T)

Table C-4: TSR Study Case with Upgrade Option 3

1	Case No.	16	17	18	19	20
2	Case Name	mh3-so15aa-pas	mh3-so15aa-pc0	mh3-so15aa-pcs	mh3-so15aa-pct	mh3-so15aa-pzs
3	Disturbance	pas	pc0	pcs	pct	pzs
4	Prior Outage	None	None	None	None	None
5	Date/Time	APR 23 2009 21:06	APR 23 2009 21:09	APR 23 2009 21:12	APR 23 2009 21:15	APR 23 2009 21:17
6	Comments					
7						
8	Steady State Flows					
9	NDEX / EAST BIAS	2329 / 130	2329 / 130	2329 / 130	2329 / 130	2329 / 130
10	MHEX / L20D	2052 / 293	2052 / 293	2052 / 293	2052 / 293	2052 / 293
11	ECL-ARP / PRI-BYN	726 / 119	726 / 119	726 / 119	726 / 119	726 / 119
12	MWEX / AHD-SLK	1669 / 647	1669 / 647	1669 / 647	1669 / 647	1669 / 647
13	D602F / F601C	0 / 1233	0 / 1233	0 / 1233	0 / 1233	0 / 1233
14	B10T / MH>SPC	165 / 60	165 / 60	165 / 60	165 / 60	165 / 60
15	OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	190 / -196
16	R50M / OH>MP	138 / 150	138 / 150	138 / 150	138 / 150	138 / 150
17	G82R	N/A	N/A	N/A	N/A	N/A
18	Dorsey bipole / CU bipole	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103
19	Dorsey Reserve / Wtrtn SVC	900 / -48	900 / -48	900 / -48	900 / -48	900 / -48
20	Forbes SVC / MSC	-7 / 600	-7 / 600	-7 / 600	-7 / 600	-7 / 600
21	RCDC	0	0	0	0	0
22	Steady State Vltgs					
23	Dorsey 500/Dorsey 230	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045
24	Roseau 500/Forbes 500	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035
25	Chisago 500/EauClaire 345	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009
26	Int Falls 115/Badoura 115	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044
27	Drayton 230/Groton 345	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015
28	SS OS Relay Margins					
29	D602F at Forbes/Dorsey	295% / 494%	295% / 494%	295% / 494%	295% / 494%	295% / 494%
30	G82R at Rugby/L20D at Draytor	999% / 673%	999% / 673%	999% / 673%	999% / 673%	999% / 673%
31	R50M/F3M	979% / 324%	979% / 324%	979% / 324%	979% / 324%	979% / 324%
32	B10T	343%	343%	343%	343%	343%
33	Min/Max Transient Vltg					
34	Arrowhd 230	0.99 1.06	0.88 0.99	0.87 0.98	0.93 0.96	0.98 1.03
35	Boise 115	0.98 1.02	1.01 1.04	1.01 1.04	1.02 1.03	1.01 1.04
36	Dorsey 230	1.04 1.07	1.03 1.08	1.03 1.08	1.04 1.05	1.03 1.07
37	Forbes 230	0.99 1.04	1.02 1.03	1.02 1.04	1.02 1.03	1.03 1.06
38	Riverton 230	1.01 1.05	1.00 1.04	1.00 1.04	1.02 1.03	1.02 1.05
39	Coal Creek 230	1.00 1.06	0.96 1.08	0.96 1.08	1.02 1.04	0.98 1.08
40	Jamestown 345	0.95 0.99	0.92 1.01	0.92 1.01	0.98 1.00	0.94 1.01
41	Drayton 230	1.00 1.05	1.02 1.07	1.01 1.05	1.02 1.03	1.02 1.04
42	Groton 345	0.99 1.03	0.97 1.03	0.97 1.03	1.00 1.02	0.98 1.03
43	Minong 161	1.02 1.08	0.85 1.01	0.85 0.99	0.92 0.97	0.99 1.05
44	Wahpeton 115	1.02 1.05	1.01 1.07	1.01 1.06	1.04 1.05	1.02 1.06
45	Watertown 345	1.01 1.04	1.00 1.04	1.00 1.04	1.02 1.03	1.01 1.04
46	Dynamic Voltage Warnings					
47		63061 [MIDCOMP] 1.23	63061 [MIDCOMP] 1.22	63061 [MIDCOMP] 1.23	63061 [MIDCOMP] 1.21	63061 [MIDCOMP] 1.21
48						
49						
50						
51						
52						
53						
54	Worst Case Angle Damping	KING 3 / 42.06%	SHERC3 / 70.07%	SHERC3 / 68.81%	SHERC3 / 52.31%	KING 3 / 69.58%
55	Dorsey SUVP / UdHold	/ 0.133	/ 0.141	/ 0.141		
56	Forbes DC Red (DCAR)	503%	313%	291%	348%	373%
57	K22W (max +dP @ t, d-ang)	86.1@ (2.00833,-39.2)	8.1@ (3.30831,-0.4)	3.3@ (0.11667,0.7)	0.0@ (0.10000,0.0)	18.3@ (2.35832,-2.4)
58	K22W (max -dP @ t, d-ang)	47.9@ (0.25833,4.2)	51.0@ (0.37500,8.4)	51.1@ (0.37500,8.3)	37.4@ (1.96666,15.5)	28.1@ (0.38333,4.5)
59	K22W (max d-ang @ t, dP)	-64.1@ (10.00832,45.3)	20.7@ (1.00833,-36.9)	21.4@ (1.05000,-41.7)	15.5@ (1.96666,-37.4)	12.7@ (0.90000,-13.4)
60	OS Rel Trip / Marg					
61	MH - OH					
62	D602F at Forbes/Dorsey	0.38333 sec / 0.18333 sec	230% / 383%	234% / 390%	278% / 466%	240% / 401%
63	G82R at Rugby/L20D at Draytor	999% / 474%	999% / 524%	999% / 533%	999% / 600%	999% / 565%
64	R50M / F3M	548% / 199%	732% / 311%	737% / 324%	854% / 324%	797% / 296%
65	B10T	210%	166%	176%	269%	174%
66	FSCAPS (SS/Unav/Final)					
67	Balta 230	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)
68	Eau Cl 345 / Park Lk 115	(4 4 3) / (0 0 0)	(4 4 4) / (0 3 3)	(4 4 3) / (0 3 3)	(4 4 3) / (0 0 0)	(4 4 4) / (0 3 3)
69	Prairie 115 / Ramsey 230	(1 1 1) / (0 0 0)	(1 3 2) / (0 1 1)	(1 1 1) / (0 1 1)	(1 1 1) / (0 0 0)	(1 1 1) / (0 1 1)
70	Roseau 230 / Running 230	(0 0 0) / (1 2 2)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)
71	Shey 115 / Split Rock 115	(1 1 1) / (1 1 1)	(1 2 2) / (1 2 2)	(1 2 2) / (1 2 2)	(1 1 1) / (1 1 1)	(1 1 1) / (1 2 2)

Case Disturbance	mh3-so15aa-pas	mh3-so15aa-pc0	mh3-so15aa-pcs	mh3-so15aa-pct	mh3-so15aa-pzs
System Response	OK	OK	OK	OK	OK
70% or 120% Violations	M	M	M	M	M
ORWG Criteria Violations					
Line Tripping	(5T)(6T)				

Table C-4: TSR Study Case with Upgrade Option 3

1	Case No.	21	22	23	24	25
2	Case Name	mh3-so15aa-pzt	mh3-so15aa-ya3	mh3-so15aa-yas	mh3-so15aa-yb3	mh3-so15aa-h13
3	Disturbance	pzt	ya3	yas	yb3	h13
4	Prior Outage	None	None	None	None	None
5	Date/Time	APR 23 2009 21:20	APR 23 2009 22:02	APR 23 2009 22:05	APR 23 2009 22:07	APR 23 2009 21:38
6	Comments					
7						
8	Steady State Flows					
9	NDEX / EAST BIAS	2329 / 130	2329 / 130	2329 / 130	2329 / 130	2329 / 130
10	MHEX / L20D	2052 / 293	2052 / 293	2052 / 293	2052 / 293	2052 / 293
11	ECL-ARP / PRI-BYN	726 / 119	726 / 119	726 / 119	726 / 119	726 / 119
12	MWEX / AHD-SLK	1669 / 647	1669 / 647	1669 / 647	1669 / 647	1669 / 647
13	D602F / F601C	0 / 1233	0 / 1233	0 / 1233	0 / 1233	0 / 1233
14	B10T / MH>SPC	165 / 60	165 / 60	165 / 60	165 / 60	165 / 60
15	OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	190 / -196
16	R50M / OH>MP	138 / 150	138 / 150	138 / 150	138 / 150	138 / 150
17	G82R	N/A	N/A	N/A	N/A	N/A
18	Dorsey bipole / CU bipole	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103
19	Dorsey Reserve / Wtrtn SVC	900 / -48	900 / -48	900 / -48	900 / -48	900 / -48
20	Forbes SVC / MSC	-7 / 600	-7 / 600	-7 / 600	-7 / 600	-7 / 600
21	RCDC	0	0	0	0	0
22	Steady State Vltgs					
23	Dorsey 500/Dorsey 230	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045
24	Roseau 500/Forbes 500	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035
25	Chisago 500/EauClaire 345	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009
26	Int Falls 115/Badoura 115	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044
27	Drayton 230/Groton 345	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015
28	SS OS Relay Margins					
29	D602F at Forbes/Dorsey	295% / 494%	295% / 494%	295% / 494%	295% / 494%	295% / 494%
30	G82R at Rugby/L20D at Draytor	999% / 673%	999% / 673%	999% / 673%	999% / 673%	999% / 673%
31	R50M/F3M	979% / 324%	979% / 324%	979% / 324%	979% / 324%	979% / 324%
32	B10T	343%	343%	343%	343%	343%
33	Min/Max Transient Vltg					
34	Arrowhd 230	1.00 1.01	1.01 1.02	0.96 0.99	1.03 1.05	1.00 1.03
35	Boise 115	1.02 1.03	1.03 1.04	1.02 1.04	1.03 1.04	1.01 1.03
36	Dorsey 230	1.04 1.05	1.04 1.05	1.04 1.07	1.04 1.05	0.99 1.05
37	Forbes 230	1.03 1.04	1.03 1.04	1.02 1.04	1.03 1.04	1.02 1.04
38	Riverton 230	1.03 1.04	1.02 1.03	1.01 1.03	1.03 1.03	1.03 1.04
39	Coal Creek 230	1.03 1.04	1.02 1.04	1.00 1.05	1.02 1.04	1.02 1.05
40	Jamestown 345	0.99 0.99	0.98 1.00	0.97 1.00	0.98 1.00	0.97 1.00
41	Drayton 230	1.03 1.03	1.02 1.04	1.02 1.04	1.02 1.04	1.01 1.04
42	Groton 345	1.01 1.02	1.00 1.01	1.00 1.01	1.00 1.01	1.00 1.03
43	Minong 161	1.01 1.01	0.97 0.99	0.96 1.03	0.97 1.00	1.01 1.04
44	Wahpeton 115	1.05 1.05	1.04 1.05	1.04 1.05	1.04 1.05	1.04 1.05
45	Watertown 345	1.02 1.03	1.02 1.02	1.02 1.02	1.02 1.02	1.02 1.04
46	Dynamic Voltage Warnings					
47		none	none		none	
48						
49						
50						
51						
52						
53						
54	Worst Case Angle Damping	SHERC3 / 53.57%	SHERC3 / 49.74%	ANTEL3 / 67.32%	KING 3 / 52.84%	SHERC3 / 70.41%
55	Dorsey SUVP / UdHold					/ 0.133
56	Forbes DC Red (DCAR)	463%	379%	427%	410%	465%
57	K22W (max +dP @ t, d-ang)	0.0@(0.10000,0.0)	4.9@(0.11667,0.7)	3.0@(0.11667,0.4)	3.3@(0.11667,0.6)	103.7@(0.15000,-2.3)
58	K22W (max -dP @ t, d-ang)	9.3@(1.74166,3.7)	27.0@(1.65833,12.5)	22.1@(1.64166,9.6)	19.6@(1.61666,8.8)	22.5@(2.95832,4.5)
59	K22W (max d-ang @ t, dP)	3.8@(2.06666,-9.0)	12.7@(-1.90000,-24.5)	10.2@(-1.06666,-15.7)	8.9@(-1.87500,-17.4)	-9.8@(0.64166,3.7)
60	OS Rel Trip / Marg					
61	MH - OH					
62	D602F at Forbes/Dorsey	292% / 489%	295% / 494%	290% / 485%	295% / 494%	277% / 462%
63	S82R at Rugby/L20D at Draytor	999% / 655%	999% / 610%	999% / 622%	999% / 627%	999% / 608%
64	R50M / F3M	954% / 324%	979% / 324%	973% / 324%	979% / 324%	876% / 261%
65	B10T	319%	267%	274%	284%	274%
66	FSCAPS (SS/Unav/Final)					
67	Balta 230	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)
68	Eau Cl 345 / Park Lk 115	(4 4 4) / (0 0 0)	(4 4 4) / (0 0 0)	(4 4 4) / (0 0 0)	(4 4 4) / (0 0 0)	(4 4 4) / (0 0 0)
69	Prairie 115 / Ramsey 230	(1 1 1) / (0 0 0)	(1 1 1) / (0 0 0)	(1 1 1) / (0 0 0)	(1 1 1) / (0 0 0)	(1 1 1) / (0 0 0)
70	Roseau 230 / Running 230	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)	(0 0 0) / (1 1 1)
71	Shey 115 / Split Rock 115	(1 1 1) / (1 1 1)	(1 1 1) / (1 1 1)	(1 1 1) / (1 1 1)	(1 1 1) / (1 1 1)	(1 1 1) / (1 1 1)

Case Disturbance	mh3-so15aa-pzt pzt	mh3-so15aa-ya3 ya3	mh3-so15aa-yas yas	mh3-so15aa-yb3 yb3	mh3-so15aa-h13 h13
System Response 70% or 120% Violations ORWG Criteria Violations Line Tripping	OK	OK	OK	OK	OK

Table C-4: TSR Study Case with Upgrade Option 3

1	Case No.	26	27	28	29	30
2	Case Name	mh3-so15aa-h23	mh3-so15aa-h33	mh3-so15aa-h43	mh3-so15aa-hc3	mh3-so15aa-hd3
3	Disturbance	h23	h33	h43	hc3	hd3
4	Prior Outage	None	None	None	None	None
5	Date/Time	APR 23 2009 21:41	APR 23 2009 21:44	APR 23 2009 21:47	APR 23 2009 21:50	APR 23 2009 21:53
6	Comments					
7						
8	Steady State Flows					
9	NDEX / EAST BIAS	2329 / 130	2329 / 130	2329 / 130	2329 / 130	2329 / 130
10	MHEX / L20D	2052 / 293	2052 / 293	2052 / 293	2052 / 293	2052 / 293
11	ECL-ARP / PRI-BYN	726 / 119	726 / 119	726 / 119	726 / 119	726 / 119
12	MWEX / AHD-SLK	1669 / 647	1669 / 647	1669 / 647	1669 / 647	1669 / 647
13	D602F / F601C	0 / 1233	0 / 1233	0 / 1233	0 / 1233	0 / 1233
14	B10T / MH>SPC	165 / 60	165 / 60	165 / 60	165 / 60	165 / 60
15	OH E-W / OH>MH	190 / -196	190 / -196	190 / -196	190 / -196	190 / -196
16	R50M / OH>MP	138 / 150	138 / 150	138 / 150	138 / 150	138 / 150
17	G82R	N/A	N/A	N/A	N/A	N/A
18	Dorsey bipole / CU bipole	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103	3245 / 1103
19	Dorsey Reserve / Wtrtn SVC	900 / -48	900 / -48	900 / -48	900 / -48	900 / -48
20	Forbes SVC / MSC	-7 / 600	-7 / 600	-7 / 600	-7 / 600	-7 / 600
21	RCDC	0	0	0	0	0
22	Steady State Vltgs					
23	Dorsey 500/Dorsey 230	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045	1.046 / 1.045
24	Roseau 500/Forbes 500	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035	1.043 / 1.035
25	Chisago 500/EauClaire 345	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009	1.031 / 1.009
26	Int Falls 115/Badoura 115	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044	1.023 / 1.044
27	Drayton 230/Groton 345	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015	1.029 / 1.015
28	SS OS Relay Margins					
29	D602F at Forbes/Dorsey	295% / 494%	295% / 494%	295% / 494%	295% / 494%	295% / 494%
30	G82R at Rugby/L20D at Draytor	999% / 673%	999% / 673%	999% / 673%	999% / 673%	999% / 673%
31	R50M/F3M	979% / 324%	979% / 324%	979% / 324%	979% / 324%	979% / 324%
32	B10T	343%	343%	343%	343%	343%
33	Min/Max Transient Vltg					
34	Arrowhd 230	1.02 1.06	1.03 1.08	1.00 1.03	1.01 1.04	0.97 1.05
35	Boise 115	1.01 1.03	0.97 1.01	1.00 1.02	1.00 1.02	1.00 1.02
36	Dorsey 230	1.02 1.07	1.04 1.07	0.99 1.04	1.03 1.06	1.03 1.06
37	Forbes 230	1.04 1.05	1.05 1.07	1.02 1.04	1.01 1.04	1.02 1.04
38	Riverton 230	1.04 1.05	1.04 1.06	1.03 1.04	1.02 1.04	1.00 1.04
39	Coal Creek 230	1.03 1.06	1.03 1.07	1.02 1.05	1.02 1.06	1.01 1.06
40	Jamestown 345	0.97 1.00	0.94 1.00	0.97 1.00	0.95 0.99	0.96 0.99
41	Drayton 230	1.03 1.06	1.01 1.05	1.01 1.03	1.01 1.04	1.01 1.04
42	Groton 345	1.00 1.04	0.99 1.04	1.00 1.03	0.99 1.03	0.99 1.03
43	Minong 161	1.02 1.07	1.04 1.08	1.01 1.04	1.03 1.06	1.00 1.08
44	Wahpeton 115	1.04 1.06	1.02 1.06	1.04 1.05	1.02 1.05	1.02 1.05
45	Watertown 345	1.03 1.04	1.02 1.04	1.02 1.03	1.02 1.03	1.02 1.04
46	Dynamic Voltage Warnings					
47		63061 [MIDCOMP] 1.26	63061 [MIDCOMP] 1.24	none	none	none
48						
49						
50						
51						
52						
53						
54	Worst Case Angle Damping	KING 3 / 3.51%	KING 3 / 32.95%	SHERC3 / 70.12%	KING 3 / 29.92%	KING 3 / 50.09%
55	Dorsey SUVP / UdHold	/ 0.133	/ 0.133	/ 0.133	/ 0.133	/ 0.133
56	Forbes DC Red (DCAR)	446%	507%	477%	507%	507%
57	K22W (max +dP @ t, d-ang)	103.7@(0.15000,-2.3)	98.0@(0.15000,-1.9)	98.0@(0.15000,-1.9)	103.7@(0.15000,-2.3)	74.8@(2.05000,-28.4)
58	K22W (max -dP @ t, d-ang)	0.0@(0.01667,0.0)	18.2@(0.24167,0.5)	33.8@(2.95832,7.3)	4.0@(0.25000,0.3)	60.2@(0.26667,7.0)
59	K22W (max d-ang @ t, dP)	-39.7@(10.00821,44.8)	-67.5@(10.00821,44.3)	8.3@(2.61665,-21.0)	-47.6@(10.00821,36.8)	-47.1@(10.00821,37.8)
60	OS Rel Trip / Marg					
61	MH - OH					
62	D602F at Forbes/Dorsey	295% / 494%	0.18333 sec / 0.18333 sec	285% / 473%	224% / 377%	190% / 323%
63	G82R at Rugby/L20D at Draytor	999% / 673%	999% / 629%	999% / 535%	999% / 671%	999% / 483%
64	R50M / F3M	979% / 250%	581% / 171%	732% / 259%	903% / 232%	714% / 227%
65	B10T	328%	255%	259%	267%	196%
66	FSCAPS (SS/Unav/Final)					
67	Balta 230	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)	(0 0 0)
68	Eau Cl 345 / Park Lk 115	(4 4 3)/(0 0 0)	(4 4 3)/(0 0 0)	(4 4 4)/(0 0 0)	(4 4 3)/(0 0 0)	(4 4 3)/(0 0 0)
69	Prairie 115 / Ramsey 230	(1 1 1)/(0 0 0)	(1 1 1)/(0 0 0)	(1 1 1)/(0 0 0)	(1 1 1)/(0 0 0)	(1 1 1)/(0 0 0)
70	Roseau 230 / Running 230	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)	(0 0 0)/(1 1 1)
71	Shey 115 / Split Rock 115	(1 1 1)/(1 1 1)	(1 1 1)/(1 1 1)	(1 1 1)/(1 1 1)	(1 1 1)/(1 1 1)	(1 1 1)/(1 2 2)

Case Disturbance	mh3-so15aa-h23 h23	mh3-so15aa-h33 h33	mh3-so15aa-h43 h43	mh3-so15aa-hc3 hc3	mh3-so15aa-hd3 hd3
System Response 70% or 120% Violations ORWG Criteria Violations Line Tripping	OK M (5T)(6T)	OK M (5T)(6T)	OK (5T)(6T)	OK (5T)(6T)	OK (5T)(6T)

Table C-4: TSR Study Case with Upgrade Option 3

1	Case No.	31	32
2	Case Name	mh3-so15aa-hf0	mh3-so15aa-his
3	Disturbance	hfs	his
4	Prior Outage	None	None
5	Date/Time	APR 24 2009 9:20	APR 23 2009 21:59
6	Comments		
7			
8	Steady State Flows		
9	NDEX / EAST BIAS	2329 / 130	2329 / 130
10	MHEX / L20D	2052 / 293	2052 / 293
11	ECL-ARP / PRI-BYN	726 / 119	726 / 119
12	MWEX / AHD-SLK	1669 / 647	1669 / 647
13	D602F / F601C	0 / 1233	0 / 1233
14	B10T / MH>SPC	165 / 60	165 / 60
15	OH E-W / OH>MH	190 / -196	190 / -196
16	R50M / OH>MP	138 / 150	138 / 150
17	G82R	N/A	N/A
18	Dorsey bipole / CU bipole	3245 / 1103	3245 / 1103
19	Dorsey Reserve / Wtrtn SVC	900 / -48	900 / -48
20	Forbes SVC / MSC	-7 / 600	-7 / 600
21	RCDC	0	0
22	Steady State Vltgs		
23	Dorsey 500/Dorsey 230	1.046 / 1.045	1.046 / 1.045
24	Roseau 500/Forbes 500	1.043 / 1.035	1.043 / 1.035
25	Chisago 500/EauClaire 345	1.031 / 1.009	1.031 / 1.009
26	Int Falls 115/Badoura 115	1.023 / 1.044	1.023 / 1.044
27	Drayton 230/Groton 345	1.029 / 1.015	1.029 / 1.015
28	SS OS Relay Margins		
29	D602F at Forbes/Dorsey	295% / 494%	295% / 494%
30	G82R at Rugby/L20D at Drayton	999% / 673%	999% / 673%
31	R50M/F3M	979% / 324%	979% / 324%
32	B10T	343%	343%
33	Min/Max Transient Vltg		
34	Arrowhd 230	1.01 1.06	0.87 1.03
35	Boise 115	1.00 1.04	0.99 1.03
36	Dorsey 230	1.04 1.16	1.04 1.07
37	Forbes 230	1.04 1.07	1.00 1.04
38	Riverton 230	1.03 1.05	0.98 1.05
39	Coal Creek 230	1.01 1.06	0.99 1.06
40	Jamestown 345	0.96 1.00	0.96 1.01
41	Drayton 230	1.05 1.11	1.02 1.06
42	Groton 345	0.99 1.04	0.98 1.03
43	Minong 161	1.02 1.08	0.87 1.06
44	Wahpeton 115	1.03 1.06	1.02 1.07
45	Watertown 345	1.02 1.04	1.00 1.04
46	Dynamic Voltage Warnings		
47		none	none
48			
49			
50			
51			
52			
53			
54	Worst Case Angle Damping	KING 3 / 32.93%	SHERC3 / 67.81%
55	Dorsey SUVP / UdHold	/ 0.133	/ 0.133
56	Forbes DC Red (DCAR)	413%	467%
57	K22W (max +dP @ t, d-ang)	146.1@(1.52500,-43.3)	76.0@(2.24166,-28.9)
58	K22W (max -dP @ t, d-ang)	52.5@(0.39166,6.4)	55.0@(0.30000,8.0)
59	K22W (max d-ang @ t, dP)	-78.3@(10.00821,82.1)	-42.5@(10.00821,24.5)
60	OS Rel Trip / Marg		
61	MH - OH		
62	D602F at Forbes/Dorsey	59% / 84%	169% / 283%
63	G82R at Rugby/L20D at Drayton	999% / 334%	999% / 515%
64	R50M / F3M	489% / 196%	679% / 234%
65	B10T	227%	118%
66	FSCAPS (SS/Unav/Final)		
67	Balta 230	(0 0 0)	(0 0 0)
68	Eau Cl 345 / Park Lk 115	(4 4 3) / (0 0 0)	(4 4 3) / (0 0 0)
69	Prairie 115 / Ramsey 230	(1 4 1) / (0 1 1)	(1 2 1) / (0 1 1)
70	Roseau 230 / Running 230	(0 1 0) / (1 2 1)	(0 0 0) / (1 1 1)
71	Shey 115 / Split Rock 115	(1 1 1) / (1 1 1)	(1 3 2) / (1 2 2)

Case Disturbance	mh3-so15aa-hf0 hfs	mh3-so15aa-his his
System Response 70% or 120% Violations ORWG Criteria Violations Line Tripping	OK	OK