


Manitoba Hydro Group TSR Study

Transmission Options
October 2008


- Dorsey Maple River Helena 500 kV
 - 500 kV single circuit with series capacitors (located at Prairie), with HVDC reduction for the loss of the line
- Dorsey Riel 500 kV
- North La Crosse West Middleton Rockdale 345 kV (ATC proposed facility with 2013 ISD)
- An additional sensitivity would consider tapping the line at Prairie (345 kV).
- Option assumes use of Helena Lake Marion North Rochester –
 North La Crosse 345 kV CAPX 2020 facilities





- Dorsey Maple River 500 kV
 - 500 kV single circuit, series compensated; series capacitors located at Prairie; HVDC reduction for the loss of the line
- Maple River Arrowhead 500 kV
- Dorsey Riel 500 kV
- Arrowhead Chisago King 345 kV
- North La Crosse W. Middleton Rockdale 345 kV line
- This option may require series compensation on the Arrowhead Gardner Park 345 kV line and additional shunt reactive support. Base assumptions will exclude such reactive compensation; and a scenario including these will be studied if required.
- Option assumes use of Helena Lake Marion North Rochester North La Crosse 345 kV CAPX 2020 facilities






Option 2a


- Dorsey Maple River 500 kV
 - 500 kV single circuit, series compensated; series capacitors located at Prairie; HVDC reduction for the loss of the line
- Maple River Arrowhead 345 kV double circuit
- Arrowhead Chisago King 345 kV
- Dorsey Riel 500 kV
- North La Crosse W. Middleton Rockdale 345 kV line
- This option may require series compensation on the Arrowhead Gardner Park 345 kV line and additional shunt reactive support. Base assumptions will exclude such reactive compensation; will be studied if required
- Option assumes use of Helena Lake Marion North Rochester North La Crosse 345 kV CAPX 2020 facilities






- Another 500 kV from Dorsey to King, parallel to the path of the existing 500 kV line
 - 500 kV single circuit, series compensated; HVDC reduction for the loss of the line
- North La Crosse W. Middleton Rockdale 345 kV line
- Dorsey Riel 500 kV
- Option assumes use of Helena Lake Marion North Rochester –
 North La Crosse 345 kV CAPX 2020 facilities





- Option 4a
 - Dorsey Maple River 500 kV AC
 - Maple River Arrowhead N. Appleton DC
 - N. Appleton to Morgan 345 kV AC
 - Dorsey Riel 500 kV
- 500 kV AC single circuit, series compensated; series capacitors located at Prairie; HVDC reduction for the loss of the line
- Option assumes use of Helena Lake Marion North Rochester North
 La Crosse 345 kV CAPX 2020 facilities






Option 4, contd...

- Option 4b
 - Dorsey Maple River 500 kV AC
 - Maple River W. Middleton DC
 - W. Middleton N. Madison 345 kV AC
 - Dorsey Riel 500 kV
- 500 kV AC single circuit, series compensated; series capacitors located at
 Prairie; HVDC reduction for the loss of the line
- Option assumes use of Helena Lake Marion North Rochester North
 La Crosse 345 kV CAPX 2020 facilities





List of TSRs – South Flow

A_REF	TS_TYPE	START TIME	STOP TIME	POR	POD	CAPACITY	
76486855	POINT_TO_POINT	5/1/2007	5/1/2009	MHEB	CIN	80	
76486858	POINT_TO_POINT	5/1/2007	5/1/2009	MHEB	NSP	80	
76503369	NETWORK	4/1/2008	4/1/2013	MHEB	NSP	30	
76612785	POINT_TO_POINT	11/1/2009	11/1/2014	MHEB	NSP	250	
76492364	NETWORK	11/1/2014	11/1/2024	MHEB	GRE	200	
76544681	NETWORK	6/1/2017	6/1/2037	MHEB	MP	250	
76637045	NETWORK	6/1/2017	6/1/2027	MHEB	NSP	50	
76637046	NETWORK	6/1/2017	6/1/2027	MHEB	WEC	100	
76537306	NETWORK	6/1/2017	6/1/2027	MHEB	WPS	500	



List of TSRs – North Flow

A_REF	TS_TYPE	START TIME	STOP TIME	POR	POD	CAPACITY	Study Number
76637091	POINT_TO_POINT	11/1/2014	11/1/2024	GRE	MHEB	100	A415
76637089	POINT_TO_POINT	11/1/2014	11/1/2024	GRE	MHEB	100	A415
76637257	POINT_TO_POINT	6/1/2017	6/1/2027	WEC	MHEB	50	A414
76637260	POINT_TO_POINT	6/1/2017	6/1/2027	ALTE	MHEB	50	A413
76637259	POINT_TO_POINT	6/1/2017	6/1/2027	ALTE	MHEB	50	A413
76544699	NETWORK	6/1/2017	6/1/2037	MP	MHEB	250	A383
76537582	NETWORK	6/1/2017	6/1/2027	WPS	MHEB	500	A380

