

Community Solar Project Interconnection
Community Solar Project System Impact Study Report

Completed for

(“Applicant”)
OCS036

Proposed Point of Interconnection
Circuit 5L45 out of Hornet substation at 12.0 kV
(at approximately 42°11'7.70"N, 121°41'12.42"W)

October 7, 2020

TABLE OF CONTENTS

| | |
|--|-------------------------------------|
| 1.0 DESCRIPTION OF THE COMMUNITY SOLAR PROJECT | 2 |
| 2.0 APPROVAL CRITERIA FOR TIER 4 INTERCONNECTION REVIEW | 2 |
| 3.0 SCOPE OF THE STUDY | 2 |
| 4.0 PROPOSED POINT OF INTERCONNECTION | 2 |
| 5.0 STUDY ASSUMPTIONS..... | 4 |
| 6.0 REQUIREMENTS | 4 |
| 6.1 COMMUNITY SOLAR PROJECT REQUIREMENTS | 4 |
| 6.2 TRANSMISSION SYSTEM MODIFICATIONS..... | 5 |
| 6.3 DISTRIBUTION/TRANSMISSION LINE MODIFICATIONS | 5 |
| 6.4 EXISTING BREAKER MODIFICATIONS – SHORT-CIRCUIT | 5 |
| 6.5 PROTECTION REQUIREMENTS | 5 |
| 6.6 DATA REQUIREMENTS (RTU) | 6 |
| 6.7 COMMUNICATION REQUIREMENTS | 6 |
| 6.7.1 Line Protection..... | <i>Error! Bookmark not defined.</i> |
| 6.7.2 Data Delivery to the Control Centers | <i>Error! Bookmark not defined.</i> |
| 6.8 SUBSTATION REQUIREMENTS | 6 |
| 6.9 METERING REQUIREMENTS | 6 |
| 7.0 COST ESTIMATE | 7 |
| 8.0 SCHEDULE | 8 |
| 9.0 PARTICIPATION BY AFFECTED SYSTEMS | 8 |
| 10.0 APPENDICES..... | 8 |
| 10.1 APPENDIX 1: HIGHER PRIORITY REQUESTS | 9 |
| 10.2 APPENDIX 2: INFORMATIONAL NETWORK RESOURCE INTERCONNECTION SERVICE ASSESSMENT | 10 |
| 10.3 APPENDIX 3: PROPERTY REQUIREMENTS..... | 11 |
| 10.4 APPENDIX 4: TRANSMISSION/DISTRIBUTION STUDY RESULTS | 13 |

1.0 DESCRIPTION OF THE COMMUNITY SOLAR PROJECT

(“Applicant”) proposed interconnecting 1.4 MW of new generation to PacifiCorp’s (“Public Utility”) circuit 5L45 out of Hornet substation located in Klamath County, Oregon. The project (“Project”) will consist of eight (8) Delta M125HV inverters factory derated to 117 kW and four (4) Delta M125HV inverters factory derated to 116 kW for a total requested output of 1.4 MW. The requested commercial operation date is May 31, 2021.

The Public Utility has assigned the Project “OCS036.”

2.0 APPROVAL CRITERIA FOR TIER 4 INTERCONNECTION REVIEW

Pursuant to the Section I(1) of the Public Utility’s CSP Interconnection Procedures, a Public Utility must use the Tier 4 review procedures for an application to interconnect a Community Solar Project that meets the following requirements:

- (a) The Community Solar Project does not qualify for or failed to meet Tier 2 review requirements; and
- (b) The Community Solar Project must have a nameplate capacity of three (3) megawatts or less.

3.0 SCOPE OF THE STUDY

Pursuant to Section I(6)(g) of the CPS Interconnection Procedures, the System Impact Study Report shall consist of: (1) the underlying assumptions of the study; (2) a short circuit analysis; (2) a stability analysis; (3) a power flow analysis; (4) voltage drop and flicker studies; (5) protection and set point coordination studies; (6) grounding reviews; (7) the results of the analyses; and (8) any potential impediments to providing the requested Interconnection Service, including a non-binding informational NRIS portion that addresses the additions, modifications, and upgrades to the Public Utility’s Transmission System that would be required at or beyond the point at which the Interconnection Facilities connect to the Public Utility’s Transmission System to accommodate the interconnection of the CSP Project. In addition, the System Impact Study shall provide a list of facilities that are required as a result of the Community Solar Project request and non-binding good faith estimates of cost responsibility and time to construct.

4.0 PROPOSED POINT OF INTERCONNECTION

The Applicant’s proposed Community Solar Project is to be interconnected to the Public Utility’s distribution circuit 5L45 out of Hornet substation via a 12.0 kV primary meter. The proposed Point of Interconnection (“POI”) will be located at approximately 42°11'7.70"N, 121°41'12.42"W located in Klamath County, Oregon. Figure 1 below is a one line diagram that illustrates the interconnection of the proposed generating facility to the Public Utility’s system.



5.0 STUDY ASSUMPTIONS

- All active higher-priority requests for transmission service and/or generator interconnection service (including requests in the traditional interconnection queue and other requests in the Community Solar queue) in the local area of the requested POI will be considered in this study and are listed in Appendix 1. If any of these requests are withdrawn, the Public Utility reserves the right to restudy this request, as the results and conclusions contained within this study could significantly change.
- The Applicant's request for interconnection service in and of itself does not convey transmission service.
- This study assumes the Project will be integrated into Public Utility's system at the agreed upon and/or proposed POI.
- The Applicant will construct and own any facilities required between the POI and the Project unless specifically identified by the Public Utility.
- Line reconductor or fiber underbuild required on existing poles will be assumed to follow the most direct path on the Public Utility's system. If during detailed design the path must be modified it may result in additional cost and timing delays for the Applicant's project.
- Generator tripping may be required for certain outages.
- All facilities will meet or exceed the minimum Western Electricity Coordinating Council ("WECC"), North American Electric Reliability Corporation ("NERC"), and Public Utility performance and design standards.
- The PacifiCorp distribution facility point closest to the POI is 01439101.0-075001 on Keller Road east of Highway 39.
- Distribution load flows were performed at peak and light load and full and no generation with summer and winter loading conditions.
- This report is based on information available at the time of the study. It is the Applicant's responsibility to check the Public Utility's web site regularly for transmission system updates (<https://www.oasis.oati.com/ppw>)

6.0 REQUIREMENTS

6.1 COMMUNITY SOLAR PROJECT REQUIREMENTS

The Community Solar Project and Interconnection Equipment owned by the Applicant are required to operate under automatic power factor control with the power factor sensed electrically at the POI. The required power factor is 1.0 per unit at the POI.

In general, the Community Solar Project and Interconnection Equipment should be operated so as to maintain the voltage at the POI between 1.01 pu to 1.04 pu. At the Public Utility's discretion, these values might be adjusted depending on the operating conditions.

The minimum power quality requirements are in PacifiCorp's Engineering Handbook and are available at <https://www.pacificpower.net/about/power-quality-standards.html>.

Requirements in the System Impact Study that exceed requirements in the Engineering Handbook power quality standards shall apply.

All generators must meet applicable WECC low voltage ride-through requirements as specified in the interconnection agreement.

As per NERC standard VAR-001-1, the Public Utility is required to specify voltage or reactive power schedule at the POI. Under normal conditions, the Public Utility's system should not supply reactive power to the Community Solar Project.

6.2 TRANSMISSION SYSTEM MODIFICATIONS

No transmission system modifications are required to accommodate the proposed Applicant's facility.

6.3 DISTRIBUTION/TRANSMISSION LINE MODIFICATIONS

Extend #2 AAAC phase and neutral from Keller Road to the POI. The line extension includes a pole for primary metering and a pole with a 600 amp group operated switch.

6.4 EXISTING BREAKER MODIFICATIONS – SHORT-CIRCUIT

The increase in the fault duty on the system as the result of the addition of the generation facility with photovoltaic arrays fed through 8 – 117 kW inverters and 4 – 116 kW inverters connected to a 1.5 MVA 12 kV – 600 V transformer with 5.8 % impedance will not push the fault duty above the interrupting rating of any of the existing fault interrupting equipment.

6.5 PROTECTION REQUIREMENTS

The OCS036 generating facility will need to disconnect from the network in a high speed manner for faults on the 12 kV line, 5L45, out of Hornet substation. The minimum daytime load on the circuit can be less than 50% of the potential power output from the proposed OCS036 generating facility and the existing hydroelectric plant which is connected to the 12 kV circuit. For this reason the imbalance condition of the load and generation cannot be relied upon to cause the high speed disconnection of the generating facilities for faults on the distribution system. A transfer trip system will need to be installed as part of this project to cause the disconnection of the OCS036 generating facility for the opening of 5L45 at Hornet substation.

The 5L45 breaker relay circuitry is already equipped with dead line checking control circuitry to delay the automatic reclose if the generation on the circuit is not disconnected due to a failure of the relay circuitry at the timing for the reclose operation. The feeder relay on 5L45 will need to be replaced with a relay that can accommodate the communication for the transfer trip circuit.

For phase to ground faults on the other 12 kV feeder out of Hornet substation the fault current contribution from the OCS036 generating facility added with the fault current from the existing hydroelectric plant will be greater than the pickup value for the ground overcurrent element for the 5L45 feeder relay. The typical overcurrent element for a feeder relay is non-directional. With this arrangement the 5L45 circuit will be tripped for faults on the other 12 kV circuit. This will cause unnecessary interruption to the customers on

5L45. To prevent this type of operation the ground overcurrent elements for 5L45 will need to be set directional so as to only operate for faults on the 5L45 circuit. The new relay planned for the 5L45 breaker will have this capability.

The 12 kV circuit recloser planned to be installed at the OCS036 project will need to be equipped Schweitzer Engineering Laboratories (SEL) 651R relay/controller and voltage instrument transformers mounted on the utility side of the circuit recloser. The 651R will perform the following protection functions:

1. Detect faults on the 12 kV equipment at the solar-electric generation facility
2. Detect faults on the 12 kV line to Hornet Substation
3. Monitor the voltage and react to under or over frequency, and /or magnitude of the voltage
4. Receive transfer trip from Hornet substation

6.6 DATA REQUIREMENTS (RTU)

Due to the power size of the solar-electric generation facility no real time monitoring will be required by the Public Utility for the operation of the transmission network so no RTU will be required.

6.7 COMMUNICATION REQUIREMENTS

A communication system will need to be installed to carry the transfer trip signal between Hornet substation and the OCS036 POI recloser. If line of site is verified, an SEL-3031 spread-spectrum radio system will be installed between Hornet substation and the POI recloser. Field verification of the path will be required. The radio and support equipment will be installed in a cabinet at the recloser and in the Hornet substation control house. Poles to hold antennas will need to be installed at both locations. The existing pole in Hornet substation will likely need to be removed and replaced with a taller pole. Height of the poles will be dependent on the status of trees at the farm adjacent to Hornet substation. Install antennas and coax cable. Install SEL-2812 fiber optic transceivers between the RS232 ports and the relays.

If the trees in the adjacent farm are blocking the path and cannot be removed, ADSS cable will need to be installed between the two sites instead of the radio link.

6.8 SUBSTATION REQUIREMENTS

Hornet Substation

Minor modifications required to panel 3FF in the control building for installation of SEL-751.

6.9 METERING REQUIREMENTS

Interchange Metering

The metering will be located on the high side of the customer generator step up transformer at the POI. The metering will be installed overhead on a pole per distribution DM construction standards. The Public Utility will procure, install, test, and own all revenue

metering equipment. The metering will be bi-directional to measure KWH and KVARH quantities for both generation received and back feed retail load delivered. There will be no additional station service metering for supplying generation load. The metering generation and billing data will be remotely interrogated via the Public Utility's MV90 data acquisition system.

Station Service/Construction Power

The Applicant must arrange distribution voltage retail meter service for electricity consumed by the project when not generating. Temporary construction power metering shall conform to the Six State Electric Service Requirements manual. Applicant must call the PCCC Solution Center 1-800-640-2212 to arrange this service. Approval for back feed is contingent upon obtaining station service

7.0 COST ESTIMATE

The following estimate represents only scopes of work that will be performed by the Public Utility. Costs for any work being performed by the Applicant are not included.

| | |
|--|------------------|
| OCS036 Collector Substation | \$81,000 |
| <i>Install metering & communications equipment, develop relay settings</i> | |
| Distribution Line Extension | \$25,000 |
| <i>Install poles, switch and conductor</i> | |
| Hornet Substation | \$91,000 |
| <i>Install protection and communications equipment</i> | |
| Total | \$197,000 |

*Any distribution line modifications identified in this report will require a field visit analysis in order to obtain a more thorough understanding of the specific requirements. The estimate provided above for this work could change substantially based on the results of this analysis. Until this field analysis is performed the Public Utility must develop the Project schedule using conservative assumptions. The Applicant may request that the Public Utility perform this field analysis, at the Applicant's expense, prior to the execution of an Interconnection Agreement in order to obtain more cost and schedule certainty.

Note: Costs for any excavation, duct installation and easements shall be borne by the Applicant and are not included in this estimate. This estimate is as accurate as possibly given the level of detailed study that has been completed to date and approximates the costs incurred by Public Utility to interconnect this Community Solar Project to Public Utility's electrical distribution or transmission system. An estimate, based on finer detail, will be calculated during the Facilities Study. The Applicant will be responsible for all actual costs, regardless of the estimated costs communicated to or approved by the Applicant.

8.0 SCHEDULE

The Public Utility estimates it will require approximately 12-15 months to design, procure and construct the facilities described in this report following the execution of an Interconnection Agreement. The schedule will be further developed and optimized during the Facilities Study.

Please note, the time required to perform the scope of work identified in this report does not support the Applicant's requested commercial operation date of May 31, 2021.

9.0 PARTICIPATION BY AFFECTED SYSTEMS

Public Utility has identified the following Affected Systems: None

Copies of this report will be shared with each Affected System.

10.0 APPENDICES

Appendix 1: Higher Priority Requests

Appendix 2: Informational Network Resource Interconnection Service Assessment

Appendix 3: Property Requirements

Appendix 4: Distribution Study Results

10.1 APPENDIX 1: HIGHER PRIORITY REQUESTS

All active higher priority transmission service and/or generator interconnection and Community Solar Project requests will be considered in this study and are identified below. If any of these requests are withdrawn, the Public Utility reserves the right to restudy this request, as the results and conclusions contained within this study could significantly change.

Transmission/Generation Interconnection/Community Solar Queue Requests considered:

| Queue # | Size (MW) |
|---------|-----------|
| 660 | 10 |
| 721 | 55 |
| 741 | 40 |
| 849 | 100 |
| 905 | 50 |
| 971 | 2.7 |
| 1029 | 400 |
| 1031 | 80 |
| 1032 | 80 |
| 1033 | 80 |
| 1034 | 60 |
| 1055 | 4.2 |
| 1087 | 50 |
| 1104 | 3 |
| 1120 | 3 |
| 1126 | 8 |
| 1133 | 80 |
| 1134 | 120 |
| 1135 | 80 |
| 1147 | 2.999 |
| 1160 | 70 |
| 1192 | 238.5 |
| OCS003 | 0.8 |
| OCS004 | 0.8 |
| OCS019 | 0.882 |
| OCS020 | 0.594 |
| OCS025 | 2.8 |
| OCS033 | 1.0 |
| OCS034 | 0.978 |

10.2 APPENDIX 2: INFORMATIONAL NETWORK RESOURCE INTERCONNECTION SERVICE ASSESSMENT

The study results described above reflect an energy resource interconnection service (“ERIS”) evaluation, modified in the CSP program rules to examine only generation and load conditions local to the requested CSP project’s interconnection point (sometimes referred to as the “zoomed in view”). The “zoomed in view” functions to: (1) study the project’s proposed interconnection without considering certain existing or higher-queued requests outside of the local area; and (2) to inform whether the CSP facility must cap its project to mitigate, although not eliminate, the risk of potential deliverability-related network upgrades to accommodate the proposed CSP generator.

By contrast, the following informational section provides a network resource interconnection service (“NRIS”) evaluation performed with traditional assumptions, i.e., not modified to examine only local generation and load conditions, but rather one that assumes that all existing interconnections, higher-queued requests for interconnection service (in both the traditional and CSP queue), and generators with executed contracts beyond the local area are in-service. Depending on the severity of the conditions created when absorbing additional generation (capped or not capped) in that broader, “zoomed out” area, the local area-focused generator size cap developed in the “zoomed in” examination may not be sufficient to mitigate the need for deliverability-related network upgrades. Regardless of this report’s informational NRIS results, the deliverability-related network upgrades ultimately necessary to accommodate the proposed CSP generator will depend on conditions present when the future transmission service study is performed, as well as whether network upgrade alternatives are available at that time.

There are currently a significant number of higher-queued requests seeking interconnection in the southern Oregon area where the CSP generator proposes to interconnect. These interconnection studies must be completed before the transmission provider can determine what upgrades and associated cost estimates may be required for the aggregate of generation in the local area to be delivered to the aggregate of load on the transmission provider’s transmission system (the NRIS study scope).

10.3 APPENDIX 3: PROPERTY REQUIREMENTS

Requirements for rights of way easements

Rights of way easements will be acquired by the Applicant in the Public Utility's name for the construction, reconstruction, operation, maintenance, repair, replacement and removal of Public Utility's Interconnection Facilities that will be owned and operated by PacifiCorp. Applicant will acquire all necessary permits for the project and will obtain rights of way easements for the project on Public Utility's easement form.

Real Property Requirements for Point of Interconnection Substation

Real property for a POI substation will be acquired by an Applicant to accommodate the Applicant's project. The real property must be acceptable to Public Utility. Applicant will acquire fee ownership for interconnection substation unless Public Utility determines that other than fee ownership is acceptable; however, the form and instrument of such rights will be at Public Utility's sole discretion. Any land rights that Applicant is planning to retain as part of a fee property conveyance will be identified in advance to Public Utility and are subject to the Public Utility's approval.

The Applicant must obtain all permits required by all relevant jurisdictions for the planned use including but not limited to conditional use permits, Certificates of Public Convenience and Necessity, California Environmental Quality Act, as well as all construction permits for the project.

Applicant will not be reimbursed through network upgrades for more than the market value of the property.

As a minimum, real property must be environmentally, physically, and operationally acceptable to Public Utility. The real property shall be a permitted or able to be permitted use in all zoning districts. The Applicant shall provide Public Utility with a title report and shall transfer property without any material defects of title or other encumbrances that are not acceptable to Public Utility. Property lines shall be surveyed and show all encumbrances, encroachments, and roads.

Examples of potentially unacceptable environmental, physical, or operational conditions could include but are not limited to:

- Environmental: known contamination of site; evidence of environmental contamination by any dangerous, hazardous or toxic materials as defined by any governmental agency; violation of building, health, safety, environmental, fire, land use, zoning or other such regulation; violation of ordinances or statutes of any governmental entities having jurisdiction over the property; underground or above ground storage tanks in area; known remediation sites on property; ongoing mitigation activities or monitoring activities; asbestos; lead-based paint, etc. A phase I environmental study is required for land being acquired in fee by the Public Utility unless waived by Public Utility.

- Physical: inadequate site drainage; proximity to flood zone; erosion issues; wetland overlays; threatened and endangered species; archeological or culturally sensitive areas; inadequate sub-surface elements, etc. Public Utility may require Applicant to procure various studies and surveys as determined necessary by Public Utility.
- Operational: inadequate access for Public Utility's equipment and vehicles; existing structures on land that require removal prior to building of substation; ongoing maintenance for landscaping or extensive landscape requirements; ongoing homeowner's or other requirements or restrictions (e.g., Covenants, Codes and Restrictions, deed restrictions, etc.) on property which are not acceptable to the Public Utility.

10.4 APPENDIX 4: TRANSMISSION/DISTRIBUTION STUDY RESULTS

Transmission:

Three base cases were developed to represent heavy summer, heavy winter and light spring load conditions. A Power flow analysis was performed on each case for three system configurations.

1. Normal transmission configuration: Hornet substation in a radial 69 kV system configuration fed from Klamath Falls substation.
2. Contingency transmission configuration: 69 kV transmission line from Klamath Falls to Hornet substation is open. Hornet substation is switched to the Malin source via Henley substation. Bonanza and Casebeer substations are transferred to the Fish Hole source via Sprague River substation.

Each Power flow analysis was conducted pre and post OCS036. The study focused on the 69 kV system in the Klamath Falls area and distribution voltages at Hornet substation. Voltage and thermal limitation of surrounding substation buses and lines were monitored.

The results for the transmission study concluded that steady state and post transient voltages are within acceptable limits. No thermal violations were identified. The proposed OCS036 project does not result in additional deficiencies to the Public Utility's transmission system.

There are no contingent facilities identified for this interconnection request.

Distribution:

- The modeled power flow on Hornet Substation breaker 5L45 is 317 kW reverse power flow during light load and full generation.
- The modeled power flow on the Hornet Substation transformer T-3545 is 2461 kW forward power flow.